

2024 Annual Transmission Plan								
First Quarter(Q1)	Start Date	January	End Date	March				
Second Quarter(Q2)	Start Date	April	End Date	June				
Third Quarter(Q3)	Start Date	July	End Date	September				
Forth Quarter(Q4)	Start Date	October	End Date	December				
Transmission Group Outages								
System Elements	Work On	Duration (Days)	Start	Finish	Project Owner	Region	Comments	Restrictions
L-5530	L5530A/B (46W-36W)	22	1/3/2024	1/25/2024	Transmission Group	South Shore	L5530 Outage (46W-36W) for Structure and Insulator Replacement Work	
L-6047	L6047 Outage	1	1/3/2024	1/4/2024	Transmission Group	South Shore	L6047 Outage for Structure Replacement	
L-7005	L7005 Hold Off	5	1/3/2024	1/8/2024	Transmission Group	East/North East	L7005 Hold Off for climbing Inspection of Canso Towers	• Cape Breton Export is limited to 875 MW in summer, 1000 MW in winter. • Onslow Import is limited to 1050 MW in summer, 1150 MW in winter.
L-5028	L5028 Hold Off	10	1/8/2024	1/18/2024	Transmission Group	North East	L5028 Hold Off for new Lafarge Tap Construction	
L-5016	L5016 Outage (17V-20V)	17	1/8/2024	1/25/2024	Transmission Group	Valley	L5016 Outage (17V-20V) for Structure and Insulator Replacement Work	
L-5530	L5530 Outage (50W-46W)	24	1/29/2024	2/22/2024	Transmission Group	South Shore	L5530 Outage (50W-46W) for Structure and Insulator Replacement Work	
L-6516	L6516 Outage	38	1/29/2024	3/7/2024	Transmission Group	East	L6516 Outage for Structure and Insulator Replacements	
L-5534	L5534 Outage	31	2/5/2024	3/7/2024	Transmission Group	South Shore	L5534 Outage for Structure and Insulator Replacement Work	• Generation Restrictions in place.
L-5530	L5530C (36W-30W)	10	2/26/2024	3/7/2024	Transmission Group	South Shore	L5530 Outage (36W-30W) for Structure and Insulator Replacement Work	
L-6012	L6012 Outage	2	3/25/2024	3/27/2024	Transmission Group	Valley	L6012 Outage for Structure and Insulator Replacement Work	
L-7005	L7005 Outage	10	4/1/2024	4/11/2024	Transmission Group	East/North East	L7005 Outage for Conductor Repairs at the Canso Crossing	• Cape Breton Export is limited to 875 MW in summer, 1000 MW in winter. • Onslow Import is limited to 1050 MW in summer, 1150 MW in winter.
L-6516	L6516 (2C-22C) Outage	10	4/29/2024	5/9/2024	Transmission Group	East	L6516 (2C-22C) Outage for Interconnection Work	• Generation Restrictions in place.
L-6539	L6539 Outage	52	5/6/2024	6/27/2024	Transmission Group	East	L6539 (1115-35) Outage for Structure and Insulator Replacements	• Generation Restrictions in place.
L-8001/3025	L8001 Outage	3	5/6/2024	5/9/2024	Transmission Group	North East	L8001 Outage for Insulator Replacement Work	• NS-NB import and export restrictions in place. • Onslow Import is restricted to 1150 MW. • Cape Breton Export is restricted to 1000 MW in summer and 1150 MW in winter.
L-7012	L7012 Outage	10	5/13/2024	5/23/2024	Transmission Group	East	L7012 Outage for Interconnection Work	• Cape Breton Export is limited to 710 MW in summer, 875 MW in winter. • Onslow Import is limited to 965 MW in summer, 1140 MW in winter. • Generation restrictions in place.
L-7011	L7011 Outage	10	5/27/2024	6/6/2024	Transmission Group	East	L7011 Outage for Interconnection Work	• Cape Breton Export is limited to 875 MW in summer, 1025 MW in winter. • Onslow Import is limited to 1140 MW in summer, 1150 MW in winter. • Generation restrictions in place.
L-6040	L6040 Outage	31	6/3/2024	7/4/2024	Transmission Group	Metro	L6040 Outage for Overhead Guy Wire Replacement	
L-7002	L7002 Outage	10	6/3/2024	6/13/2024	Transmission Group	Metro/North East	L7002 Outage for Structure and Insulator Replacements	• Onslow South is restricted to 785 MW in summer and 900 MW in winter
L-6020	L6020 Outage	10	6/3/2024	6/13/2024	Transmission Group	South Shore	L6020 Outage for Structure and Insulator Replacements Phase 2	
L-8004	L8004 Outage	10	6/10/2024	6/20/2024	Transmission Group	East	L8004 Outage for Interconnection Work	• Hastings From is limited to 590 MW in summer, 730 MW in winter. • Mainland at Hastings/Cape Breton Export is limited to 570 MW in summer, 680 MW in winter. • Generation restrictions in place
L-6514	L6514 Outage	45	7/1/2024	8/15/2024	Transmission Group	North East	L6514 Outage for Structure and Insulator Replacements	
L-6549	L6549 Outage	31	7/1/2024	8/1/2024	Transmission Group	East	L6549 Outage for Structure and Insulator Replacements	
L-6536/1160 (Remote H/O)	L6536 Outage	45	7/15/2024	8/29/2024	Transmission Group	North East	L6536 Outage for Structure and Insulator Replacements	
L-7022	L7022 Outage	38	7/22/2024	8/29/2024	Transmission Group	East	L7022 Outage for Structure and Insulator Replacements	• Generation Restrictions in place.
L-6001	L6001 Outage	31	7/29/2024	8/29/2024	Transmission Group	Metro/North East	L6001 Outage for Structure and Insulator Replacements	
L-6551 (Remote H/O at 92N, not 30N)	L6551 Outage	32	9/9/2024	10/11/2024	Transmission Group	North East	L6551 Outage for Overhead Guy Wire Replacement	
L-7009	L7009 Outage	31	9/23/2024	10/24/2024	Transmission Group	Metro/South Shore	L7009 Outage for Structure and Insulator Replacements	
L-6006	L6006 Outage	26	10/7/2024	11/2/2024	Transmission Group	South Shore	L6006 Outage for Structure and Insulator Replacements	

System Maintenance Outages						
First Quarter(Q1)		Start Date		End Date	March	
Second Quarter(Q2)		Start Date		End Date	June	
Third Quarter(Q3)		Start Date		End Date	September	
Forth Quarter(Q4)		Start Date		End Date	December	
System Elements	Work On	Start	Duration (Days)	Project Owner	Region	Comments
433V	433V-D31	First Quarter (Q1)	2	System Maintenance	Valley	433V-D31 C Maintenance
98V	98V-D41	First Quarter (Q1)	2	System Maintenance	Valley	98V-D41 C Maintenance
427V	427V-D31	First Quarter (Q1)	2	System Maintenance	Valley	427V-D31 C Maintenance
22V	22V-D31	First Quarter (Q1)	2	System Maintenance	Valley	22V-D31 C Maintenance
4V	4V-D31	First Quarter (Q1)	2	System Maintenance	Valley	4V-D31 C Maintenance
3V	3V-D31	First Quarter (Q1)	2	System Maintenance	Valley	3V-D31 C Maintenance
411V	411V-D31	First Quarter (Q1)	2	System Maintenance	Valley	411V-D31 C Maintenance
110W	110W-661	First Quarter (Q1)	4	System Maintenance	South Shore	110W-661 C Maintenance
110W	110W-662	First Quarter (Q1)	4	System Maintenance	South Shore	110W-662 C Maintenance
110W	110W-419	First Quarter (Q1)	4	System Maintenance	South Shore	110W-419 C Maintenance
110W	110W-429	First Quarter (Q1)	4	System Maintenance	South Shore	110W-429 C Maintenance
110W	110W-439	First Quarter (Q1)	4	System Maintenance	South Shore	110W-439 C Maintenance
17V	17V-611	First Quarter (Q1)	4	System Maintenance	Valley	17V-611 C Maintenance
17V	17V-651	First Quarter (Q1)	4	System Maintenance	Valley	17V-651 C Maintenance
43V	43V Relay Testing	First Quarter (Q1)	14	System Maintenance	Valley	43V Electromechanical Relay Testing
51V	51V-301	First Quarter (Q1)	4	System Maintenance	Valley	51V-301 C Maintenance
16V	16V-314	First Quarter (Q1)	4	System Maintenance	Valley	16V-314 C Maintenance
16V	16V-315	First Quarter (Q1)	4	System Maintenance	Valley	16V-315 C Maintenance
36V	36V-302	First Quarter (Q1)	4	System Maintenance	Valley	36V-302 C Maintenance
22V	22V-314	First Quarter (Q1)	4	System Maintenance	Valley	22V-314 C Maintenance
110W	110W-CT61	First Quarter (Q1)	2	System Maintenance	South Shore	110W-CT61 C Maintenance
110W	110W-P411	First Quarter (Q1)	2	System Maintenance	South Shore	110W-P411 C Maintenance
110W	110W-P412	First Quarter (Q1)	2	System Maintenance	South Shore	110W-P412 C Maintenance
110W	110W-P421	First Quarter (Q1)	2	System Maintenance	South Shore	110W-P421 C Maintenance
110W	110W-P422	First Quarter (Q1)	2	System Maintenance	South Shore	110W-P422 C Maintenance
110W	110W-P423	First Quarter (Q1)	2	System Maintenance	South Shore	110W-P423 C Maintenance
17V-B63	17V-B63	First Quarter (Q1)	2	System Maintenance	Valley	17V-B63 C Maintenance
17V	17V-P6051	First Quarter (Q1)	2	System Maintenance	Valley	17V-P6051 C Maintenance
17V	17V-P6011	First Quarter (Q1)	2	System Maintenance	Valley	17V-P6011 C Maintenance
43V	43V-P6004	First Quarter (Q1)	2	System Maintenance	Valley	43V-P6004 C Maintenance
101W-D41	101W-D41 C Maintenance	First Quarter (Q1)	2	System Maintenance	South Shore	101W-D41 C Maintenance
413N	413N-D31	First Quarter (Q1)	2	System Maintenance	North East	C Inspection 413N-D31
3W	3W-D41 C Maintenance	First Quarter (Q1)	2	System Maintenance	South Shore	3W-D41 C Maintenance
79N	79N-L6508 "A" & "B" Protection	First Quarter (Q1)	1	System Maintenance	North East	NPCC Trip Testing 79N-L6508 "A" & "B" Protection
79N	79N-L6507 "A" & "B" Protection	First Quarter (Q1)	1	System Maintenance	North East	NPCC Trip Testing 79N-L6507 "A" & "B" Protection
30N	30N-D41	First Quarter (Q1)	2	System Maintenance	North East	C Inspection 30N-D41
67N	67N-321	First Quarter (Q1)	3	System Maintenance	North East	C Inspection 67N-321
79N	79N-411	First Quarter (Q1)	3	System Maintenance	North East	C Inspection 79N-411
93N	93N-D41	First Quarter (Q1)	2	System Maintenance	North East	C-Maintenance
120H	L7009 A-protection	First Quarter (Q1)	2	System Maintenance	Metro	NPCC A-protection trip testing (12 years)
104H	104H-D41	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
113H	113H-D41	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
131H	131H-D41	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
20H	20H-D31	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
82V	82V-D41	First Quarter (Q1)	1	System Maintenance	Metro/North East	C Maintenance
62H	62H-D41	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
426H	426H-D21	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance

90H	90H-D31	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
120H	120H-D41	First Quarter (Q1)	1	System Maintenance	Metro	NPCC C Maintenance
90H	90H-D41	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
120H	120H-D42	First Quarter (Q1)	1	System Maintenance	Metro	NPCC C Maintenance
99H	99H-D41	First Quarter (Q1)	1	System Maintenance	Metro	C Maintenance
415H	415H-D31	First Quarter (Q1)	1	System Maintenance	Metro	NPCC C Maintenance
415H	415H-D32	First Quarter (Q1)	1	System Maintenance	Metro	NPCC C Maintenance
91H	91H-B52	First Quarter (Q1)	2	System Maintenance	Metro	91H-B52 trip testing
1H	1H-427	First Quarter (Q1)	2	System Maintenance	Metro	C Maintenance
120H	120H-L6010	First Quarter (Q1)	2	System Maintenance	Metro	120H-L6010 A&B protection trip testing NPCC
1H	1H-461	First Quarter (Q1)	2	System Maintenance	Metro	C Maintenance
91H	91H-B51	First Quarter (Q1)	2	System Maintenance	Metro	91H-B51 NPCC trip testing
1H	1H-462	First Quarter (Q1)	2	System Maintenance	Metro	C Maintenance
120H	120H-L6016	First Quarter (Q1)	1	System Maintenance	Metro	120H-L6016 A & B protection NPCC trip testing
120H	120H-L7001	First Quarter (Q1)	1	System Maintenance	Metro	120H-L7001 A & B protection NPCC trip testing
120H	120H-L7002	First Quarter (Q1)	1	System Maintenance	Metro	120H-L7002 A & B protection NPCC trip testing
120H	120H-L7008	First Quarter (Q1)	1	System Maintenance	Metro	120H-L7008 A & B protection NPCC trip testing
91H	91H-T64	First Quarter (Q1)	11	System Maintenance	Metro	C Maintenance
108H	108H-600	First Quarter (Q1)	4	System Maintenance	Metro	C Maintenance
88W	88W-T51 C Maintenance	Second Quarter (Q2)	24	System Maintenance	South Shore	88W-T51 C Maintenance (SP-MS installed)
110W	110W-PB61	Second Quarter (Q2)	4	System Maintenance	South Shore	110W-PB61 C Maintenance
110W	110W-PT61	Second Quarter (Q2)	2	System Maintenance	South Shore	110W-PT61 C Maintenance
110W	110W-PT62	Second Quarter (Q2)	2	System Maintenance	South Shore	110W-PT62 C Maintenance
L-5532 (Remote H/O at 13V, not 3W)	3W-502 C Maintenance	Second Quarter (Q2)	4	System Maintenance	South Shore / Valley	3W-502 & 3P-5532 C Maintenance
67N	67N-B81 "A" & "B" Protection	Second Quarter (Q2)	2	System Maintenance	North East	NPCC Relay Testing 67N-B81 "A" & "B" Protection (EM)
67N	67N-B82 "A" & "B" Protection	Second Quarter (Q2)	1	System Maintenance	North East	NPCC Relay Testing 67N-B82 "A" & "B" Protection (EM)
410C	410C-D31	Second Quarter (Q2)	1	System Maintenance	East	C Inspection 410C-D31
L-5541	3W-P5541 C Maintenance	Second Quarter (Q2)	1	System Maintenance	South Shore	3W-P5541 C Maintenance
9W	9W-517 C Maintenance	Second Quarter (Q2)	3	System Maintenance	South Shore	Switching to isolate 9W-517 for C Maintenance
3W	3W-PB53 C Maintenance	Second Quarter (Q2)	1	System Maintenance	South Shore	3W-PB53 C Maintenance (bus outage)
67N	67N-711	Second Quarter (Q2)	3	System Maintenance	North East	C Inspection 67N-711
50W	50W-P1-69 C Maintenance	Second Quarter (Q2)	1	System Maintenance	South Shore	50W-P1-69 C Maintenance
50W	50W-P3-138 C Maintenance	Second Quarter (Q2)	1	System Maintenance	South Shore	50W-P3-138 C Maintenance
99W-546	99W-546 C Maintenance	Second Quarter (Q2)	4	System Maintenance	South Shore	Switching to isolate 99W-546 for C Maintenance
67N	67N-P7005	Second Quarter (Q2)	1	System Maintenance	North East	C Inspection 67N-P7005
75W	75W-T1 C Maintenance	Second Quarter (Q2)	25	System Maintenance	South Shore	75W-T1 C Maintenance (SP-MS Installed) 75W-PB61 C Maintenance
L-6531	50W-614 C Maintenance (Replacement)	Second Quarter (Q2)	25	System Maintenance	South Shore	Switching to isolate 50W-614 for Capital Replacement
L-6002	75W-604 C Maintenance	Second Quarter (Q2)	4	System Maintenance	Metro/South Shore	Switching to Isolate 75W-604 for C Maintenance
4N	4N-313	Second Quarter (Q2)	1	System Maintenance	North East	C Inspection 4N-313
L-6002	75W-603 C Maintenance	Second Quarter (Q2)	4	System Maintenance	Metro/South Shore	Switching to Isolate 75W-603 for C Maintenance
78C	78C-311	Second Quarter (Q2)	1	System Maintenance	East	C Inspection 78C-311
67N	67N-710	Second Quarter (Q2)	2	System Maintenance	North East	C Inspection 67N-710
70W	70W-T53 C Maintenance	Second Quarter (Q2)	25	System Maintenance	South Shore	70W-T51 C Maintenance (SP-MS Installed)
492C	429C-D31	Second Quarter (Q2)	1	System Maintenance	North East	C-Maintenance
82V	82V-T41G	Second Quarter (Q2)	18	System Maintenance	Metro/North East	82V-T41G C Maintenance
82V	82V-441	Second Quarter (Q2)	18	System Maintenance	Metro/North East	82V-441 C Maintenance
82V	82V-T41	Second Quarter (Q2)	18	System Maintenance	Metro/North East	82V-T41 C Maintenance
14H	14H-GT1	Second Quarter (Q2)	14	System Maintenance	Metro	14H-GT1 sudden pressure relay testing + C Maintenance
91H	91H-T65	Second Quarter (Q2)	15	System Maintenance	Metro	91H-T65 sudden pressure relay testing + C Maintenance
104H	104H-419	Second Quarter (Q2)	4	System Maintenance	Metro	C Maintenance
126H	126H-T71	Second Quarter (Q2)	28	System Maintenance	Metro	C Maintenance
91H	91H-T65	Second Quarter (Q2)	11	System Maintenance	Metro	C Maintenance line up with 91H-G5, 91H-UT35 outage
103H	103H-CTR411	Second Quarter (Q2)	2	System Maintenance	Metro	C Maintenance

91H	91H-G5	Second Quarter (Q2)	16	System Maintenance	Metro	91H-G5 U/F relays
90H-607	90H-607	Second Quarter (Q2)	4	System Maintenance	Metro	C Maintenance
91H	91H-T64	Second Quarter (Q2)	14	System Maintenance	Metro	91H-T64 sudden pressure relay testing + C Maintenance
101H	101H-600	Second Quarter (Q2)	4	System Maintenance	Metro	C Maintenance
101H	101H-638	Second Quarter (Q2)	4	System Maintenance	Metro	103H-638, 103H-CT638, 103H-P6038 C Maintenance
58H	58H-419	Second Quarter (Q2)	4	System Maintenance	Metro	C Maintenance
90H	90H-502	Second Quarter (Q2)	2	System Maintenance	Metro	C Maintenance
90H	90H-T1	Second Quarter (Q2)	18	System Maintenance	Metro	90H-T1 & 90H-503, 90H-PB51, 90H-PT1 C Maintenance
108H	108H-607	Second Quarter (Q2)	4	System Maintenance	Metro	C Maintenance
90H	90H-604	Second Quarter (Q2)	2	System Maintenance	Metro	C Maintenance
120H	120H-230 BBU	Second Quarter (Q2)	2	System Maintenance	Metro	120H-230 BBU NPCC testing
120H	120H-T71	Second Quarter (Q2)	18	System Maintenance	Metro	120H-T71 C Maintenance + NPCC trip tesitng
91H	91H-T11	Second Quarter (Q2)	11	System Maintenance	Metro	C Maintenance
104H	104H	Second Quarter (Q2)	1	System Maintenance	Metro	104H U/F relay testing NPCC
108H	108H	Second Quarter (Q2)	1	System Maintenance	Metro	108H U/F relay testing NPCC
10H	10H-T1	Second Quarter (Q2)	11	System Maintenance	Metro	C Maintenance
403S	403S-D31	Third Quarter (Q3)	1	System Maintenance	East	403S-D31 C Maintenance
16V	16V-T51	Third Quarter (Q3)	21	System Maintenance	Valley	16V-T51 C Maintenance
16V	16V-PB53	Third Quarter (Q3)	2	System Maintenance	Valley	16V-PB53 C Maintenance
95H	95H-PB51 (B)	Third Quarter (Q3)	2	System Maintenance	North East	C Inspection 95H-PB51 (B)
L-6548	2C-648	Third Quarter (Q3)	2	System Maintenance	East	2C-648 C Maintenance
50V	50V-T51	Third Quarter (Q3)	21	System Maintenance	Valley	50V-T51 C Maintenance
6V	6V-GT1	Third Quarter (Q3)	21	System Maintenance	Valley	6V-GT1 C Maintenance
20V	20V-T1	Third Quarter (Q3)	21	System Maintenance	Valley	20V-T1 C Maintenance
10V	10V-T1	Third Quarter (Q3)	21	System Maintenance	Valley	10V-T1 C Maintenance
110W	110W-T61	Third Quarter (Q3)	21	System Maintenance	South Shore	110W-T61 C Maintenance
110W	110W-T62	Third Quarter (Q3)	21	System Maintenance	South Shore	110W-T62 C Maintenance
406S	406S-D31	Third Quarter (Q3)	1	System Maintenance	East	406S-D31 C Maintenance
426C	426C-D31	Third Quarter (Q3)	1	System Maintenance	East	426C-D31 C Maintenance
L-6516	2C-649	Third Quarter (Q3)	2	System Maintenance	East	2C-649 C Maintenance
11S	11S-D41	Third Quarter (Q3)	1	System Maintenance	East	11S-D41 C Maintenance
81S	81S-D41	Third Quarter (Q3)	1	System Maintenance	East	81S-D41 C Maintenance
4S	4S-D41	Third Quarter (Q3)	1	System Maintenance	East	4S-D41 C Maintenance
411C	411C-D31	Third Quarter (Q3)	1	System Maintenance	East	411C-D31 C Maintenance
2C	2C-T61	Third Quarter (Q3)	1	System Maintenance	East	2C-T61 Sudden Pressure Relay Testing - NPCC Requirement
Lingan 1	87S-ET1	Third Quarter (Q3)	1	System Maintenance	East	87S-ET1 Sudden Pressure Relay Testing - NPCC Requirement
Lingan 1	87S-GT1	Third Quarter (Q3)	1	System Maintenance	East	NPCC Trip Testing 87S-GT1 "B" Protection (6 YEARS)
Lingan 2	87S-ET2	Third Quarter (Q3)	1	System Maintenance	East	87S-ET2 Sudden Pressure Relay Testing - NPCC Requirement
Lingan 2	87S-GT2	Third Quarter (Q3)	1	System Maintenance	East	NPCC Trip Testing 87S-GT2 "B" Protection (6 YEARS)
Lingan 3	87S-GT3	Third Quarter (Q3)	1	System Maintenance	East	NPCC Trip Testing 87S-GT3 "B" Protection (6 YEARS)
47C	47C-T67	Third Quarter (Q3)	3	System Maintenance	East	C Inspection 47C-T67
Lingan 1	87S-UT1	Third Quarter (Q3)	1	System Maintenance	East	87S-UT1 Sudden Pressure Relay Testing - NPCC Requirement
Lingan 2	87S-UT2	Third Quarter (Q3)	1	System Maintenance	East	87S-UT2 Sudden Pressure Relay Testing - NPCC Requirement
Lingan 2	87S-UT2	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 87S-UT2
Lingan 2	87S-ET2	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 87S-ET2
L-7003	3C L-7003	Third Quarter (Q3)	1	System Maintenance	East/North East	NPCC Trip Testing 3C-L7003 "A" & "B" Protection
Lingan 1	87S-UT1	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 87S-UT1
Lingan 1	87S-GT1	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 87S-GT1
Lingan 1	87S-ET1	Third Quarter (Q3)	5	System Maintenance	East	C Inspection 87S-ET1
2C	2C UFLS	Third Quarter (Q3)	1	System Maintenance	East	NPCC Testing 2C-U/F RELAYS (EM)
88S	88S 345kv SPS	Third Quarter (Q3)	1	System Maintenance	East	NPCC Trip Testing 88S 345kv SPS "A" & "B" Protection
88S	88S-D41	Third Quarter (Q3)	1	System Maintenance	East	NPCC Testing 88S-D41 Batteries (VLA)
85S	85S-D42	Third Quarter (Q3)	1	System Maintenance	East	NPCC Testing C Inspection 85S-D42 (VLA)
9C	9C-304	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 9C-304

L-7012	3C-P7012	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 3C-P7012
L-7003	3C-P7003	Third Quarter (Q3)	1	System Maintenance	East/North East	C Inspection 3C-P7003
Victoria Junction 1	83S-301	Third Quarter (Q3)	1	System Maintenance	East	83S-301 C Maintenance
Victoria Junction 2	83S-GT2	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 83S-GT2
3C	3C-715	Third Quarter (Q3)	1	System Maintenance	East	3C-715 C Maintenance
6P	6P	Third Quarter (Q3)	1	System Maintenance	Metro	6P Circuit Switch C Maintenance
L-6533	88S L-6533	Third Quarter (Q3)	1	System Maintenance	East	NPCC Trip Testing 88S-L6533 "A" & "B" Protection
L-6548	2C L-6548	Third Quarter (Q3)	1	System Maintenance	East	NPCC Relay Testing 2C-L-6548 (EM)
L-6534	88S L-6534	Third Quarter (Q3)	1	System Maintenance	East	NPCC Trip Testing 88S-L6534 "A" & "B" Protection
Lingan 2	87S-GT2	Third Quarter (Q3)	1	System Maintenance	East	87S-GT2 Sudden Pressure Relay Testing - NPCC Requirement
88S	88S 345kv SPS	Third Quarter (Q3)	1	System Maintenance	East	NPCC Relay Testing 88S 345kv SPS "A" & "B" Protection (Micro)
Lingan 1	87S-GT1	Third Quarter (Q3)	1	System Maintenance	East	87S-GT1 Sudden Pressure Relay Testing - NPCC Requirement
Victoria Junction 2	83S-GT2	Third Quarter (Q3)	1	System Maintenance	East	83S-GT2 Sudden Pressure Relay Testing - NPCC Requirement
67N	67N-PB31	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 67N-PB31
110W	110W-PB41	Third Quarter (Q3)	2	System Maintenance	South Shore	110W-PB41 C Maintenance
110W	110W-PB42	Third Quarter (Q3)	2	System Maintenance	South Shore	110W-PB42 C Maintenance
92N	92N-601	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-601
92N	92N-CT61	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-CT61
92N	92N-602	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-602
92N	92N-PB61	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-PB61
92N	92N-603	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-603
92N	92N-P6551	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-P6551
92N	92N-P6535	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-P6535
92N	92N-CT6535	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 92N-CT6535
89S	89S-UT1	Third Quarter (Q3)	3	System Maintenance	East	C Inspection 89S-UT1
89S	89S-GT1	Third Quarter (Q3)	1	System Maintenance	East	89S-GT1 Sudden Pressure Relay Testing - NPCC Requirement
89S	89S-ET1	Third Quarter (Q3)	1	System Maintenance	East	89S-ET1 Sudden Pressure Relay Testing - NPCC Requirement
89S	89S-ST1	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 89S-ST1
89S	89S-UT1	Third Quarter (Q3)	1	System Maintenance	East	89S-UT1 Sudden Pressure Relay Testing - NPCC Requirement
89S	89S-ET1	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 89S-ET1
Point Aconi	89S-GT1	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 89S-GT1
50N	50N-D33	Third Quarter (Q3)	1	System Maintenance	North East	C Inspection 50N-D33
91N	91N-230kv BBU	Third Quarter (Q3)	2	System Maintenance	North East	NPCC Trip Testing 91N-230kv BBU (6 Year Test)
91N	91N-B71	Third Quarter (Q3)	1	System Maintenance	North East	NPCC Trip Testing 91N-B71 (6 Year Test)
24C	24C-T54G3	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 24C-T54G3
24C	24C-T54G2	Third Quarter (Q3)	1	System Maintenance	East	C Inspection 24C-T54G2
120H-T72	120H-T72	Third Quarter (Q3)	23	System Maintenance	Metro	120h-t72 NPCC trip testing + C Maintenance
113H	113H-439	Third Quarter (Q3)	4	System Maintenance	Metro	C Maintenance
113H	113H-449	Third Quarter (Q3)	4	System Maintenance	Metro	C Maintenance
23H	23H	Third Quarter (Q3)	1	System Maintenance	Metro	23H U/F relay testing npcc
120H	120H-628	Third Quarter (Q3)	2	System Maintenance	Metro	120h-628 & 120h-CT628 C Maintenance
120H	120H-710	Third Quarter (Q3)	1	System Maintenance	Metro	C Maintenance
120H	120H-T72	Third Quarter (Q3)	11	System Maintenance	Metro	120H-T72 C Maintenance + NPCC trip testing + A protection
91H	91H-603	Third Quarter (Q3)	2	System Maintenance	Metro	C Maintenance
91H	91H-T65	Third Quarter (Q3)	2	System Maintenance	Metro	C Maintenance
48H	48H	Third Quarter (Q3)	1	System Maintenance	Metro	48H U/F relay testing NPCC
24C	24C-T54G1	Fourth Quarter (Q4)	1	System Maintenance	East	C Inspection 24C-T54G1
8C	8C-T41	Fourth Quarter (Q4)	11	System Maintenance	North East	C Inspection 8C-T41 (3P-MS)
30N	30N-P6514	Fourth Quarter (Q4)	1	System Maintenance	North East	C Inspection 30N-P6514
8C	8C-T42	Fourth Quarter (Q4)	11	System Maintenance	North East	C Inspection 8C-T42 (3P-MS)
67N	67N-712	Fourth Quarter (Q4)	3	System Maintenance	North East	C Inspection 67N-712
24C	24C-T54	Fourth Quarter (Q4)	4	System Maintenance	East	C Inspection 24C-T54
1N	1N-L6527 "A" & "B" Protection	Fourth Quarter (Q4)	1	System Maintenance	North East	NPCC Trip Testing 1N-L6527 "A" & "B" Protection