

# **Residential Virtual Solar Rough-In Inspections**

## **Checklist**

Photo	Requirements	Captured
Junction Boxes, Conductors	Photos must be taken of each junction box, conduit, and cable run	
Full Roof Layout Picture	Photos must be taken of the racking system from multiple angles, ensuring the complete array is included.	
Racking, cabling, connections	Photos must show rails with cables supported, bond conductors with complete connection points, and cable routing with jumped sections.	
Equipment Pictures	Photos must include all equipment and equipment labels with approval markings. All photos must be clear and legible.	
Conformation of Home Photo	Photos must include a wide shot showing the home to confirm that the array matches the property. The address or civic number should be visible, which can be displayed on a temporary sign.	
SLD	Same SLD submitted and approved by plans review, Add this to any section on the web submission form.	