
Nova Scotia Utility and Review Board

IN THE MATTER OF *The Public Utilities Act*, R.S.N.S. 1989, c.380, as amended

2023 10-Year System Outlook

NS Power

June 30, 2023

NON-CONFIDENTIAL

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

TABLE OF CONTENTS

1.0	INTRODUCTION	5
2.0	LOAD FORECAST	7
3.0	GENERATION RESOURCES.....	10
3.1	Existing Generation Resources	10
3.1.1	Maximum Unit Capacity Rating Adjustments.....	14
3.1.2	Mersey Hydro	14
3.1.3	Wreck Cove Hydro	15
3.2	Changes in Capacity	15
3.2.1	NS Power IRP Process.....	15
3.2.2	Brooklyn Power	18
3.2.3	Lingan Unit 2	18
3.2.4	Annapolis Tidal.....	19
3.3	Unit Utilization Forecast.....	20
3.3.1	Evolution of the Energy Mix in Nova Scotia.....	22
3.3.2	Projections of Unit Utilization	23
3.3.3	Steam Fleet Utilization Outlook	25
4.0	QUEUED SYSTEM IMPACT STUDIES.....	30
4.1	System Impact Studies (SIS).....	32
4.2	OATT Transmission Service Queue	32
5.0	ENVIRONMENTAL AND EMISSIONS REGULATORY REQUIREMENTS	34
5.1	Renewable Electricity Requirements	34
5.2	Environmental Regulatory Requirements.....	36
5.3	Anticipated Policy Changes.....	40
6.0	RESOURCE ADEQUACY	42
6.1	Operating Reserve Criteria.....	42
6.2	Planning Reserve Criteria	43
6.3	Capacity Contribution of Renewable Resources in Nova Scotia.....	44
6.4	Load and Resources Review	45
7.0	TRANSMISSION PLANNING	48
7.1	System Description	48

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

7.2	Transmission Design Criteria.....	49
7.2.1	Bulk Power System (BPS).....	50
7.2.2	Bulk Electric System (BES).....	50
7.2.3	2022 Bulk Electric System Exception Requests	51
7.2.4	Special Protection Systems (SPS).....	51
7.2.5	NPCC Directory 1 Review.....	51
7.3	Transmission Life Extension	52
7.4	Transmission Project Approval.....	52
7.5	New Large-Load Customer Interconnection Requests	53
8.0	TRANSMISSION DEVELOPMENT 2022 to 2033	54
8.1	Impact of Proposed Load Facilities	54
8.2	129H-Kearney Lake Relocation.....	54
8.3	Transmission Development Plans.....	55
8.4	Reliability Tie	58
8.5	Western Valley Transmission System – Phase II Study	58
9.0	CONCLUSION.....	60

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

TABLE OF FIGURES

Figure 1: Net System Requirement with Future DSM Program Effects (actuals not weather adjusted) 8

Figure 2: Coincident Peak Demand with Future DSM Program Effects 9

Figure 3: 2023 Firm Generating Capability for NS Power and IPPs 12

Figure 4: Firm Generating Capability for Wholesale Market Participants 13

Figure 5: Firm Capacity Changes & DSM 17

Figure 6: Additions and Retirements as in the 10-Year System Outlook Resource Plan 20

Figure 7: 2005, 2022 Actual and 2024 Forecast Energy Mix 22

Figure 8: NS Power Steam Fleet Unit Utilization Forecast 23

Figure 9: Utilization Factor 25

Figure 10: Forecast Unit Utilization Factors 27

Figure 11: Forecasted Sustaining Capital Investment (in 2023\$) by Unit 29

Figure 12: Combined T&D Advanced Stage Interconnection Queue as of June 28, 2023 30

Figure 13: Requests in the OATT Transmission Queue as of June 28, 2023 32

Figure 14: RES Compliance Forecast 35

Figure 15: Multi-year Greenhouse Gas Emission Limits 36

Figure 16: Greenhouse Gas Free Allowances 2019-2022 37

Figure 17: Emissions (SO₂, NO_x, Hg) 38

Figure 18: NS OBPS Emission Intensity Standards 40

Figure 19: NS Power 10-Year Load and Resources Outlook 46

Figure 20: NS Power Major Facilities in Service 2023 48

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 **1.0 INTRODUCTION**

2
3 Delivering clean, reliable and lowest cost energy is NS Power’s commitment to customers. NS
4 Power is committed to supplying 80 percent clean energy and phasing out coal generation by 2030.
5 The Company has made great strides towards these goals by more than tripling the amount of
6 renewable energy on the grid over the last decade. In order to achieve its commitment to
7 customers, NS Power performs planning and resource adequacy assessments while adhering to the
8 Nova Scotia Wholesale and Renewable to Retail Electricity Market Rules.

9
10 In accordance with the 3.4.2.1¹ Market Rule requirements, this report provides the 10-Year System
11 Outlook on behalf of the Nova Scotia Power System Operator (NSPSO) for 2023. The 10-Year
12 System Outlook is not an integrated resource planning exercise. It is the NSPSO’s annual
13 assessment of Nova Scotia Power Incorporated’s (NS Power, Company) system capacity and
14 adequacy.

15
16 The Report contains the following information:

- 17
- 18 • A summary of the NS Power load forecast and an update on the Demand Side Management
19 (DSM) forecast in **Section 2.0**.
 - 20 • A summary of generation expansion anticipated for facilities owned by NS Power and
21 others in **Section 3.0**. NS Power’s generation planning for existing facilities, including
22 retirements as well as investments in upgrades, refurbishment or life extension, and new
23 generating facilities committed in accordance with previously approved NSPSO system
24 plans.

¹ Nova Scotia Wholesale and Renewable to Retail Electricity Market Rules (as amended 2016 06 10), Market Rule 3.4.2 states, “The NSPSO system plan will address: (a) transmission investment planning; (b) DSM programs operated by EfficiencyOne or others; (c) NS Power generation planning for existing Facilities, including retirements as well as investments in upgrades, refurbishment or life extension; (d) new Generating Facilities committed in accordance with previous approved NSPSO system plans; (e) new Generating Facilities planned by Market Participants or Connection Applicants other than NS Power; and (f) requirements for additional DSM programs and / or generating capability (for energy or ancillary services).”

2023 10-Year System Outlook
NON-CONFIDENTIAL

- 1 • A summary of environmental and emissions regulatory requirements, as well as forecast
2 compliance in **Section 5.0**. Section 5.0 also includes projections of the level of renewable
3 energy forecast and discusses anticipated policy changes.
- 4 • A Resource Adequacy Assessment in **Section 6.0**.
- 5 • A discussion of transmission planning considerations in **Sections 7.0 and 8.0**.
- 6

7 The previous (2022) 10-year System Outlook report relied on outcomes of the 2020 NS Power
8 Integrated Resource Plan (IRP), which evaluated a robust set of future planning scenarios, with
9 modeling assumptions that incorporated stakeholder input. 2020 IRP Scenario 3.1C was chosen
10 as the basis for the 2022 10YSO as it best reflected the load and policy landscape at the time², as
11 opposed to the original 2020 IRP reference plan (Scenario 2.0C).

12

13 Since that time and in accordance with NS Power’s IRP Action Plan Update³ and 2022 Evergreen
14 IRP Study Scope and Timeline,⁴ NS Power has completed a focused evaluation and refinement of
15 the long-term electricity strategy⁵ developed as part of the 2020 IRP that reflects the current
16 planning environment. The results of the evergreen IRP work⁶ have assessed a range of future
17 planning scenarios reflecting various potential system planning outcomes. Evergreen IRP scenario
18 CE1-E1-R2 (net zero 2035, current policy and trends for electrification, no Atlantic Loop) has
19 been selected as the basis for the 2023 10-year System Outlook report. Please refer to **Section 3.0**
20 for a more detailed discussion of the evergreen IRP and the selected reference scenario.

21

² 2020 IRP Scenario 3.1C reflected the mid-electrification load profile, base demand side management assumptions, access to a Regional Interconnection, and retirement of coal by 2030.

³ M10504, Nova Scotia Power IRP Action Plan Update, January 21, 2022.

⁴ M10504, Nova Scotia Power IRP Evergreen Study Scope. April 6, 2022.

⁵ M10504, Nova Scotia Power IRP Action Plan Roadmap.

⁶ [2022 Evergreen IRP - NSP Integrated Resource Planning \(nspower.ca\)](https://www.nspower.ca/2022-Evergreen-IRP-NSP-Integrated-Resource-Planning)

1 **2.0 LOAD FORECAST**

2
3 The NS Power load forecast provides an outlook on the energy and peak demand requirements of
4 customers in the province. The load forecast forms the basis for fuel and power-purchase supply
5 planning, investment planning, and overall operating activities of NS Power. The figures presented
6 in this Report are the same as those filed with the NSUARB in the 2023 Load Forecast Report⁷ on
7 April 29, 2023, and were developed using NS Power’s statistically adjusted end-use (SAE) model
8 to forecast the residential and commercial rate classes. The residential and commercial SAE
9 models are combined with an econometric-based industrial forecast and customer-specific
10 forecasts for NS Power’s large customers to develop an energy forecast for the province, also
11 referred to as the Net System Requirement (NSR).

12
13 **Figure 1** shows historical and forecast NSR which includes in-province energy sales plus system
14 losses. Compared to the 2022 Load Forecast, the 2023 Load Forecast shows accelerated growth in
15 the near term due to increased customer addition forecasts and higher average use when adjusted
16 for weather. Mid to long-term growth is driven by sustained customer growth and higher Electric
17 Vehicle (EV) sales driven by the federal government’s goal of achieving 60 percent zero-emissions
18 vehicle sales by 2030 and 100 percent by 2035. Sales through the Renewable to Retail (RTR)
19 market are forecast to reduce load in the 2024-2025 timeframe by approximately 136 GWh. In
20 the long term, energy sales will be reduced by Demand Side Management (DSM) initiatives and
21 natural energy efficiency improvements outside structured DSM programs, as well as increased
22 behind-the-meter solar installations. The net result is an average annual increase in Net System
23 Requirement of 0.7 percent.

24

⁷ M11108, Nova Scotia Power 2023 Load Forecast Report, April 28, 2023.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 **Figure 1: Net System Requirement with Future DSM Program Effects (actuals not weather**
2 **adjusted)**

3

Year	NSR (GWh)	Growth (%)
2013	11,194	6.9
2014	11,037	-1.4
2015	11,099	0.6
2016	10,809	-2.6
2017	10,873	0.6
2018	11,250	3.5
2019	11,077	-1.5
2020	10,723	-3.2
2021	10,902	1.7
2022	11,134	2.1
2023*	11,288	1.4
2024*	11,168	-1.1
2025*	11,199	0.3
2026*	11,327	1.1
2027*	11,416	0.8
2028*	11,531	1.0
2029*	11,616	0.7
2030*	11,720	0.9
2031*	11,838	1.0
2032*	11,998	1.4
2033*	12,113	1.0

4 *Forecast value

5
6 NS Power also forecasts peak hourly demand for future years. The system peak is defined as the
7 highest single hourly average demand experienced in a year. It includes both firm and interruptible
8 loads. Due to the weather-sensitive load component in Nova Scotia, the system peak occurs in the
9 period from December through February.

10
11 The peak demand forecast is developed using end-use energy forecasts combined with peak-day
12 weather conditions to generate monthly peak demand forecasts through an estimated monthly peak
13 demand regression model. The peak contribution from large customer classes is calculated from
14 historical coincident load factors for each of the rate classes. Peak savings related to Demand
15 Response (DR) activities, adjusted for Effective Load Carrying Capability (ELCC) as outlined in

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 the 2020 IRP and including critical peak pricing and direct load control components, are included
 2 in the firm peak. Customer growth and increased EV sales will increase the peak, while DSM
 3 activities will reduce the peak. As a result, the system peak demand is expected to increase by 2.3
 4 percent annually over the forecast period. The firm contribution to peak demand is expected to
 5 increase by 2.2 percent annually over the forecast period. **Figure 2** shows the historical and
 6 forecast net system peak.

7

8 **Figure 2: Coincident Peak Demand with Future DSM Program Effects**

9

Year	Interruptible Contribution to Peak (MW)	Demand Response (reduction in Firm Peak only, MW)	Firm Contribution to Peak (MW)	Net System Peak (MW)	Growth (%)
2013	136	-	1,897	2,033	8.0
2014	83	-	2,036	2,118	4.2
2015	141	-	1,874	2,015	-4.9
2016	98	-	2,013	2,111	4.8
2017	67	-	1,951	2,018	-4.4
2018	80	-	1,993	2,073	2.7
2019	111	-	1,949	2,060	-0.6
2020	96	-	1,954	2,050	-0.5
2021	94	-	1,875	1,968	-4.0
2022	155	4	2,061	2,216	12.6
2023*	146	12	2,105	2,256	1.8
2024*	147	24	2,111	2,271	0.7
2025*	148	36	2,119	2,291	0.9
2026*	156	39	2,148	2,340	2.1
2027*	157	39	2,198	2,395	2.3
2028*	157	39	2,259	2,454	2.5
2029*	157	38	2,325	2,520	2.7
2030*	156	38	2,395	2,589	2.8
2031*	156	38	2,468	2,662	2.8
2032*	156	38	2,545	2,738	2.9
2033*	156	37	2,627	2,819	3.0

10 *Forecast value

11

12 As with any forecast, there is a degree of uncertainty around actual future outcomes. In electricity
 13 forecasting, much of this uncertainty is due to the impact of variations in weather, energy

1 efficiency program effectiveness, the health of the economy, government policy, the impact of
2 electrification, changes in large customer loads, the number of electric appliances and end-use
3 equipment installed, and changes in technology.

4 5 **3.0 GENERATION RESOURCES**

6 7 **3.1 Existing Generation Resources**

8
9 NS Power's generation portfolio is composed of a mix of fuel and technology types that include
10 coal, petroleum coke, light and heavy fuel oil, natural gas, biomass, wind, hydro and solar. In
11 addition, NS Power purchases energy from Independent Power Producers (IPPs) located in the
12 province and imports power across the NS Power/NB Power intertie and the Maritime Link. Since
13 the implementation of the *Renewable Electricity Standards* (RES) discussed in Section 5.1, an
14 increased percentage of total energy is produced by variable renewable resources such as wind.
15 However, due to their intermittent nature, these variable resources provide less firm capacity, as a
16 percentage of net operating capacity, than conventional generation resources. Therefore, the
17 majority of the system requirement for firm capacity is met with NS Power's conventional units
18 (e.g. coal, gas) while their energy output is displaced by renewable resources when they are
19 producing energy. This is discussed further in **Section 3.3** below.

20
21 **Figure 3** lists NS Power's and the IPPs' verified and forecast firm generating capability for
22 generating stations/systems along with their fuel types up to the filing date of this Report. The
23 changes and additions over the 10-year period to this total capacity are shown in **Figure** . The firm
24 generating capability for the wholesale market participants is set out in **Figure 4**.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 **Figure 3: 2023 Firm Generating Capability for NS Power and IPPs**

2

Plant/System	Fuel Type	Winter Net Capacity (MW) ⁸
Avon	Hydro	6.4
Black River	Hydro	21.4
Lequille System	Hydro	23.0
Bear River System	Hydro	35.5
Tusket	Hydro	2.3
Mersey System	Hydro	33.9
St. Margaret's Bay	Hydro	10.3
Sheet Harbour	Hydro	10.2
Dickie Brook	Hydro	3.6
Wreck Cove	Hydro	201.4
Annapolis Tidal ⁹	Hydro	0.0
Fall River	Hydro	0.5
Maritime Link NS Base Block	Hydro	145.4
Total Hydro		493.8
Tufts Cove	Heavy Fuel Oil/Natural Gas	318
Trenton	Coal/Pet Coke/Heavy Fuel Oil	304
Point Tupper	Coal/Pet Coke/Heavy Fuel Oil	150
Lingan ¹⁰	Coal/Pet Coke/Heavy Fuel Oil	607
Point Aconi	Coal/Pet Coke & Limestone Sorbent (CFB)	168
PH Biomass		43
Total Steam		1590
Tufts Cove Units 4, 5 & 6	Natural Gas	144
Total Combined Cycle		144
Burnside	Light Fuel Oil	132
Tusket	Light Fuel Oil	33

⁸ Wind, Hydro and solar are Effective Load Carrying Capability (ELCC) values. Please refer to Section 6.3 for further information.

⁹ Annapolis is assumed to be out of service. Please refer to Section 3.2..

¹⁰ Lingan Unit 2 will be retained in cold reserve in order to provide firm capacity for the upcoming winter (2023/2024). Please refer to Section 3.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

Plant/System	Fuel Type	Winter Net Capacity (MW) ⁸
Victoria Junction	Light Fuel Oil	66
Total Combustion Turbine		231
Pre-2001 Renewables	Independent Power Producers (IPPs)	25.7
Post-2001 Renewables (firm)	IPPs	64.9
NS Power wind (firm)	Wind	14.5
Community-Feed-in-Tariff (firm) ¹¹	IPPs	29.6
Solar	Solar	0.1
Tidal	Tidal	0.1
Total IPPs & Renewables		134.9
Total Capacity		2593.7

1
2
3

Figure 4: Firm Generating Capability for Wholesale Market Participants

Wholesale Market Participant	Fuel Type	Winter Net Capacity ¹² (MW)
Backup Top-Up (BUTU) ¹³	Wind [Ellershouse ¹⁴]	4.2
Backup Top-Up (BUTU)	Municipal Tariff ¹⁵	0
Total		4.2

4
5

¹¹ Existing Energy Resource Interconnection Service (ERIS) and Network Resource Interconnection Service (NRIS) wind projects are assumed to have a firm capacity contribution of 18 percent as detailed in Section 6.3.1.

¹² M09940, UARB Backup/Top-up Service (BUTU) decision to use 18 percent ELCC for wind and 0 percent for non-firm Imports to align with current NS Power planning practices (page 38).

¹³ Wholesale Market Backup/Top-up Service (BUTU) Tariff participants currently include the Municipal load for Berwick, Mahone Bay, Antigonish and Riverport.

¹⁴ Ellershouse wind farm owned by Alternative Resource Energy Authority (AREA).

¹⁵ Energy requirement needs now met by NS Power under the Municipal Tariff (2023), previously met by imports delivered via the Nova Scotia/New Brunswick Intertie.

1 **3.1.1 Maximum Unit Capacity Rating Adjustments**

2
3 As a member of the Maritimes Area of the Northeast Power Coordinating Council (NPCC), NS
4 Power meets the requirement for generator capacity verification as outlined in North American
5 Electric Reliability Corporation (NERC) Standard *MOD-025-2 Verification and Data Reporting*
6 *of Generator Real and Reactive Power Capability and Synchronous Condenser Reactive Power*
7 *Capability*¹⁶ which was approved by Federal Energy Regulatory Commission (FERC) on March
8 20, 2014 and approved by the NSUARB for effect in the province on July 1, 2016.

9
10 The Net Operating Capacity of the thermal units and large hydro units covered by the NERC
11 criteria are current. NS Power will continue to update unit maximum capacities in the 10-Year
12 System Outlook each year as operational conditions change.

13
14 **3.1.2 Mersey Hydro**

15
16 NS Power continues to assess options to address current concerns on the Mersey Hydro System.
17 Degradation of the powerhouses and water control structures after nearly a century of service has
18 necessitated the need for future significant redevelopment work. The Mersey Hydro System is an
19 important part of NS Power’s hydro assets and is responsible for approximately 25 percent of
20 annual domestic hydroelectric production. The Company has increased its sustaining capital from
21 now until 2030 to reflect the shifted start of the larger Mersey Hydro System redevelopment
22 project.

23
24 In the current Evergreen IRP study, the Mersey hydro system is modeled as being retained
25 throughout the planning horizon. To account for the status of the redevelopment project work, the
26 derated adjusted forced outage rate (DAFOR) has been increased to account for potential
27 additional outage hours on the Mersey Hydro System. In addition, the modeled Effective Load

¹⁶ <https://www.nerc.com/pa/Stand/Pages/Project2007-09-Generator-Verification.aspx>

1 Carrying Capability (ELCC) has been reduced to 85 percent; this is reflected in the firm generating
2 capacity table (please see **Figure 3**).

3 4 **3.1.3 Wreck Cove Hydro**

5
6 The Wreck Cove Hydro system is an important asset for NS Power, providing critical and
7 renewable generation for peak demand periods. With the ability to quickly provide 212 MW of
8 peak capacity from two operating units and average annual generation of 300 GWh, Wreck Cove
9 is NS Power's largest hydroelectric system. As part of the Life Extension and Modernization
10 (LEM) Project, the two unit turbines will be replaced with newly designed turbine runners which
11 will have increased efficiency and a wider operating range over the existing ones. While the change
12 in turbine runners will not change the peak capacity of 212 MW, it will provide a forecast increase
13 of 5 percent to the annual generation from Wreck Cove. The completion of this project will bring
14 the average annual generation at Wreck Cove to 315 GWh per year.

15 16 **3.2 Changes in Capacity**

17 18 **3.2.1 NS Power IRP Process**

19
20 Since the completion of the 2020 IRP, there have been significant changes to the electricity
21 planning environment, which include the following (please refer to the February 2023 IRP Action
22 Plan Update for more details¹⁷):

- 23
24 • 2030 targets including 80 percent renewable energy standards and phase-out of coal
25 generation (please see **Section 6.0**).
- 26 • Nova Scotia Output-Based Pricing System implementation and the associated Federal
27 carbon price trajectory to \$170/tonne in 2030 (please refer to **Section 6.0** for further
28 discussion).

¹⁷ [PowerPoint Presentation \(nspower.ca\)](https://www.nspower.ca)

2023 10-Year System Outlook
NON-CONFIDENTIAL

- 1 • The pausing of the Eastern Clean Energy Initiative (ECEI) project investments as an
2 outcome of the passage of Bill 212, which limits non-fuel rate increases to 1.8 percent to
3 the end of 2024.
- 4 • Announcement of the Federal Investment Tax Credit for qualifying renewable energy,
5 storage and delivery resources.
- 6 • The accelerating pace of load growth in the province as discussed in **Section 2.0**.
- 7 • The awarding of PPAs associated with the Provincial Rate Base Procurement program.¹⁸

8
9 The Evergreen IRP process is NS Power’s approach to assess and refine its IRP Action Plan and
10 Roadmap items. The Evergreen modeling aligns NS Power’s electricity strategy with the current
11 planning and policy environment.

12
13 For the purposes of the 2023 10 Year System Outlook Report, NS Power has selected scenario
14 CE1-E1-R2 (net zero 2035, current policy and trends electrification, no Atlantic Loop) as the
15 resource plan that is representative of the range of scenarios evaluated in the 2023 evergreen IRP
16 and aligned with the current planning environment. This scenario is among the lowest cost plans
17 evaluated which achieves the 2030 decarbonization targets and the Federal target of a net zero
18 electricity system in 2035. The remainder of the Report uses scenario CE1-E1-R2 as the reference
19 resource plan.

20
21 NS Power will continue to be responsive to ongoing changes in the electricity planning
22 environment, including but not limited to potential advancement of the Atlantic Loop¹⁹, the pace
23 of economy-wide electrification, and development of alternative peak mitigation strategies. NS
24 Power will also monitor developments in emerging technologies in alignment with Federal policy
25 discussion papers which point to these technologies as part of the path to a net zero electricity
26 system. The emerging technologies considered in the evergreen IRP include hydrogen fueled

¹⁸ [Nova Scotia Rate Base Procurement \(novascotiarp.com\)](https://www.novascotiarp.com)

¹⁹ In the evergreen IRP analysis, scenario CE1-E1-R1 BD, which includes a bidirectional Atlantic Loop in 2030, was the lowest cost plan modeled. The addition of the Atlantic Loop and associated wind offset the need for approximately 300MW of alternative firm capacity resources cumulatively through 2030. The balance of the resource mix through the period is similar; accordingly CE1-E1-R2 continues to be representative of the overall system resource mix anticipated for this 10-year period.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 combustion turbines, small modular reactors, tidal, natural gas generation with carbon capture &
2 storage, and long duration energy storage. These resources are not currently commercially
3 available but were evaluated as potential future resources in the evergreen IRP modeling. Although
4 they were not economically selected in the evergreen IRP modeling, NS Power will continue to
5 monitor the development of these potential resources and reassess as needed.

6
7 **Figure 5** below shows the anticipated DSM and firm capacity changes over the ten-year period
8 starting in 2024.

9
10 **Figure 5: Firm Capacity Changes & DSM**

11

New Resources 2024-2033	Net MW
DSM Peak reduction	245
Demand Response (Firm contribution) ²⁰	37
Total Demand Side MW Change Projected Over Planning Period	282
Maintenance/Repairs:	
Hydro derates during Wreck Cove LEM	-101
Wreck Cove LEM completion	101
Additions:	
Biomass	43
Tidal	2
New Wind Build (Rate Base Procurement) (Firm capacity)	37
Battery (Firm capacity)	114
Fast Acting Generation	870
Point Tupper 2 Coal-to-Gas conversion	150
New Wind Build (Firm capacity)	160
Other Wind (Firm capacity) ²¹	13

²⁰ Represents the firm contribution of demand response programs in 2033 assuming an ELCC of 48 percent. Refer to Section 2.0, Figure 2 for the annual DR totals from 2024 to 2033.

²¹ Represents the Pirate Harbour Wind project

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

New Resources 2024-2033	Net MW
Lingan 1, 3 & 4 HFO Operation	459
Retirements:	
Trenton 5 & 6	-304
Lingan 1, 2, 3 & 4 (Coal Operation)	-607
Point Tupper (Coal Operation)	-150
Point Aconi	-168
Total Firm Supply MW Change Projected Over Planning Period	635

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

3.2.2 Brooklyn Power

Brooklyn Power owns a 24 MW firm dispatchable renewable energy Biomass facility located in Liverpool, Nova Scotia. NS Power purchases energy from Brooklyn Power under a long-term power purchase agreement (PPA). On February 18, 2022 high winds caused damage to the unit's power stack and warehouse, ultimately taking the unit offline. Repairs to the facility have since been completed and the facility was brought back online in early 2023.

3.2.3 Lingan Unit 2

Effective August 15, 2022, Lingan Unit 2 was laid up and not made available for economic dispatch. The unit was placed into cold reserve and available to be recalled on two weeks' notice. Over winter 2022/2023, the unit was recalled to service eight times by the NSPSO to support firm customer load, generating a total of 404 GWh.

During the Wreck Cove LEM project scheduled outages, Lingan Unit 2 will be available, if needed, to provide firm capacity and maintain an adequate planning reserve margin (**Section 6.2**) for the upcoming winter (2023/2024).

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 In NS Power’s Wreck Cove LEM capital application,²² the single-unit winter outages were
2 identified as requiring an offsetting capacity replacement. At the time of the application, NS Power
3 estimated the costs of replacement capacity and included this cost in its LEM project application.
4 As discussed in the February 2023 IRP Action Update, near-term firm import opportunities over
5 existing transmission interfaces are unavailable for winter 2023/2024. With Lingan Unit 2 phased
6 out of economic dispatch for energy provision but available to provide firm capacity for winter
7 2023/2024 (recallable on two weeks’ notice), NS Power maintains sufficient capacity to meet its
8 planning reserve margin requirements.

9
10 As new firm capacity resources are added to the system, retaining existing thermal units in cold
11 reserve can support commissioning, testing and establishment of reliable operations without
12 compromising the planning reserve margin requirements. This will be considered and assessed as
13 plans for new resources are progressed.

14
15 **3.2.4 Annapolis Tidal**

16
17 The Annapolis Tidal Generating Station ceased generation in January 2019 following the failure
18 of a crucial station component. Subsequently, NS Power completed an analysis to determine
19 whether continued reinvestment in the facility was the lowest cost option for customers.
20 Ultimately, NS Power made the determination that the facility should be retired. In February 2021,
21 NS Power applied to the NSUARB²³ for approval to treat the generating station as Not Used and
22 Not Useful in accordance with approved accounting policies, and for approval to amortize the
23 unrecovered net book value of the assets over a 10-year period. On January 14, 2022 the NSUARB
24 concluded that it was not yet in a position to find the asset Not Used and Not Useful. The NSUARB
25 will reconsider the application for the requested accounting treatment if NS Power resubmits it
26 with a decommissioning application. NS Power is continuing capital planning activities with
27 respect to the generating station and is engaging in discussions with Fisheries and Oceans Canada.

²² M09596, NS Power Wreck Cove Life Extension and Modernization – Unit Rehabilitation and Replacement, CI 13838, February 28, 2020.

²³ M10013, NS Power Application re Annapolis Tidal Generation Station Retirement: Request for Accounting Treatment and Net Book Value Recovery (P-111.6), February 22, 2021.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 NS Power provided a status update to the NSUARB on March 9, 2023 indicating that the
2 Company, along with the relevant environmental regulators (DFO), continues to assess the
3 Annapolis Tidal Generating Station. Another update will be provided to the NUARB on July 31,
4 2023. For the purposes of the 2023 10-Year System Outlook, NS Power has assumed no capacity
5 or energy contribution from the Annapolis Tidal Generating Station.

6
7 **3.3 Unit Utilization Forecast**

8
9 The Company typically forecasts 10 years of utilization and investment projections in this Report.
10 These projections inform NS Power’s asset planning approach and are used to guide investment
11 strategies. There are many operational factors, such as the prices of fuel and power or changes in
12 policy, electricity demand, or regulation that could trigger a significant shift in the utilization
13 forecast to provide the most economic system dispatch for customers. A summary of the
14 anticipated system additions and retirements is set out below in **Figure 6**.

15
16 **Figure 6: Additions and Retirements as in the 10-Year System Outlook Resource Plan**

17

Winter	Additions	Retirements
2024/2025	<ul style="list-style-type: none">• New wind additions (Rate Base Procurement) (Installed capacity 194 MW, firm 19.4MW based on marginal ELCC of 10%)• New wind additions (Installed capacity 130MW, firm 13MW based on marginal ELCC of 10%)	
2025/2026	<ul style="list-style-type: none">• New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%)• Battery Storage (Installed capacity 30MW, firm 25.6MW)	Lingan 2 (-148 MW)
2026/2027	<ul style="list-style-type: none">• New wind additions (Rate Base Procurement) (Installed capacity 178.2 MW, firm 17.8 MW based on marginal ELCC of 10%)• New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%)	

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

Winter	Additions	Retirements
	<ul style="list-style-type: none"> Battery Storage (Installed capacity: 10MW; firm capacity: 8MW) Combustion turbine (50 MW) 	
2027/2028	<ul style="list-style-type: none"> Combustion turbines (200 MW) New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%) Battery Storage (Installed capacity: 50MW; firm capacity: 33MW) 	Trenton 5 (-150 MW)
2028/2029	<ul style="list-style-type: none"> Combustion turbines (350 MW) Point Tupper 2 coal-to-gas conversion (150 MW) New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%) Battery Storage (Installed capacity: 50 MW; firm capacity: 25MW) 	Point Aconi, Point Tupper 2 & Trenton 6 (-472 MW)
2029/2030	<ul style="list-style-type: none"> Combustion turbines (50 MW) Coal to HFO operation (Lingan 1, 3, 4; 459MW) New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%) 	Lingan 1, 3, 4 (- 459 MW)
2030/2031	<ul style="list-style-type: none"> Combustion turbines (50 MW) New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%) Battery Storage (Installed capacity: 60MW; firm capacity: 23MW) 	
2031/2032	<ul style="list-style-type: none"> Reciprocating engine (20 MW) New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%) 	
2032/2033	<ul style="list-style-type: none"> Combustion turbines (150 MW) New wind additions (Installed capacity 200 MW, firm 20 MW based on marginal ELCC of 10%) 	


1
2 Since many of the resource additions listed are currently in the development stage, there may be
3 adjustments in timing for planned in-service dates and corresponding retirement dates. NS Power
4 will continue to make adjustments as required.

5

3.3.1 Evolution of the Energy Mix in Nova Scotia

NS Power’s energy production mix has undergone significant changes over the last 15 years. Since the implementation of the RES, an increased percentage of energy sales is produced by variable renewable resources such as wind. However, due to their intermittent nature, variable resources provide less firm capacity, as a percentage of net operating capacity, than conventional generation resources. Therefore, the majority of the system requirement for firm capacity and other ancillary services is met with NS Power’s conventional units (i.e. coal, gas, diesel, hydro) as discussed in Sections 3.1, while the energy output of conventional units is being displaced by renewable resources. Figure 7 below illustrates this change with the actual energy mix from 2005 and 2022 and the updated forecast for 2024.

Figure 7: 2005, 2022 Actual and 2024 Forecast Energy Mix



**2023 10-Year System Outlook
NON-CONFIDENTIAL**

3.3.2 Projections of Unit Utilization

NS Power’s projected utilization of each of the units in the thermal generating fleet is set out below in **Figure 8**.

Figure 8: NS Power Steam Fleet Unit Utilization Forecast

		2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Lingan 1 ²⁴	Capacity Factor (%)	31	38	29	28	32	11	1	1	2	1
	Unit Cycles	12	24	23	24	24	23	6	4	5	5
	Service Hours	3,201	4,438	3,540	3,301	3,968	1,344	116	103	183	142
Lingan 2 ²⁵	Capacity Factor (%)	0	0	0	0	0	0	0	0	0	0
	Unit Cycles	0	0	0	0	0	0	0	0	0	0
	Service Hours	0	0	0	0	0	0	0	0	0	0
Lingan 3 ²⁴	Capacity Factor (%)	30	14	14	11	17	8	1	2	2	2
	Unit Cycles	48	24	22	24	23	24	7	8	10	7
	Service Hours	3,238	1,734	1,685	1,250	1,880	957	171	209	273	242
Lingan 4 ²⁴	Capacity Factor (%)	35	23	26	15	22	10	2	2	2	2
	Unit Cycles	18	24	21	22	24	24	5	6	7	7
	Service Hours	3,495	2,632	3,101	1,651	2,607	1,191	176	182	247	222
Point Aconi	Capacity Factor (%)	32	10	1	4	2	0	0	0	0	0
	Unit Cycles	9	8	4	6	3	0	0	0	0	0
	Service Hours	3,289	1,015	160	488	226	0	0	0	0	0

²⁴ Lingan units operate on HFO from 2030-2033.

²⁵ See Section 3.2.4

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

Point Tupper ²⁶	Capacity Factor (%)	39	59	41	55	53	7	2	1	2	2
	Unit Cycles	40	21	24	24	21	12	8	9	10	5
	Service Hours	4,722	5,831	4,071	5,391	5,235	862	254	161	270	219
Trenton 5	Capacity Factor (%)	16	17	12	14	0	0	0	0	0	0
	Unit Cycles	4	15	12	9	0	0	0	0	0	0
	Service Hours	1,769	1,896	1,244	1,514	0	0	0	0	0	0
Trenton 6	Capacity Factor (%)	64	44	37	50	21	0	0	0	0	0
	Unit Cycles	11	19	21	21	7	0	0	0	0	0
	Service Hours	6,802	4,920	4,333	5,649	2,386	0	0	0	0	0
Tufts Cove 1	Capacity Factor (%)	24	5	5	1	2	1	5	3	5	4
	Unit Cycles	16	23	20	8	6	4	14	7	12	11
	Service Hours	2,443	591	482	139	189	125	447	285	467	367
Tufts Cove 2	Capacity Factor (%)	25	18	8	5	3	16	20	16	17	12
	Unit Cycles	29	60	44	32	11	63	62	65	46	45
	Service Hours	2,960	2,351	1,087	763	324	1,763	2,142	1,676	1,679	1,240
Tufts Cove 3	Capacity Factor (%)	41	21	14	12	7	26	30	23	28	21
	Unit Cycles	27	65	72	65	31	74	89	83	80	79
	Service Hours	4,829	2,865	2,018	1,803	926	3,081	3,340	2,525	3,067	2,322
Tufts Cove 4	Capacity Factor (%)	73	68	57	61	61	68	62	56	57	43
	Unit Cycles	92	100	174	149	142	205	222	214	209	206
	Service Hours	7,135	6,810	5,426	5,705	5,756	6,420	5,822	5,240	5,355	4,051
Tufts Cove 5	Capacity Factor (%)	71	63	56	60	58	65	62	55	57	44
	Unit Cycles	104	112	193	147	154	222	237	221	206	218
	Service Hours	7,024	6,440	5,247	5,694	5,459	6,091	5,827	5,186	5,379	4,120

1

²⁶ Point Tupper is converted to Natural Gas in 2028.

2023 10-Year System Outlook
NON-CONFIDENTIAL

Tufts Cove 6	Capacity Factor (%)	54	44	37	37	39	46	45	40	41	34
	Unit Cycles	100	57	128	87	87	137	161	159	145	161
	Service Hours	5,734	6,799	5,868	6,257	6,020	6,111	5,598	5,074	5,225	4,082

1

2 **3.3.3 Steam Fleet Utilization Outlook**

3

4 Unit utilization and reliability objectives have long been the drivers for unit investment planning.
 5 Traditionally, in a predominantly base-loaded generation fleet, it was sufficient to consider
 6 capacity factor as the source for utilization forecasts for any given unit. This is no longer the case;
 7 integration of variable renewable resources on the NS Power system has imposed revised operating
 8 and flexibility demands to integrate wind generation on previously base-loaded steam units.
 9 Therefore, it is also necessary to consider the effects of unit starts, operating hours, flexible
 10 operating modes (e.g. ramping and two-shifting) and asset health along with the forecast unit
 11 capacity factors.

12

13 NS Power created the concept of utilization factor (UF) for the purpose of providing a directional
 14 understanding of the future use of each generating unit. This approach enables the Company to
 15 better demonstrate the demands placed upon NS Power’s generating units given their planned
 16 utilization. The UF for each unit is evaluated by considering the forecast capacity factor, annual
 17 operating hours, unit starts, expected two-shifting, and a qualitative evaluation of asset health. By
 18 accounting for these operational capabilities, the value brought to the power system by these units
 19 is more clearly reflected. Please refer to **Figure 9** below.

20

21 **Figure 9: Utilization Factor**

$$U_{Factor}^{Utilization} = fn \left\{ \begin{array}{l} \text{Capacity} \\ \text{Factor} \end{array} \right. \left. \begin{array}{l} \text{Service} \\ \text{Hours} \end{array} \right. \left. \begin{array}{l} \text{Cycles} \end{array} \right. \left. \begin{array}{l} \text{Asset} \\ \text{Health} \end{array} \right\}$$

22

23 The UF parameters are assessed to more completely describe the operational outlook for the steam
 24 fleet and direct investment planning. The four parameters are described below.

2023 10-Year System Outlook
NON-CONFIDENTIAL

- 1 • Capacity factor reflects the energy production contribution of a generating unit and is a
2 necessary constituent of unit utilization. It is a part of the utilization factor determination
3 rather than the only consideration, as it would have been in the past.
4
- 5 • Service hours have become a more important factor to consider with increased penetration
6 of variable-intermittent generation, as units are frequently running below their full capacity
7 while providing load following and other essential reliability services for wind integration.
8 For example, if a unit operates at 50 percent of its capacity for every hour of the year, then
9 the capacity factor would be 50 percent. In a traditional model, this would suggest a
10 reduced level of investment required, commensurate with decreased capacity factor.
11 However, many failure mechanisms are a function of operating hours (e.g. turbines, some
12 boiler failure mechanisms, and high energy piping) and the number of service hours (which
13 in this example is every hour of the year) is not reflected by the unit's capacity factor.
14 Additionally, some failure mechanisms can be exacerbated by reducing load operation (e.g.
15 valves, some pumps, throttling devices).
16
- 17 • Unit cycling increases damage mechanisms on many components (e.g. turbines, motors,
18 breakers, and fatigue in high energy piping systems) and accelerates failure mechanisms;
19 therefore, these must also be considered to properly estimate the service interval and
20 appropriate maintenance strategies.
21
- 22 • Asset health is a critical operating parameter to keep at the forefront of all asset
23 management decisions. For example, asset health may determine if a unit is capable of
24 two-shifting (unit is shut down during low load overnight and restarts to serve load the next
25 day). Although it does not necessarily play directly into the UF function, it can be a
26 dominant determinant in allowing a mode of operation; therefore, it influences the UF
27 function.
28

29 While the UF rating provides a directional understanding of the future use of each generating unit,
30 the practice of applying it has another layer of sophistication as system parameters change. NS

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 Power utilizes the PLEXOS dispatch optimization model to derive utilization forecasts and
 2 qualitatively assess the UF of each unit by evaluating the components described above. **Figure 10**
 3 below provides the UF by each unit on an annual basis.

4
 5 **Figure 10: Forecast Unit Utilization Factors**

Unit***	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
LIN-1**	M	M	M	M	M	M	M	UL	UL	UL	UL
LIN-2	UL	-	-	-	-	-	-	-	-	-	-
LIN-3**	M	M	M	M	M	M	M	UL	UL	UL	UL
LIN-4**	M	M	M	M	M	M	M	UL	UL	UL	UL
POA-1	M	L	UL	UL	UL	UL	UL	-	-	-	-
POT-2*	M	M	H	M	H	H	UL	UL	UL	UL	UL
TRE-5	L	L	L	L	L	-	-	-	-	-	-
TRE-6	H	H	M	M	H	L	-	-	-	-	-
TUC-1	L	L	UL	UL	UL	UL	UL	UL	UL	UL	UL
TUC-2	M	M	H	M	M	L	H	H	H	M	M
TUC-3	M	M	H	H	H	M	H	H	H	H	H
TUC-4	H	H	H	H	H	H	H	H	H	H	H
TUC-5	H	H	H	H	H	H	H	H	H	H	H
TUC-6	H	H	H	H	H	H	H	H	H	H	H
PHB-1	H	H	H	H	H	H	H	H	H	H	H

*POT-2 values from 2029 onwards reflect operation post natural gas conversion

**LIN-1, 3 and 4 values from 2030 onwards reflect operation on Heavy Fuel Oil (HFO)

***H = High, M = Medium, L = Low, UL = Ultra Low

6 **Figure 11** below provides the projected sustaining investments based on the anticipated utilization
 7 forecast in **Section 3.3.2**. Estimates of unit sustaining investment are forecast by applying the UF,

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 related life consumption and known failure mechanisms. NS Power does not include unplanned
2 failures in sustaining capital estimates. These estimates are evaluated at the asset class level; some
3 asset class projections are prorated by the UF and others have additional overriding factors. For
4 example, the use of many instrument and electrical systems is a function of calendar years, as they
5 operate whether a unit is running or not. Investments for coal and ash systems are a direct function
6 of capacity factor, as they typically have material volume-based failure mechanisms. In contrast,
7 the UF is directly applicable to the investment associated with turbines, boilers and high energy
8 piping. Major assets are regularly reassessed in terms of their condition and intended service as
9 NS Power's operational data, utilization plan, asset health information, and forecasts are updated.


10
11 The overarching investment philosophy is to maintain unit reliability cost effectively while
12 minimizing undepreciated capital. Mitigating risks by using less intensive investment strategies
13 is a method executed throughout the thermal fleet. Major outage intervals are extended where
14 possible to reduce large investments in the thermal fleet.

15

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 **Figure 11: Forecasted Sustaining Capital Investment (in 2023\$) by Unit**

2



3

4 Note: Forecast investments are subject to change arising from asset health and actual utilization. Changes in
5 currency value, escalation and inflation can also have significant effect on actual cost.

6

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 **4.0 QUEUED SYSTEM IMPACT STUDIES**

2

3 **Figure 12** below provides the location and size of the generating facilities currently in the
 4 Combined Transmission & Distribution (T&D) Advanced Stage Interconnection Request Queue.
 5 Active transmission and distribution requests not appearing in the Combined T&D Advanced
 6 Stage Interconnection Request Queue are considered to be at the initial queue stage, as they have
 7 not yet proceeded to the system impact study (SIS) stage of the Generator Interconnection
 8 Procedures (GIP) or Distribution Generator Interconnection Procedures (DGIP).

9

10 The Port Hawkesbury Biomass generating unit (63.8 MW gross / 45 MW net output) is presently
 11 an energy resource interconnection service (ERIS)-classified resource which will be converted to
 12 network resource interconnection service (NRIS) following the system upgrades associated with
 13 Transmission Service Request 400 which is discussed further in Section .

14

15 **Figure 12: Combined T&D Advanced Stage Interconnection Queue as of June 28, 2023**

16

Queue Order	IR#	Request Date DD-MMM-YY	County	MW Summer	MW Winter	Inter-connection Point	Type	In-Service date DD-MMM-YY ²⁷	Status	Service Type
1-T	426	27-Jul-12	Richmond	45	45	47C	Biomass	01-Sep-18	Generation Interconnection Agreement (GIA) Executed	NRIS
2-T	516	5-Dec-14	Cumberland	1.26	1.26	37N	Tidal	31-May-20	GIA Executed	NRIS
3-T	540	28-Jul-16	Hants	14.1	14.1	17V	Wind	31-Oct-23	GIA Executed	NRIS
4-T	542	26-Sep-16	Cumberland	3.78	3.78	37N	Tidal	30-Jun-25	GIA Executed	NRIS
5-D	557	19-Apr-17	Halifax	5.6	5.6	24H	CHP	01-Sep-18	SIS Complete	N/A
6-T	517	15-Dec-14	Cumberland	4	4	37N	Tidal	01-Oct-2019	GIA In progress	NRIS
7-D	569	26-Jul-19	Digby	0.6	0.6	509V-302	Tidal	30-Jul-21	GIA Executed	N/A

²⁷ The In-Service dates listed reflect the milestone dates specified in the interconnection agreement with the Interconnection Customer associated with each individual Interconnection Request or as last specified by the Interconnection Customer in interconnection study related agreements.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

Queue Order	IR#	Request Date DD-MMM-YY	County	MW Summer	MW Winter	Inter-connection Point	Type	In-Service date DD-MMM-YY ²⁷	Status	Service Type
8-D	566	16-Jan-19	Digby	0.7	0.7	509V-301	Tidal	30-Apr-22	GIA Executed	N/A
9-T	574	27-Aug-20	Hants	58.8	58.8	L-6051	Wind	30-Jun-23	Facilities Study (FAC) in Progress	NRIS
10-T	598	13-May-21	Cumberland	2.52	2.52	37N	Tidal	01-Dec-22	SIS Milestones Met	NRIS
11-D	604	7-Jun-21	Cape Breton	0.45	0.45	11S-303	Solar	15-Jan-22	GIA Executed	N/A
12-T	597	07-May-21	Queens	36	36	50W	Wind	31-Aug-23	FAC Complete	NRIS
13-T	647	6-Oct-21	Cumberland	1.5	1.5	37N	Tidal	31-Dec-23	GIA in progress	NRIS
14-D	653	19-Jan-22	Halifax	0.09	0.09	24H-406	Solar	30-Oct-22	SIS in progress	N/A
15-D	654	16-Feb-22	Halifax	0.125	0.125	127H-413	Solar	20-Sep-22	SIS in progress	N/A
16-T	664	26-Jul-22	Lunenburg	50	50	99W	Battery	15-Dec-23	SIS in progress	NRIS
17-T	662	26-Jul-22	Halifax	50	50	132H	Battery	15-Dec-24	SIS in progress	NRIS
18-T	663	26-Jul-22	Colchester	50	50	1N	Battery	15-Jun-24	SIS in progress	NRIS
19-T	670	05-Aug-22	Colchester	97.98	97.98	L-7005	Wind	28-Feb-26	SIS in progress	NRIS
20-T	671	05-Aug-22	Halifax	88.96	88.96	L-6004	Wind	28-Feb-26	SIS in progress	NRIS
21-T	669	04-Aug-22	Cumberland	99	99	L-6613	Wind	31-Dec-25	SIS in progress	NRIS
22-T	668	03-Aug-22	Antigonish	94.4	94.4	L-7003	Wind	01-Dec-25	SIS in progress	NRIS
23-T	618	21-Jul-21	Guysborough	130.2	130.2	L-7003	Wind	01-Jan-25	SIS in progress	NRIS
24-T	673	09-Aug-22	Hants	33.6	33.6	L-6054	Wind	31-Dec-24	SIS in progress	NRIS
25-T	675	10-Aug-22	Queens	112.5	112.5	50W	Wind	01-Dec-24	SIS in progress	NRIS
26-T	677	23-Sep-22	Yarmouth	80	80	L-6024	Wind	31-Dec-25	SIS in progress	NRIS
27-D	676	15-Aug-22	Halifax	0.74	0.6475	103H-431	Solar	01-Jun-22	SIS in progress	N/A
28-T	697	28-Mar-23	Kings	50	50	43V	Battery	15-Mar-26	SIS Agreement in Place	NRIS
D-29	699	21-Apr-23	Halifax	0.625	0.625	58H-431	Solar	31-Dec-24	SIS Agreement in Place	N/A
30-D	700	21-Apr-23	Cape Breton	0.585	0.585	82S-303	Solar	30-Sep-23	SIS Agreement in Place	N/A
31-D	701	28-Apr-23	Halifax	0.5625	0.5625	139H-412	Solar	01-Nov-23	SIS Agreement in Place	N/A
32-T	686	23-Jan-23	Cumberland	340	340	L-8002	Wind	01-Dec-25	SIS in progress	N/A

1
2

4.1 System Impact Studies (SIS)

As outlined in **Figure 12**, a significant number of SIS have been completed or are in progress. Of the SIS either in progress or complete, the majority are studying wind generation facilities. With the associated increase in variable renewable inverter-based generation on the system and the anticipated decrease in synchronous generation related to the coal-fired generation phase-out requirement by 2030, GIP SIS analyses are being expanded to include Electromagnetic Transient (EMT) Analysis in addition to Load Flow and Dynamic Analysis to understand the impacts of generator interconnections and requirements to support system reliability. Each transmission SIS initiated after March 3, 2023 will have a phase 2 EMT study completed for each SIS grouping to determine if additional equipment/network upgrades are required to support the integration of new wind resources. This will be completed in parallel with the facilities study and will inform the overall system requirements for each interconnection customer.

4.2 OATT Transmission Service Queue

As of June 20, 2023 there are two active requests in the Open Access Transmission Tariff (OATT) Transmission Queue as shown in **Figure 13**.

Figure 13: Requests in the OATT Transmission Queue as of June 28, 2023

Item	Project	Date & Time of Service Request	Project Type	Project Location	Requested In-Service Date	Project Size (MW)	Status
1	TSR 400	July 22, 2011	Point-to-point	NS-NB*	May 2019	330	System Upgrades in Progress
2	TSR 411	January 19, 2021	Point-to-point	NS-NB*	January 1, 2028	550	Facilities Study in Process

*Indicates project as being located near provincial border.

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 Information in **Figure 13** under Project Location reflects the non-confidential information
2 provided in the customer’s application. Details regarding the location of the generating
3 facility(ies) supplying the capacity and energy and the location of the load ultimately served by
4 the capacity and energy transmitted are deemed confidential under Section 17.2 of the OATT²⁸
5 and not available to the public on the Open Access Same-Time Information System (OASIS). As
6 such, there is limited further information the Company can include in this Report on a non-
7 confidential basis.

8
9 The design for the remaining system upgrades related to Transmission Service Request (TSR) 400
10 was completed in 2022. The execution of the remaining upgrades (increase the rating of lines L-
11 8004 and L-6613) is planned for 2024/2025.

12
13 A Facilities Study (FAC) is currently being performed for TSR 411, with a forecast completion
14 date of Q3 2023.

²⁸ Nova Scotia Power Inc. Open Access Transmission Tariff As approved by the UARB May 31, 2005 and As Amended June 10, 2016. The OATT is available on NS Power’s website at https://www.nspower.ca/docs/default-source/pdf-to-upload/revised-oatt-june-10-2016.pdf?sfvrsn=7d69fd73_0

1 **5.0 ENVIRONMENTAL AND EMISSIONS REGULATORY REQUIREMENTS**

2
3 **5.1 Renewable Electricity Requirements**

4
5 On July 9, 2021 the Province of Nova Scotia amended the *Renewable Electricity Regulations* to
6 add a RES of 80 percent of energy sales beginning in 2030. NS Power was directed to meet this
7 requirement, in part, through the acquisition of 1,100 GWh of new renewable energy from
8 independent power producers. The Province also announced on July 10, 2021 that it was initiating
9 a procurement targeting 1,100 GWh of electricity from renewable sources as part of its Rate Base
10 Procurement program. The procurement administrator identified the portfolio in August 2022,
11 awarding 372 MW of total installed wind capacity. The selected projects will all be in service by
12 December 31, 2026.²⁹

13
14 On April 8, 2016 the Province amended the *Renewable Electricity Regulations* to allow NS Power
15 to include COMFIT projects in its RES compliance planning. It also amended the Regulations to
16 remove the “must-run” requirement of the Port Hawkesbury biomass generating facility.³⁰ From
17 2015 to 2019 the Company served 26.6 percent (2015), 28 percent (2016), 29 percent (2017), 30
18 percent (2018) and 30 percent (2019) of sales using qualifying renewable energy sources.

19
20 The Nova Scotia block of the Muskrat Falls energy from Newfoundland & Labrador began
21 delivery over the Maritime Link on August 15, 2021. However, ongoing issues prevented the full
22 delivery of energy from Muskrat Falls, and the Company was unable to meet the 40 percent
23 renewable energy standard over the three calendar years (2020-2022). For the years 2020, 2021
24 and 2022, the Company served 29 percent (2020), 30.4 percent (2021) and 36 percent (2022) of
25 sales using qualifying renewable energy sources. NS Power is now receiving the full NS block.

26

²⁹ [Timeline | Nova Scotia Rate Based Procurement \(novascotiarp.com\)](https://www.novascotiarp.com)

³⁰ *Renewable Electricity Regulations*, made under Section 5 of the *Electricity Act* S.N.S. 2004, c. 25 O.I.C. 2010-381 (effective October 12, 2010), N.S. Reg. 155/2010 as amended to O.I.C. 2020-147 (effective May 5, 2020), N.S. Reg. 74/2020 s. 5(2A).

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 The near-term RES Compliance Forecast in **Figure 14** illustrates the full amount of RES-eligible
2 energy forecast to be available to the Company for 2024-2026.

3

4 **Figure 14: RES Compliance Forecast**

5

RES Compliance Forecast³¹			
	2024	2025	2026
Energy Requirements (GWh)			
NSR including DSM effects	11,168	11,199	11,327
Losses	734	741	741
Sales	10,434	10,458	10,586
RES (%) Requirement	40%	40%	40%
RES Requirement (GWh)	4,174	4,183	4,232
Renewable Energy Sources (GWh)			
NS Power Wind	239	260	234
Post-2001 IPPs*	739	2130	2543
PH Biomass	289	208	212
COMFIT Wind Energy	508	532	499
COMFIT Non-Wind Energy	17	26	26
Eligible Pre-2001 IPPs	111	16	16
Eligible NSPI Legacy Hydro	919	918	957
REA procurement (South Canoe/Sable)	328	344	296
Compliant Renewable Import	2346	2362	2364
Forecast Renewable Energy (GWh)	5,496	6,797	7,147
Forecast Surplus or Deficit (GWh)	110	2,614	3,517
Forecast RES Percentage of Sales	53%	65%	68%

6 *Includes Rate Base Procurement

7

³¹ NSR and Losses are provided in the 2022 NS Power Load Forecast Report, Table A1, April 29, 2022 (M10109).

1 **5.2 Environmental Regulatory Requirements**

2
3 The Nova Scotia *Greenhouse Gas Emissions Regulations*³² specify emission caps for 2010-2030,
4 as outlined in **Figure 15**. The net result is a hard cap reduction from 10.0 to 4.5 million tonnes
5 over that 20-year period, which represents a 55 percent reduction in CO₂ release over 20 years.
6 Carbon emissions in Nova Scotia from the production of electricity in 2030 are forecast to have
7 decreased by 58 percent from 2005 levels.

8
9 **Figure 15: Multi-year Greenhouse Gas Emission Limits**

10

Year	GHG Cumulative Million tonnes (CO₂)
2014-2016	26.32
2017-2019	24.06
2020	7.5 (annual)
2021-2024	27.5
2025	6 (annual)
2026-2029	21.5
2030	4.5 (annual)

11
12 Further discussion of the *Environmental Goals and Climate Change Reduction Act* (EGCCRA) is
13 provided in **Section 5.2**.

14
15 On January 1, 2019, Nova Scotia’s cap-and-trade program came into effect. The *Cap-and-Trade*
16 *Program Regulations* included the annual free allowances for GHG emissions for NS Power.

³² *Greenhouse Gas Emissions Regulations* made under subsection 28(6) and Section 112 of the Environment Act S.N.S. 1994-95, c. 1, O.I.C. 2009-341 (August 14, 2009), N.S. Reg. 260/2009 as amended to O.I.C. 2013-332 (September 10, 2013), N.S. Reg. 305/2013.

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 Under the GHG cap-and-trade system, NS Power is allowed to purchase no more than 5 percent
2 of GHG credits offered for auction by the province. Although the free GHG allowance under the
3 GHG cap-and-trade system was specified for each year from 2019 to 2022 as noted in **Figure 16**,
4 the allowances can be redistributed in a four-year compliance period between 2019 and 2022 in
5 order to reduce the cost of compliance. NS Power met the requirements of the program through
6 reduced emissions and the amendment to the Cap-and-Trade Regulations, which provided NS
7 Power with 2,600 additional kilotonnes.

8
9 **Figure 16: Greenhouse Gas Free Allowances 2019-2022**

Year	GHG Free Allowances Million tonnes
2019	6.334
2020	5.517
2021	5.120
2022	5.087

11
12 The Nova Scotia *Air Quality Regulations*³³ specify emission caps for sulphur dioxide (SO₂),
13 nitrogen oxides (NO_x), and mercury (Hg). These regulations were amended to extend from 2020
14 to 2030, effective January 1, 2015. The amended regulations replaced annual limits with multi-
15 year caps for the emissions targets for SO₂ and NO_x.

16
17 The Province introduced amendments to the Air Quality Regulations respecting the SO₂ cap for a
18 three-year period from 2020 to 2022, effective January 21, 2020. The regulations also provide
19 local annual maximums, as well as limits on individual coal units for SO₂. The revised emissions
20 requirements are shown below in **Figure 17**.

³³ *Air Quality Regulations* made under Sections 25 and 112 of the Environment Act S.N.S. 1994-95, c. 1 O.I.C. 2005-87 (February 25, 2005, effective March 1, 2005), N.S. Reg. 28/2005 as amended to O.I.C. 2020-016 (effective January 21, 2020), N.S. Reg. 8/2020.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

Figure 17: Emissions (SO₂, NO_x, Hg)

Multi-Year Caps Period	SO₂ (t)	SO₂ (t) Annual Max	NO_x (t)	NO_x (t) Annual Max	Hg (kg)
2020	60,900		14,955		35
2021-2022	90,000			14,955	35
2023-2024	68,000		56,000		35
2025	28,000		11,500		35
2026-2029	104,000	28,000	44,000	11,500	35
2030	20,000		8,800		30

By 2030 SO₂ emissions from generating electricity will have been reduced by 80 percent from 2005 levels. NO_x emissions will have decreased by 73 percent and mercury emissions will have decreased 71 percent from 2005 levels.

SO₂ reductions are being addressed mainly by reduced thermal generation and changes to fuel blends. NO_x reductions are being addressed through reductions in thermal generation and the previous installation of Low-NO_x Combustion Firing Systems. Mercury reductions are being accomplished through reduced thermal generation, changed fuel blends, and the use of Powder Activated Carbon (PAC) systems. NS Power offered a mercury recovery program from 2015 through to the end of January 2020. The program involved recycling light bulbs or other mercury-containing consumer products, which reduced the amount of mercury going into the environment through landfills. Credits approved by Nova Scotia Environment and Climate Change (ECC) may be used to compensate from the deferred emissions by 2020, and a limited number of credits approved by ECC (30 kg in 2020, 10 kg per year for subsequent years) may be used for compliance from 2020 to 2029.

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 In December 2020, as part of the report titled A Healthy Environment and a Healthy Economy,³⁴
2 the Federal Government proposed a carbon price trajectory of \$65/tonne starting in 2023 and rising
3 \$15 annually to \$170/tonne in 2030 (“Federal Backstop”). Following this report, additional
4 information from both the Federal Government and the Province provided further guidance on the
5 carbon policy requirements related to both the carbon price and how this would be enabled in the
6 provinces. In July 2021, the Federal Government confirmed the Federal Backstop and referenced
7 potential requirements for a provincial system to be found equivalent to the Federal Backstop. In
8 January 2022, the Federal Government confirmed the program options for the Province to enact
9 the carbon policy which include meeting the Federal Backstop carbon pricing for emissions
10 produced, extending the cap-and-trade program or enabling a hybrid model in which a
11 performance target is established, which retains a marginal price signal to incent emissions
12 reductions.

13
14 In October 2022, the Province updated the *Environment Act*,³⁵ moving from a then current cap-
15 and-trade system to a provincial output-based pricing system (Nova Scotia OBPS, referred to as
16 the “NS OBPS”). The NS OBPS sets emissions intensity limits for various types of generating
17 facilities. Facilities covered under the NS OBPS program include solid fuels, liquid and gaseous
18 fuels, and the emissions limit is calculated using an emissions-intensity performance standard for
19 electricity generation by facility. Facilities that emit more than the applicable emission intensity
20 limits must provide compensation for the excess emissions, which are priced according to the
21 federal carbon price.


22
23 The Province received federal approval late in 2022 for the NS OBPS, which establishes a
24 performance standard by facility type for the electricity sector beginning in 2023. The performance
25 standards for the NS OBPS by fuel type are shown in **Figure 18**.

26

³⁴<https://www.canada.ca/en/environment-climate-change/news/2020/12/a-healthy-environment-and-a-healthy-economy.html>

³⁵ Nova Scotia Legislature – Bill No. 208: [c046.pdf \(nslegislature.ca\)](#)

1 **Figure 1814: NS OBPS Emission Intensity Standards**



5 As noted above, the province introduced the EGCCRA on October 27, 2021.³⁶ The EGCCRA
6 includes the 80 percent RES 2030 requirement in addition to the requirement to phase out coal-
7 fired electricity generation in the Province by 2030. It also includes provincial GHG reduction
8 targets of 53 percent below 2005 levels by 2030, Net Zero by 2050 (discussed further in **Section**
9 **5.3**) and a zero-emission vehicle mandate that will require 30 percent of new vehicle sales of all
10 light duty and personal vehicles in the Province by 2030 to be zero-emission vehicles.

11
12 **5.3 Anticipated Policy Changes**

13 In the spring of 2022, the Federal Government (Environment and Climate Change Canada, ECCC)
14 produced a discussion paper on a potential Clean Electricity Standard (CES).³⁷ The focus of the
15 discussion paper was on the Federal Government’s commitment to target net-zero electricity
16 production by 2035, in support of achieving net-zero emissions economy-wide by 2050.

³⁶ *Environmental Goals and Climate Change Reduction Act*, S.N.S. 2021, c. 20, s. 1.

³⁷ [A clean electricity standard in support of a net-zero electricity sector: discussion paper - Canada.ca](https://www.ec.gc.ca/energy/eng/2022/06/20220622-clean-electricity-standard-discussion-paper)

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 Offsets/credits are being considered as an element of the CES framework, which would serve to
2 offset emissions from electricity generation in support of economy wide electrification. In parallel,
3 the OBPS emissions performance standards will be reviewed within the context of meeting the
4 2035 targets and beyond.

5
6 Following the discussion paper and a period of industry engagement, ECCC released a proposed
7 frame³⁸ for a Clean Electricity Regulation under the Canadian Environmental Protection Act
8 (CEPA) in July 2022, which will establish the performance standards and operating parameters for
9 emitting generation in 2035 and beyond. NS Power participated in the consultation phase leading
10 up to the fall of 2022 and ECCC ended the initial phase of consultation in advance of Canada
11 Gazette 1 publication. NS Power anticipates continued stakeholder engagement ahead of Canada
12 Gazette 2 and will continue to be engaged.

13
14 In response to both the existing and anticipated policy changes, NS Power is assessing, refining,
15 and enabling the electricity strategy to continue the path to meet the 2030 targets (80 percent RES,
16 coal phase-out, carbon pricing) and beyond (net-zero electricity 2035) through the transformation
17 of the generation fleet. This is supported by the NS Power Evergreen IRP process which will refine
18 the IRP Action Plan and Roadmap items identified as part of the 2020 IRP.

19
20 NS Power continues to engage with both levels of government to explore opportunities to
21 accelerate the Company's carbon reduction strategy in a way that is affordable for customers,
22 maintains reliability, and supports NS Power's customers and the communities where they live
23 and work. As the governments' announced policy changes become legislative and regulatory
24 requirements, NS Power will reflect these changes in future planning studies.

25

³⁸ [Proposed Frame for the Clean Electricity Regulations - Canada.ca](https://www.canada.ca/en/environment-climate-change/services/proposed-clean-electricity-regulations-2022.html)

1 **6.0 RESOURCE ADEQUACY**

2
3 **6.1 Operating Reserve Criteria**

4
5 Operating Reserves are resources which can be called upon by system operators on short notice to
6 respond to the unplanned loss of generation or imports or unanticipated changes in load. These
7 assets are essential to the reliability of the power system.

8
9 As a member of the Maritimes Area of NPCC, NS Power meets the operating reserve requirements
10 as outlined in *NPCC Regional Reliability Reference Directory #5, Reserve*. These criteria are
11 reviewed and adjusted periodically by NPCC and subject to approval by the NSUARB. The
12 criteria require that:

13
14 Each Balancing Authority shall have ten-minute reserve available that is at least
15 equal to its first contingency loss...and,

16
17 Each Balancing Authority shall have thirty-minute reserve available that is at least
18 equal to one half its second contingency loss.³⁹

19
20 In the *Interconnection Agreement between Nova Scotia Power Incorporated and New Brunswick*
21 *System Operator (NBSO)*⁴⁰ NS Power and New Brunswick Power (NB Power) have agreed to
22 share the reserve requirement for the Maritimes Area on the following basis:

23
24 The Ten-Minute Reserve Responsibility, for contingencies within the Maritimes
25 Area, will be shared between the two Parties based on a 12CP [coincident peak]
26 Load-Ratio Share... Notwithstanding the Load-Ratio Share the maximum that
27 either Party will be responsible for is 100 percent of its greatest, on-line, net single
28 contingency, and, NSPI shall be responsible for 50 MW of Thirty-Minute Reserve.

³⁹ <https://www.npcc.org/program-areas/standards-and-criteria/regional-criteria/directories>

⁴⁰ New Brunswick's Electricity Act (the Act) was proclaimed on October 1, 2013. Among other things, the Act establishes the amalgamation of the New Brunswick System Operator (NBSO) with New Brunswick Power Corporation ("NB Power").

1 The Ten-Minute Reserve Responsibility for NS Power is typically 32 MW⁴¹ of spinning reserve
2 on the system. Additional regulating reserve is maintained to manage the variability of customer
3 load and generation.

4 5 **6.2 Planning Reserve Criteria**

6
7 The Planning Reserve Margin (PRM) is intended to maintain sufficient resources to reliably serve
8 firm customers. Unit forced outages, higher than forecast demand, and lower than forecast wind
9 generation are all conditions that could individually or collectively contribute to a shortfall of
10 dispatchable capacity resources to meet customer demand.

11
12 NS Power is required to comply with the NPCC reliability criteria that have been approved by the
13 NSUARB. These criteria are outlined in *NPCC Regional Reliability Reference Directory #1 –*
14 *Design and Operation of the Bulk Power System* which states:

15
16 Each Planning Coordinator or Resource Planner shall probabilistically evaluate
17 resource adequacy of its Planning Coordinator Area portion of the bulk power
18 system to demonstrate that the loss of load expectation (LOLE) of disconnecting
19 firm load due to resource deficiencies is, on average, no more than 0.1 days per
20 year. [This evaluation shall] make due allowances for demand uncertainty,
21 scheduled outages and deratings, forced outages and deratings, assistance over
22 interconnections with neighboring Planning Coordinator Areas, transmission
23 transfer capabilities, and capacity and/or load relief from available operating
24 procedures.⁴²
25

26 The PRM is a long-term planning assumption that is typically updated as part of an IRP process.
27 NS Power studied the appropriate calculation of its PRM as part of the 2020 IRP⁴³ which
28 confirmed that a 20 percent PRM target was appropriate for long-term planning.

⁴¹ This is a fixed 32MW at all times based on an interim operating agreement with New Brunswick.

⁴² <https://www.npcc.org/program-areas/standards-and-criteria/regional-criteria/directories>

⁴³ M08929, Nova Scotia Power, IRP Final Report, November 27, 2020, page 40.

1 The PRM provides a basis for the minimum required firm generation NS Power must plan to
2 maintain to comply with NPCC reliability criteria; it does not represent the optimal or maximum
3 required capacity to serve other system requirements. The optimal capacity requirement is
4 determined through a long-term planning exercise such as the Evergreen IRP, as discussed in
5 **Section 3.2.1.**

6
7 From February 3-4, 2023, Nova Scotia experienced a severe cold weather event, which tested the
8 limits of the system capacity to meet demand requirements. NS Power served a record hourly peak
9 load of 2455 MW, which is 217 MW over the previous all-time peak (recorded in January of 2004).
10 This peak exceeds the current firm planning peak by approximately 400 MW. With adequate
11 planning for firm peak and PRM requirements, good performance from all available units and
12 anticipatory reduced loads from Large Industrial Interruptible Rider (LIIR) customers, NS Power
13 was able to meet the demand.

14 15 **6.3 Capacity Contribution of Renewable Resources in Nova Scotia**

16
17 Due to their variability, renewable energy resources such as wind and solar are not always available
18 to contribute during peak demand hours. The Effective Load Carrying Capability (ELCC), or
19 “capacity value” of a resource represents the statistical likelihood that it will be available to serve
20 the firm peak demand, and as a result, what percentage of its capacity can be counted on as firm
21 for system planning. Loss of Load Expectation (LOLE) studies are the industry standard used to
22 calculate the ELCC or capacity value of these renewable resources.

23
24 In a letter dated October 5, 2018⁴⁴ the NSUARB directed NS Power to complete certain pre-IRP
25 analyses by July 31, 2019. One of the pre-IRP deliverables directed by the NSUARB was a
26 Capacity Study to calculate the ELCC of wind and other renewable energy generators, both for the
27 existing wind resources as well as potential new resources. The study was undertaken by
28 Energy+Environmental Economics (E3)⁴⁵ on behalf of NS Power and the results determined the

⁴⁴ M08059, UARB Decision Letter, Generation Utilization and Optimization, October 5, 2018.

⁴⁵ M08929, Integrated Resource Planning and Generation Utilization and Optimization (P-884)

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 average ELCC of the wind currently installed on the NS Power system to be 19 percent. The
2 declining marginal ELCC value of adding new wind to the NS Power system was determined to
3 be 11 to 9 percent. In the 2020 IRP, the Company used 10 percent for the ELCC value of new
4 wind. For the purposes of this Report, NS Power has used the 18 percent capacity value of existing
5 wind to account for the wind farm serving wholesale market participants under the Back-up / Top-
6 up (BUTU) Tariff (referred to at lines 13-16 below), 10 percent capacity value of new wind, and
7 95 percent for hydro. Solar has very limited ELCC in Nova Scotia due to poor correlation with the
8 net peak load hours, which primarily occur on winter evenings. Beyond initial penetrations of solar
9 capacity, the marginal capacity value declines to 0 percent.

10
11 Please refer to **Section 3.1** regarding the inclusion of ERIS wind resources.

12
13 Municipal load for Berwick, Mahone Bay, Antigonish, and Riverport is served by a wind farm
14 owned by Alternative Resource Energy Authority (AREA). This generation is not included in NS
15 Power's sourced wind generation but contributes to operational considerations of the total amount
16 of wind generation on the Nova Scotia system.

17 18 **6.4 Load and Resources Review**

19
20 The 10-year load and resources outlook in **Figure 19** is based on the capacity changes and DSM
21 forecast from **Figure 5**, and provides details regarding NS Power's required minimum forecast
22 PRM equal to 20 percent of the firm peak load. Since the CE1-E1-R2 Evergreen IRP scenario is
23 based on the 2022 Load Forecast, the firm capacity additions have been slightly modified to
24 account for additional firm peak requirements reflected in the 2023 Load Forecast.⁴⁶ This
25 requirement is met by an increase in new fast-acting combustion turbine capacity in the latter part
26 of the 10-year horizon (please refer to **Figure 19**).

Energy+Environmental Economics, Planning Reserve Margin and Capacity Value Study, July 2019, Attachment 18
to NS Power's Pre-IRP Final Report at <https://irp.nspower.ca/documents/pre-irp-deliverables/>

⁴⁶ M11108, NS Power 2023 Load Forecast, April 28, 2023

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

1 The current forecast indicates a small PRM deficit from 2023 to 2026. NS Power will continue to
2 monitor potential deficits or apparent surpluses as forecasts continue to evolve and will adjust
3 decisions accordingly.

4
5 **Figure 19** is intended to provide a medium-term outlook of the capacity resources anticipated to
6 be available to the Company compared to expected customer demand.

7
8 **Figure 19: NS Power 10-Year Load and Resources Outlook⁴⁷**

Load and Resources Outlook for NSPI - Winter 2023/2024 to 2032/2033											
(All values in MW except as noted)											
		2023/ 2024	2024/ 2025	2025/ 2026	2026/ 2027	2027/ 2028	2028/ 2029	2029/ 2030	2030/ 2031	2031/ 2032	2032/ 2033
A	Firm Peak including effects of DSM & DR	2,111	2,119	2,148	2,198	2,259	2,325	2,395	2,468	2,545	2,627
B	Required Reserve (A x 20%)	422	424	430	440	452	465	479	494	509	525
C	Required Capacity (A + B)	2,534	2,542	2,578	2,638	2,711	2,790	2,874	2,962	3,054	3,152
D	Existing Resources (NS Power and IPPs)	2,551	2,551	2,551	2,551	2,551	2,551	2,551	2,551	2,551	2,551
E	Existing Resources (Wholesale Market Resources)	4	4	4	4	4	4	4	4	4	4
F	Total Existing Resources (D + E)	2,555	2,555	2,555	2,555	2,555	2,555	2,555	2,555	2,555	2,555
	Firm Resource Additions:										
G	Biomass		43								
H	Hydro	-101	101								
I	Tidal	2									
J	New Wind - Rate Base Procurement		19		18						
K	Other Wind Projects		13								
L	Additions - Wind			20	20	20	20	20	20	20	20
M	Additions - Coal to Gas Conversion						150				
N	Additions - New Fast Acting CTs				50	200	350	50	50	20	150
O	Additions - Battery			25.6	8	33	25		23		
P	Additions - Coal to HFO Operation							459			
Q	Retirements			-148		-150	-472	-459			

⁴⁷ Resource additions must first demonstrate reliable performance before corresponding retirements are fully decommissioned.

**2023 10-Year System Outlook
NON-CONFIDENTIAL**

Load and Resources Outlook for NSPI - Winter 2023/2024 to 2032/2033											
(All values in MW except as noted)											
R	Total Annual Firm Additions (Sum of rows G thru Q)	-99	176	-102	95	103	73	70	93	40	170
S	Total Cumulative Firm Additions (R + S of the previous year)	-99	77	-25	70	173	246	316	409	449	619
T	Total Firm Capacity (F + S)	2,456	2,632	2,530	2,625	2,728	2,801	2,871	2,964	3,004	3,174
	+ Surplus / - Deficit (T - C)	-78	90	-48	-13	17	11	-3	3	-50	22
	Reserve Margin % [(T - A)/A]	16%	24%	18%	19%	21%	20%	20%	20%	18%	21%

1

2


2023 10-Year System Outlook
NON-CONFIDENTIAL

7.0 TRANSMISSION PLANNING

7.1 System Description

The existing transmission system has approximately 5,220 km of transmission lines at voltages at the 69 kV, 138 kV, 230 kV and 345 kV levels. The configuration of the NS Power transmission system and major facilities is shown in **Figure 20**.

Figure 20: NS Power Major Facilities in Service 2023



The 345 kV transmission system is approximately 468 km in length and comprises 372 km of steel tower lines and 96 km of wood pole lines.

The 230 kV transmission system is approximately 1,271 km in length and comprises 47 km of steel/laminated structures and 1,224 km of wood pole lines.

1 The 138 kV transmission system is approximately 1,871 km in length and comprises 303 km of
2 steel structures and 1,568 km of wood pole lines.

3
4 The 69 kV transmission system is approximately 1,560 km in length and comprises 12 km of
5 steel/concrete structures and 1,548 km of wood pole lines.

6
7 Nova Scotia is interconnected with the New Brunswick electric system through one 345 kV and
8 two 138 kV lines providing up to 505 MW of transfer capability to New Brunswick and between
9 0 and 300 MW of transfer capability from New Brunswick, depending on system conditions. As
10 the New Brunswick system is interconnected with the province of Quebec and the state of Maine,
11 Nova Scotia is integrated into the NPCC bulk power system.

12
13 Nova Scotia is also interconnected with Newfoundland via a 500 MW, +/-200 kV DC Maritime
14 Link. The Maritime Link is owned and operated by NSP Maritime Link Inc., a wholly-owned
15 subsidiary of Emera Newfoundland & Labrador.

16 17 **7.2 Transmission Design Criteria**

18
19 Consistent with good utility practice, NS Power utilizes a set of deterministic criteria for its
20 interconnected transmission system that combines protection performance specifications with
21 system dynamics and steady state performance requirements. The approach used has involved the
22 subdivision of the transmission system into various classifications, each of which is governed by
23 the NS Power System Design Criteria. The criteria require the overall adequacy and security of
24 the interconnected power system to be maintained following a fault on and disconnection of any
25 single system component.

1 **7.2.1 Bulk Power System (BPS)**
2

3 The NS Power bulk transmission system is planned, designed and operated in accordance with
4 North American Electric Reliability Corporation (NERC) Standards and NPCC criteria. NS Power
5 is a member of the NPCC; therefore, those portions of NS Power’s bulk transmission network
6 where single contingencies can potentially adversely affect the interconnected NPCC system are
7 designed and operated in accordance with the NPCC *Regional Reliability Directory I: Design and*
8 *Operation of the Bulk Power System*, and are defined as Bulk Power System (BPS).
9

10 **7.2.2 Bulk Electric System (BES)**
11

12 The NERC Bulk Electricity System (BES) definition encompasses any transmission system
13 element at or above 100 kV with prescriptive inclusions and exclusions that further define BES.
14 System Elements that are identified as BES elements are required to comply with all relevant
15 NERC reliability standards.
16

17 NS Power has adopted the NERC definition of the BES and an NS Exception Procedure for
18 elements of the NS transmission system that are operated at 100 kV or higher for which
19 contingency testing has demonstrated no significant adverse impacts outside the local area. The
20 NS Exception Procedure is used in conjunction with the NERC BES definition to determine the
21 accepted NS BES elements and is equivalent to Appendix 5C of the NERC Rules of Procedure.
22

23 The BES Definition and NS Exception Procedure were approved by NSUARB Order dated April
24 6, 2017. Under the BES definition and NS Exception Procedure approved by the NSUARB,
25 elements classified as NS BES elements are required to adhere to all relevant NERC standards that
26 have been approved by the NSUARB for use in Nova Scotia.
27

1 **7.2.3 2022 Bulk Electric System Exception Requests**

2
3 Since the filing of the 2022 10 Year System Outlook Report, no new BES Exception Requests
4 have been received.

5
6 **7.2.4 Special Protection Systems (SPS)**

7
8 Special Protection Systems (SPS) are also referred to as Remedial Action Schemes (RAS) in
9 NERC documentation. Both terms are valid.

10
11 NS Power makes use of SPS in conjunction with the Supervisory Control and Data Acquisition
12 (SCADA) system to enhance the utilization of transmission assets. These systems act to maintain
13 system stability and remove equipment overloads, post-contingency, by rejecting generation
14 and/or shedding load. The NS Power system has several transmission corridors that are regularly
15 operated at limits without incident due to these SPS.

16
17 **7.2.5 NPCC Directory 1 Review**

18
19 A Working Group under the NPCC Task Forces on Coordination of Planning (TFCP) and
20 Coordination of Operation (TFCO) is presently conducting a review of the NPCC Directory 1
21 Document: Design and Operation of the Bulk Power System. Membership was solicited from the
22 NPCC Task Forces on Coordination of Planning, and Coordination of Operation and other
23 interested representatives of NPCC Member Companies.

24
25 At present, Directory 1⁴⁸ provides a “design-based approach” to design and operate the bulk power
26 system to a level of reliability that will not result in the loss or unintentional separation of a major
27 portion of the system from any of the contingencies referenced. NS Power has representation from
28 both Operations and Planning on the Directory 1 Working Group that is performing the review.
29 The Directory 1 Working Group anticipates the review will be complete in Q3 2023.

⁴⁸ <https://www.npcc.org/program-areas/standards-and-criteria/regional-criteria/directories>

1 **7.3 Transmission Life Extension**

2
3 NS Power has a comprehensive maintenance program in place for the transmission system focused
4 on maintaining reliability and extending the useful life of transmission assets. The program is
5 centered on detailed transmission asset inspections and associated prioritization of asset
6 replacement (i.e. conductor line, poles, cross-arms, guywires, and hardware replacement).

7
8 Transmission line inspections consist of the following actions:

- 9
- 10 • Visual inspection of every line once per year via helicopter, or via ground patrol in
11 locations not practical for helicopter patrols.
 - 12 • Foot patrol of each non-BPS line on a three-year cycle. Where a Lidar survey is requested
13 for a non-BPS line, the survey replaces the foot patrol in that year.
 - 14 • For BPS lines, Lidar surveys every two years out of three, with a foot patrol scheduled for
15 the third year.

16
17 These inspections identify asset deficiencies or damage and confirm the height above ground level
18 of the conductor span while recording ambient temperature. This enables the NSPSO to confirm
19 that the rating of each line is appropriate.

20
21 **7.4 Transmission Project Approval**

22
23 The transmission plan presented in this document provides a summary of the planned
24 reinforcement of the NS Power transmission system. The proposed investments are required to
25 maintain system reliability and security and comply with System Design Criteria and other
26 standards. NS Power has sought to upgrade existing transmission lines and utilize existing plant
27 capacity, system configurations, and existing rights-of-way and substation sites where economic.

28
29 Major projects included in the plan have been included based on a preliminary assessment of need.
30 The projects will be subject to further technical studies, internal approval at NS Power, and

1 approval by the NSUARB. Projects listed in this plan may change because of final technical
2 studies, changes in the load forecast, changes in customer requirements or other matters
3 determined by NS Power, NPCC/NERC Reliability Standards, or the NSUARB.

4
5 **7.5 New Large-Load Customer Interconnection Requests**

6
7 NS Power continued to receive large numbers of new large-load requests in 2022 with respect to
8 proposed commercial, mining, aquaculture and government projects. In particular, NS Power is
9 seeing increased interest in large-load requests from prospective Hydrogen production developers.

10
11 Since June 30, 2022, approximately twenty-five (25) Preliminary Assessments were performed in
12 the range of 1-9 MVA, leading to the completion of two (2) formal Load Impact Studies on the
13 distribution system. In some instances, Preliminary Assessments determined that a Load Impact
14 Study was not required. Not all these assessments translate into near-term load, as some projects
15 have multi-year construction or are not completed. In addition, six (6) formal Load Impact Studies
16 on the transmission system were completed, with a range of values between 4-250 MW.

17
18 NS Power has received four (4) additional formal Load Impact Studies on the transmission system,
19 all of which are currently underway and range in size from 6-900 MW.

1 **8.0 TRANSMISSION DEVELOPMENT 2022 TO 2033**

2
3 Investments in transmission infrastructure can be affected by energy policy and the changing
4 sources of energy and capacity. Proposed transmission development plans and projects are subject
5 to reconsideration and alignment with current policy goals. Items described below are current as
6 of the date of this report.

7
8 **8.1 Impact of Proposed Load Facilities**

9
10 As noted in Section 7.5 of this Report, there are several system upgrades required to serve load
11 facilities greater than 1 MW that were proposed in 2020 and 2021. These projects have precipitated
12 the need for the following system upgrades:

- 13
- 14 1. Construction of new 15/20/25 MVA, 138 kV-25 kV substation at 101W-Bowater. This
15 substation is currently under construction with an expected completion date in 2023.
 - 16 2. Construction of a new 25/33/42 MVA, 138 kV-25 kV substation in Stellarton in 2023/24.
17 The design of this substation is currently in progress.
 - 18 3. Installation of a second 25/33/42 MVA, 138 kV-25 kV transformer at 1N-Onslow. Area
19 load continues to be monitored to determine the appropriate timing of this installation.
 - 20 4. Installation of a new 25/33/42 MVA, 138 kV-25 kV substation on Susie Lake Crescent in
21 2024/25. Property acquisition for this site is currently underway.
 - 22 5. Installation of a new 10MVA, 69-25kV portable dead-front transformer on-line L-5510
23 required to provide a 25kV supply to a new mine site in 2024.

24
25 **8.2 129H-Kearney Lake Relocation**

26
27 Detailed inspection of the proposed two land parcels for relocation of 129H revealed that site
28 development costs would be much higher than expected to grade the property and provide a
29 suitable access route into the site for a mobile transformer unit. Subsequent negotiations with the
30 owners of the existing site resulted in a new option to swap the existing Kearney Lake Substation

1 site (plus sufficient property to enable an expansion for a second transformer and new approach
2 structure) with the NS Power-owned land parcels across the street. The owners of the Kearney
3 Lake site have extended the existing lease to complete this option. This option also involves
4 surrendering a small portion of the existing L-6038 ROW, resulting in re-alignment of the 129H
5 transmission approaches so that L-6038 will be in the same corridor as the existing L-5004. Once
6 complete (transfer forecasted for completion in 2023), the existing 129H-Kearney Lake substation
7 site will be suitable for the future addition of a second transformer. The transmission structure re-
8 alignment is scheduled and planned for completion in 2024.

9 10 **8.3 Transmission Development Plans**

11
12 Transmission development plans are summarized below. As noted above, these projects are subject
13 to change. For 2023, most of the projects listed are included in NS Power's 2022 ACE Plan. As a
14 result of the growth in the 2023 load forecast, and as coal phase-out planning continues to advance
15 and replacement resource are identified, additional projects are anticipated to be identified.

16 17 **2023**

- 18
 - 19 • Completion of 5P 25 MVA Mobile Substation Replacement [carry-over from 2022].
 - 20 • Completion of 101W-Port Mersey Expansion to include a new 138 kV-25 kV, 15/20/25
21 MVA transformer and two feeders (C0011261) [carry-over from 2022].
 - 22 • 78W-Martins Brook substation relocation and transformer replacement (C0010956).
 - 23 • Line structure replacements and upgrades [carry-over from 2022].
 - 24 • Resolution of the Aulds Cove 345kV crossing line deration (parallel existing lines vs
25 disconnection and grounding of lower three lines) [carry-over from 2022].
 - 26 • 2021 Transmission Right-of-Way Widening 69 kV to reduce the occurrence of edge and
27 off right-of-way tree contacts (Year 7 of 8).
 - 28 • Receipt of new large spare auto-transformer (C0031050) for substation in Stellarton.
 - 29 • Purchase suitable lot for establishing a new 138kV-25kV Suzie Lake Substation.
 - 30 • Complete land transfer to enable the retention of 129H-Kearney Lake Substation.
-

2023 10-Year System Outlook
NON-CONFIDENTIAL

- 1 • Construct new 25/33/42 MVA 138 kV–25 kV 98N Substation complete with three 25 kV
2 distribution feeders in Stellarton.
- 3 • Purchase new 138 kV–25 kV, 15/20/25 MVA transformer and site at the intersection of
4 138 kV line L-6051 and Highway 1 (near Brushy Hill) for new Lacey Lake substation.
5 Install temporary substation near site until permanent substation is complete in 2024.

6

7 **2024**

- 8
- 9 • Transmission Right-of-Way Widening 69 kV to reduce the occurrence of edge and off
10 right-of-way tree contacts (Year 8 of 8).
- 11 • Re-align transmission structures on approach to the 129H-Kearney Lake Substation.
- 12 • Replacement of 9W-B53 support structure [carry-over from 2022].

13

14 **2025**

- 15
- 16 • Construct new 25/33/42 MVA 138 kV-25 kV Suzie Lake Substation complete with four
17 25 kV distribution feeders.
- 18 • Add a second 15/20/25 MVA 69 kV-12.5 kV transformer at 70W-High Street
19 (Bridgewater). Retire the 69 kV-4.16 kV transformer 70W-T51 and install a 2.5 MVA
20 12.5kV-4.16kV padmount transformer to pick up remaining 4.16 kV load.
- 21 • Build a new 15/20/25 MVA 138kV-25kV substation tapped to line L-6002 in Bridgewater.
- 22 • Replace existing 50/66.7/83.3 MVA 138 kV-69 kV Tufts Cove auto-transformer with a
23 similarly rated unit (deteriorated tap changer issues).
- 24 • Replace existing 3/4/4.48 MVA Lower East Pubnico transformer with 7.5/10/12.5 MVA
25 unit.

26

27 **2026**

- 28
- 29 • Replace transformers 62N-T1 and 62N-T2 at end of expected life with a single 138/69 kV-
30 25 kV, 15/20/25 MVA transformer.
-

2023 10-Year System Outlook
NON-CONFIDENTIAL

- 1 • Add a second 25/33/42 MVA, 138 kV-25 kV transformer at new 98N substation in
2 Stellarton.
- 3 • Replace 83V-Wolfville Ridge transformer 83V-T51 with a 138/69kV-25 kV, 15/20/25
4 MVA transformer.
- 5 • Replace 93V-Saulnierville transformer 93V-T51 with a 138/69 kV-25 kV, 15/20/25 MVA
6 transformer.
- 7 • Add a second 25/33/42 MVA, 138 kV-25 kV transformer at the 4C substation (Lochaber
8 Road) in Antigonish.
- 9 • Installation of a second 25/33/42 MVA, 138 kV-25 kV transformer at 1N-Onslow.

10

11 **2027**

12

- 13 • Installation of a new 138/69 kV-25 kV, 15/20/25 MVA substation in Lower Truro tapped
14 to Line L-5028.

15

16 **2028 – 2033**

17

- 18 • There are currently no completed planning studies with transmission recommendations
19 beyond 2028, but NS Power anticipates that more projects will be identified as coal-fired
20 generation is phased out and electrification advances.

21

22 NS Power has several transmission and distribution planning studies in progress that are evaluating
23 the following items for inclusion in future ACE Plans. The outcome of the studies referenced below
24 may result in additional capital work, which will be reflected in future iterations of the 10-Year
25 System Outlook report:

26

- 27 • Installation of new 138 kV Supply to 50V-Klondike and replace existing 69-25 kV
28 transformer with new 15/20/25 MVA unit.
- 29 • Replace existing 7.5/10/12.5/14 MVA 22W - Barrington Passage transformer with
30 15/20/25 MVA unit and add additional feeder circuit.

- 1 • Installation of a fourth feeder at 126H-Porter’s Lake Substation.
- 2 • Installation of a fourth feeder and replacement of the substation transformer at 127H-
- 3 Aerotech Park Substation.
- 4

5 **8.4 Reliability Tie**

6 NS Power is currently developing a second 345kV intertie, the Reliability Tie, between Onslow,

7 Nova Scotia and Salisbury, New Brunswick. The development of the Reliability Tie is in

8 alignment with the findings of the 2020 IRP and the 2023 Evergreen IRP update enabling increased

9 integration of variable renewable generation. NS Power provides updates on the Reliability Tie in

10 its IRP Action Plan Updates⁴⁹. Progressing the Reliability Tie also facilitates future expanded

11 Regional Interconnections to electricity systems beyond Nova Scotia, including the proposed

12 Atlantic Loop. IRP results indicate that the Reliability Tie is an important contributor to the system

13 independent of the Atlantic Loop project. The earliest potential in-service date for the Reliability

14 Tie is currently estimated to be 2027.

15 **8.5 Western Valley Transmission System – Phase II Study**

16

17 The Western Valley transmission study was initiated to determine the system upgrades needed to

18 address transmission line capacity, clearance, and age issues in the Western Valley over a 15-year

19 transmission planning horizon. In particular, the following 69 kV lines were targeted:

20

- 21 • L-5531 (13V-Gulch to 15V-Sissiboo)
- 22 • L-5532 (13V-Gulch to 3W-Big Falls)
- 23 • L-5535 (15V-Sissiboo to 9W-Tusket)
- 24 • L-5541 (3W-Big Falls to 50W-Milton)
- 25

⁴⁹ Slides 11 – 12 of the NS Power February 2023 IRP Action Plan Update provides NS Power’s most recent update on the Reliability Tie and can be accessed here: [PowerPoint Presentation \(nspower.ca\)](#)

2023 10-Year System Outlook
NON-CONFIDENTIAL

1 The scope of the study included the assessment of the following four options:

2

3 Option #1 - Restore L-5531, L-5532, L-5535, and L-5541 to 50°C Temperature Rating

4 Option #2 - Upgrade L-5531, L-5532, L-5535, and L-5541 to 80°C Temperature Rating

5 Option #3 - Rebuild L-5531, L-5532, L-5535, and L-5541 with 336 ACSR Linnet and 100°C
6 Temperature rating

7 Option #4 - Rebuild L-5531, L-5532, L-5535, and L-5541 with 556 ACSR Dove and 100°C
8 Temperature rating (Operate at 69 kV)

9

10 A fifth and sixth option were subsequently added in 2021 and 2022 respectively to assess
11 bypassing the existing 69 kV infrastructure with either a single 138 kV circuit, or 138 kV double
12 circuit construction.

13

14 Option #5 - Bypass L-5025, L-5026, L-5531, and L-5535 with a new 138 kV line from 51V-
15 Tremont to new substations at 13V-Gulch and 9W-Tusket

16 Option #6 - Bypass L-5025, L-5026, L-5531, and L-5535 with new double circuit 138 kV line
17 from 51V-Tremont to new substations at 13V-Gulch and 9W-Tusket.

18

19 The scope of the study was subsequently expanded in 2022 to also include the impacts of
20 electrification on the Western Valley and Western regions. However, study work was paused due
21 to an influx of Feasibility Studies related to the Rate Base Procurement (RBP) process for the
22 procurement of 1100 GWh (~350MW) of renewable generation within the province. After this and
23 the identification of the RBP final procurement list, NS Power received an influx of System Impact
24 Study requests. Work on the Western study will continue to be on hold pending completion of
25 these studies. The scope of this study will be reviewed based on the outcomes of the studied
26 projects as well as the updated 2023 Load Forecast.

27

1 **9.0 CONCLUSION**

2

3 Customers count on NS Power for energy to power every moment of every day, and for solutions
4 to power a sustainable tomorrow. Environmental legislation and policy initiatives in Canada and
5 Nova Scotia continue to drive transformation of the NS Power electric power system. The
6 Evergreen IRP update (**Section 3.2.1**) is NS Power’s commitment to continuously refining the IRP
7 Action Plan and Roadmap items to reflect changes in the planning environment. Scenario CE1-
8 E1-R2 from the Evergreen IRP modeling work forms the planning basis for the 2023 10-Year
9 System Outlook as it closely reflects the current understanding of the system planning environment
10 at the time of this filing (**Section 5.0**). This updated analysis will be used to inform future 10-Year
11 System Outlook Reports and related long-term planning processes.