

NON-CONFIDENTIAL

1 **Request IR-1:**

2
3 **Reference: Appendix 16 at 30:**

4
5 **“While there may be differences in impact between RtR generation located**
6 **in Cape Breton and in the Halifax area, those impacts do not change if the**
7 **generation is connected to transmission or distribution systems in each**
8 **location.” And “There are arguments that generation delivered to load**
9 **within the same distribution zone should not have to bear the burden of**
10 **transmission system losses. However, network service transmission relies on**
11 **the use of average loss factors.”**
12

13 **(a) Please provide NS Power’s estimates of marginal transmission line losses by zone of**
14 **generator.**

15
16 **(b) Does the statement that “network service transmission relies on the use of average**
17 **loss factors” mean that NS Power believes that averaging losses across the province**
18 **is required?**

19
20 **(i) If so, please explain what requires such spatial averaging, whether law,**
21 **regulation, physics or data availability.**

22
23 **(ii) If not, please confirm that this statement is simply a reflection of NS Power’s**
24 **past practice.**

25
26 **(c) Please provide NS Power’s estimates of losses on its primary distribution system.**

27
28 **(i) If those estimates are disaggregated by type of primary service, time period,**
29 **or other parameters, please provide the disaggregated values.**

30
31 **(d) Please describe the status of NSPI’s line-loss study required by the COSS settlement**
32 **and order, and provide any workproducts produced to date.**

NON-CONFIDENTIAL

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

Response IR-1:

- (a) Please refer to **Attachment 1** for Transmission Bus Loss Factor and Short Circuit Level Data. Attachment 1 provides the incremental locational loss factor data associated with each NS Power transmission substation.
- (b) Yes.
 - (i) Section 28.5 of the existing Open Access Transmission Tariff addresses real power losses associated with the Network Integration Transmission Tariff. It requires that the Network Customer be responsible for replacing losses associated with all transmission service as calculated by the Transmission Provider in accordance with Schedule 9 of the Tariff. Schedule 9 specifies that for Network Service, the Transmission provider will apply the system average loss factor, which will be calculated annually.
 - (ii) Not applicable.
- (c) Please refer to the Cost of Service model, **Application Appendix 11A, Exhibit 9B** for a summary of the primary distribution losses by rate class.
- (d) NS Power is finalizing an action plan for the Class Load Data Collection and Analysis Project, which will include purchase and deployment of new meters to implement a refreshed sample design. The Capital Work Order for this project will be submitted in the 2016 Annual Capital Expenditure Plan in November, 2015. The Line Loss Determination Model requires a year of new class load data before it can be completed, so its expected completion is in 2017.

2014 Transmission Bus
Loss Factor and Short Circuit Level Data

Station ID	NAME	kV	LOCATION	Incremental Locational Loss Factors										Short Circuit Level			
				110 MW	100 MW	90 MW	80 MW	70 MW	60 MW	50 MW	40 MW	30 MW	20 MW	10 MW	Maximum (MVA)	X/R Ratio	Minimum (MVA)
101S WOODBINE	230 Morley Road, Sydney	11.5%	11.3%	11.1%	11.0%	10.9%	10.7%	10.6%	10.4%	10.3%	10.1%	10.0%	2691	16.5	1626	22.7	
120H BRUSHY HILL	230 East Uniacke, Grove Road	0.9%	0.9%	0.8%	0.7%	0.7%	0.6%	0.6%	0.5%	0.4%	0.4%	0.3%	3356	12.3	1540	15.4	
199S PT.ACONI	230 Point Aconi	13.4%	13.1%	12.9%	12.8%	12.6%	12.4%	12.2%	12.0%	11.8%	11.6%	11.5%	1661	15.8	1289	21.9	
3C HASTINGS	230 Port Hastings	9.8%	9.7%	9.6%	9.5%	9.3%	9.2%	9.1%	8.9%	8.8%	8.7%	8.6%	3090	11.2	1726	17.1	
67N ONSLOW	230 Onslow	3.4%	3.3%	3.3%	3.2%	3.1%	3.0%	3.0%	2.9%	2.8%	2.7%	2.7%	4104	13.7	1841	18.8	
88S LINGAN	230 Lingan	13.3%	13.1%	12.9%	12.8%	12.6%	12.5%	12.3%	12.2%	12.0%	11.9%	11.8%	3896	22.5	1716	20.8	
91N DALHOUSIE MTN	230 Dalhousie Mountain, Pictou	5.3%	5.2%	5.1%	5.0%	4.9%	4.8%	4.6%	4.5%	4.4%	4.2%	4.2%	2285	8.2	1384	11.7	
99W BWATER_A 230	230 Bridgewater	0.0%	-0.1%	-0.2%	-0.4%	-0.5%	-0.6%	-0.7%	-0.9%	-1.0%	-1.1%	-1.3%	1517	12.9	926	14.0	
99W BWATER_B 230	230 Bridgewater	0.0%	-0.2%	-0.3%	-0.4%	-0.6%	-0.7%	-0.8%	-1.0%	-1.1%	-1.2%	-1.4%	1261	10.3	808	11.4	
100C PORCUPINE	138 Cape Porcupine	10.0%	9.9%	9.7%	9.6%	9.4%	9.3%	9.1%	9.0%	8.8%	8.7%	8.5%	2336	9.9	1483	13.9	
101H COBEQUID	138 Sackville	-0.3%	-0.4%	-0.4%	-0.5%	-0.5%	-0.6%	-0.6%	-0.7%	-0.7%	-0.8%	-0.8%	3111	10.6	1322	12.8	
101W BMPC-TMP	138 Brooklyn	0.0%	-0.2%	-0.4%	-0.6%	-0.9%	-1.1%	-1.3%	-1.5%	-1.7%	-1.9%	-2.1%	1045	9.9	598	10.2	
103H LAKESIDE	138 Beechville (Lakeside)	0.5%	0.4%	0.4%	0.3%	0.3%	0.2%	0.2%	0.1%	0.0%	0.0%	-0.1%	2758	12.6	1322	15.8	
103W GOLD RIVER	138 Beech Hill Rd., Chester	1.2%	0.9%	0.5%	0.2%	-0.2%	-0.5%	-0.9%	-1.2%	-1.6%	-2.0%	-2.4%	591	4.7	471	5.5	
104H KEMPT RD	138 3176 Kempt Road, Halifax	-0.5%	-0.6%	-0.6%	-0.6%	-0.7%	-0.7%	-0.7%	-0.8%	-0.8%	-0.8%	-0.9%	2834	13.0	1229	13.1	
104S BADDECK	138 Baddeck	15.4%	15.1%	14.7%	14.4%	14.1%	13.8%	13.4%	13.1%	12.8%	12.5%	12.2%	1058	6.9	597	6.7	
104W BROOKLYN	138 Brooklyn	0.0%	-0.2%	-0.4%	-0.6%	-0.8%	-1.1%	-1.3%	-1.5%	-1.7%	-1.8%	-2.1%	1034	9.8	592	10.0	
108H BURNSIDE	138 Burnside, Dartmouth	-0.2%	-0.3%	-0.3%	-0.3%	-0.4%	-0.4%	-0.5%	-0.5%	-0.5%	-0.6%	-0.6%	3366	13.1	1296	12.2	
113H EAST DARTMOUTH	138 Cherry Brook	-1.0%	-1.0%	-1.1%	-1.1%	-1.2%	-1.3%	-1.3%	-1.4%	-1.4%	-1.5%	-1.6%	2060	8.7	1038	10.2	
120H BRUSHY HILL	138 East Uniacke, Grove Road	0.8%	0.7%	0.7%	0.6%	0.5%	0.5%	0.4%	0.4%	0.3%	0.2%	0.2%	3307	12.9	1465	16.5	
126H PORTERS LAKE	138 Porters Lake	-0.6%	-0.7%	-0.9%	-1.0%	-1.2%	-1.3%	-1.4%	-1.6%	-1.7%	-1.8%	-2.0%	1167	6.3	750	7.6	
127H AEROTECH	138 Aerotech Ind. Park, Hwy 102	0.2%	0.1%	0.0%	-0.1%	-0.2%	-0.4%	-0.5%	-0.6%	-0.7%	-0.8%	-0.9%	1511	6.4	945	7.9	
129H KEARNEY	138 102	0.6%	0.5%	0.4%	0.3%	0.2%	0.2%	0.1%	0.0%	-0.1%	-0.2%	-0.3%	2005	10.2	1120	13.2	
131H LUCASVILLE	138 Lucasville Road	0.0%	-0.1%	-0.1%	-0.2%	-0.2%	-0.3%	-0.3%	-0.4%	-0.5%	-0.5%	-0.6%	3042	11.4	1351	14.2	
137H HAMMOND PLAINS	138 Hammond Plains Rd, Bedford	0.6%	0.6%	0.5%	0.4%	0.3%	0.3%	0.2%	0.1%	0.1%	0.0%	-0.1%	2269	11.9	1209	14.9	
139H DARTMOUTH CROSS	138 Burnside, Dartmouth	-0.8%	-0.8%	-0.9%	-0.9%	-1.0%	-1.0%	-1.1%	-1.1%	-1.2%	-1.2%	-1.3%	2634	10.0	1166	11.1	
17V ST CROIX	138 St. Croix	-0.2%	-0.3%	-0.4%	-0.5%	-0.6%	-0.8%	-0.9%	-1.0%	-1.1%	-1.2%	-1.4%	1756	8.1	1036	10.6	
1C TUPPER	138 Point Tupper	11.5%	11.3%	11.1%	11.0%	10.8%	10.6%	10.5%	10.3%	10.1%	10.0%	9.8%	2290	11.3	1480	15.7	
1H WATER ST	138 Lower Water Street, Halifax	-0.3%	-0.3%	-0.4%	-0.4%	-0.5%	-0.6%	-0.6%	-0.6%	-0.7%	-0.8%	-0.8%	2307	10.8	1165	13.0	
1N ONSLOW	138 Onslow	3.4%	3.3%	3.2%	3.1%	3.0%	2.9%	2.8%	2.7%	2.7%	2.6%	2.5%	2259	11.8	1491	13.4	
22C CLEVELAND	138 Cleveland	10.7%	10.5%	10.3%	10.1%	9.9%	9.8%	9.6%	9.4%	9.2%	9.0%	8.8%	1653	7.1	1161	9.5	
22N CHURCHST	138 Church Street, Amherst	5.9%	5.4%	4.9%	4.4%	3.8%	3.3%	2.8%	2.3%	1.8%	1.2%	0.6%	1015	5.2	936	5.8	
2C HASTINGS	138 Port Hastings	10.1%	9.9%	9.8%	9.7%	9.5%	9.4%	9.2%	9.1%	9.0%	8.8%	8.7%	2755	12.5	1632	17.7	
2H ARMDALE	138 Armdale	0.1%	0.0%	-0.1%	-0.1%	-0.2%	-0.3%	-0.3%	-0.4%	-0.4%	-0.5%	-0.6%	2410	11.2	1215	14.0	
2S VICTORIA	138 Victoria Junction	12.9%	12.7%	12.5%	12.4%	12.2%	12.0%	11.8%	11.7%	11.5%	11.3%	11.1%	2152	12.9	1180	14.1	
30N MACCAN	138 Maccan	6.0%	5.5%	5.0%	4.5%	4.0%	3.4%	2.9%	2.5%	1.9%	1.4%	0.8%	1068	5.4	982	6.1	
30W SOURIQUOIS	138 Shelburne (East of)	-0.5%	-1.0%	-1.5%	-2.1%	-2.7%	-3.2%	-3.8%	-4.4%	-5.0%	-5.6%	-6.3%	567	4.4	376	5.1	
3S GANNON	138 North Sydney	14.4%	14.1%	13.8%	13.5%	13.2%	13.0%	12.7%	12.4%	12.1%	11.8%	11.6%	1159	6.7	711	7.4	
99V 99V-HIGHBURY	138 Kentville	-2.2%	-2.5%	-2.7%	-2.9%	-3.2%	-3.4%	-3.7%	-3.9%	-4.1%	-4.3%	-4.7%	1046	5.9	708	6.8	
43V CANAAN RD	138 White Rock	-2.4%	-2.6%	-2.8%	-3.0%	-3.3%	-3.5%	-3.7%	-3.9%	-4.1%	-4.3%	-4.6%	1168	6.0	759	7.0	
47C NEWPAGE	138 Point Tupper	11.4%	11.2%	11.0%	10.9%	10.7%	10.5%	10.4%	10.2%	10.0%	9.9%	9.7%	2271	11.0	1450	14.6	
49N MICH-GRAN	138 Granton	6.5%	6.4%	6.3%	6.1%	6.0%	5.9%	5.8%	5.6%	5.5%	5.4%	5.3%	2188	14.7	1471	17.6	
4C LOCHABER	138 Antigonish	8.7%	8.5%	8.2%	8.0%	7.8%	7.5%	7.3%	7.0%	6.8%	6.5%	6.3%	1135	5.7	911	6.9	

Note: This table does not imply that the indicated size of generator can be interconnected at the bus listed.
All interconnections are subject to System Impact Studies.

2014 Transmission Bus
Loss Factor and Short Circuit Level Data

Station ID	NAME	kV	LOCATION	Incremental Locational Loss Factors											Short Circuit Level			
				110 MW	100 MW	90 MW	80 MW	70 MW	60 MW	50 MW	40 MW	30 MW	20 MW	10 MW	Maximum (MVA)	X/R Ratio	Minimum (MVA)	X/R Ratio
50N TRENTON	138 Trenton	6.8%	6.6%	6.5%	6.4%	6.3%	6.1%	6.0%	5.9%	5.8%	5.6%	5.5%	2853	18.9	1732	22.1		
50W MILTON	138 Milton	-0.3%	-0.5%	-0.7%	-0.9%	-1.1%	-1.2%	-1.4%	-1.6%	-1.8%	-2.0%	-2.2%	1155	10.2	639	10.5		
51V TREMONT B61_	138 Tremont - East Tremont	-2.2%	-2.6%	-2.9%	-3.2%	-3.5%	-3.9%	-4.2%	-4.5%	-4.9%	-5.2%	-5.6%	809	5.5	572	5.9		
59C ST PETERS	138 St. Peters	12.0%	11.7%	11.5%	11.2%	11.0%	10.7%	10.4%	10.2%	9.9%	9.6%	9.4%	1050	5.8	814	7.2		
5S GLEN TOSH	138 Glen Tosh	16.2%	15.8%	15.5%	15.2%	14.9%	14.6%	14.2%	13.9%	13.6%	13.3%	13.0%	1309	7.9	615	6.7		
67C WHYC TAP	138 Whycocomagh	13.8%	13.5%	13.2%	12.9%	12.6%	12.3%	12.0%	11.7%	11.4%	11.1%	10.8%	1019	6.2	669	6.8		
67C WHYCOCO	138 Whycocomagh	14.2%	13.8%	13.5%	13.1%	12.7%	12.4%	12.0%	11.6%	11.3%	10.9%	10.6%	766	5.7	550	6.3		
74N SPRNGHILL	138 East of Springhill Town	4.8%	4.4%	4.1%	3.6%	3.2%	2.8%	2.4%	2.0%	1.5%	1.1%	0.6%	1187	5.3	1083	6.0		
74W MICHBWTP	138 Oakhill	-0.2%	-0.4%	-0.5%	-0.6%	-0.8%	-0.9%	-1.0%	-1.1%	-1.2%	-1.4%	-1.6%	1374	12.0	792	13.5		
74W MICH B-W	138 Oakhill	-0.2%	-0.3%	-0.4%	-0.5%	-0.7%	-0.9%	-1.0%	-1.1%	-1.2%	-1.4%	-1.6%	1303	11.0	768	12.7		
75W WESTHAVER	138 Blockhouse - Maitland	0.1%	0.0%	-0.2%	-0.4%	-0.6%	-0.8%	-1.0%	-1.2%	-1.3%	-1.5%	-1.8%	1018	8.2	659	9.9		
79N HOPEWELL	138 Hopewell	5.8%	5.7%	5.6%	5.5%	5.4%	5.3%	5.2%	5.1%	5.0%	4.9%	4.8%	2465	17.6	1557	21.1		
81N DEBERT	138 Debert	3.4%	3.2%	3.1%	2.9%	2.7%	2.6%	2.4%	2.3%	2.1%	2.0%	1.8%	1535	7.0	1204	8.3		
82V ELMSDALE	138 Elmsdale	0.7%	0.6%	0.5%	0.3%	0.2%	0.0%	-0.1%	-0.3%	-0.4%	-0.6%	-0.7%	1272	5.9	880	7.2		
85S WRECK COVE	138 Wreck Cove, Victoria Co.	19.5%	19.0%	18.6%	18.2%	17.8%	17.3%	16.9%	16.5%	16.1%	15.7%	15.3%	1353	14.2	457	6.0		
87H MUSQ.HBR	138 Musquodoboit Harbour	0.0%	-0.2%	-0.4%	-0.6%	-0.8%	-1.0%	-1.2%	-1.4%	-1.7%	-1.9%	-2.1%	825	5.7	592	6.7		
87W HUBBARDS	138 Hubbards, Mill Lake Road	0.3%	0.1%	-0.1%	-0.4%	-0.6%	-0.9%	-1.1%	-1.4%	-1.6%	-1.9%	-2.1%	870	5.1	632	6.3		
88S LINGAN A	138 Lingan	13.5%	13.3%	13.1%	13.0%	12.8%	12.6%	12.5%	12.3%	12.1%	12.0%	11.8%	2024	17.4	1184	18.7		
88S LINGAN B	138 Lingan	13.4%	13.2%	13.0%	12.9%	12.7%	12.5%	12.4%	12.2%	12.0%	11.9%	11.7%	2031	19.3	1187	19.6		
90H SACVILLE	138 Bedford, Lower Sackville	-0.2%	-0.3%	-0.3%	-0.4%	-0.4%	-0.4%	-0.5%	-0.5%	-0.6%	-0.6%	-0.7%	3473	12.8	1414	15.0		
91H TUFTCOVE	138 Tufts Cove, Dartmouth	-0.3%	-0.3%	-0.3%	-0.3%	-0.4%	-0.4%	-0.4%	-0.4%	-0.4%	-0.4%	-0.5%	3670	18.4	1333	14.0		
92H ST.MARG.	138 Head of St. Margaret's Bay	0.0%	-0.1%	-0.3%	-0.5%	-0.6%	-0.8%	-0.9%	-1.1%	-1.2%	-1.4%	-1.6%	1190	5.6	786	7.1		
92N AMHERST WIND	138 Southampton Rd. Amherst	6.9%	6.3%	5.7%	5.2%	4.6%	4.0%	3.5%	2.9%	2.4%	1.8%	1.2%	233	5.2	128	3.7		
93N GLEN DHU	138 Glen Dhu, Pictou	8.6%	8.4%	8.1%	7.9%	7.7%	7.5%	7.2%	7.0%	6.8%	6.5%	6.3%	1205	5.8	959	7.1		
99W BRIDGEWATER	138 Bridgewater	-0.2%	-0.4%	-0.5%	-0.6%	-0.8%	-0.9%	-1.0%	-1.1%	-1.2%	-1.4%	-1.6%	1376	12.2	793	13.7		
9W TUSKET_A	138 Tusket Falls	-1.7%	-2.3%	-2.8%	-3.4%	-4.0%	-4.6%	-5.1%	-5.8%	-6.4%	-7.0%	-7.7%	451	5.3	294	5.1		
9W TUSKET_B	138 Tusket Falls	N/A	N/A	N/A	-3.7%	-4.5%	-5.3%	-6.1%	-6.9%	-7.7%	-8.5%	-9.4%	460	8.4	300	7.3		
103C CHETICAMP	69 Cheticamp	20.8%	17.3%	14.2%	11.4%	8.4%	80	3.6	77	3.7		
103H LAKESIDE	69 Lakeside industrial park	-0.4%	-0.6%	-0.8%	-0.9%	-1.2%	299	31.0	259	30.2		
106W Pubnico Pt	69 Pubnico Point	N/A	N/A	N/A	N/A	-13.4%	232	5.2	128	3.7		
109S LINGAN WIND	69 Lingan	12.6%	12.2%	11.7%	11.3%	10.8%	525	4.6	415	5.3		
10N ABER ST	69 Springhill	2.8%	2.2%	1.6%	1.0%	0.3%	365	9.5	355	10.0		
10V NICTAUX	69 Nictaux Falls	-3.5%	-4.1%	-4.8%	-5.4%	-6.2%	470	5.6	327	5.1		
10W TUSKET GT	69 Tusket	-5.7%	-6.6%	-7.5%	-8.5%	-9.6%	486	5.2	259	4.9		
11N CEMENT	69 Pleasant Valley	5.3%	4.5%	3.8%	3.0%	2.2%	298	4.8	279	5.0		
11S KELTIC DR	69 Keltic Drive, Coxheath	10.4%	9.9%	9.3%	8.8%	8.2%	406	5.7	337	6.2		
11V PARADISE	69 Paradise	-1.9%	-2.9%	-4.0%	-5.0%	-6.1%	377	5.1	241	4.2		
11W KING ST	69 King Street, Yarmouth	-4.5%	-6.3%	-8.1%	-10.1%	-12.4%	276	2.2	191	2.8		
124H AKERLEY	69 Akerley Boulevard, Burnside	-0.1%	-0.2%	-0.3%	-0.4%	-0.5%	1371	8.9	872	10.6		
12V LEQUILLE	69 LeQuille (SE Annapolis)	0.2%	-1.2%	-2.7%	-4.3%	-5.8%	398	4.8	201	3.4		
13V GULCH	69 Bear River	2.2%	0.3%	-1.6%	-3.5%	-5.5%	471	3.3	194	2.7		
14V RIDGE	69 5 km SSE Bear River	3.3%	1.4%	-0.5%	-2.8%	-4.7%	356	2.2	178	2.4		
15N WILLOW LANE	69 Willow Lane, Truro	1.7%	1.4%	1.1%	0.7%	0.4%	498	10.6	447	11.0		

Note: This table does not imply that the indicated size of generator can be interconnected at the bus listed.
All interconnections are subject to System Impact Studies.

2014 Transmission Bus
Loss Factor and Short Circuit Level Data

Station ID	NAME	KV	LOCATION	Incremental Locational Loss Factors											Short Circuit Level			
				110 MW	100 MW	90 MW	80 MW	70 MW	60 MW	50 MW	40 MW	30 MW	20 MW	10 MW	Maximum (MVA)	X/R Ratio	Minimum (MVA)	X/R Ratio
15S WATERFORD	69 #16 Substation, New Waterford	12.8%	12.3%	11.8%	11.2%	10.7%	416	3.4	345	3.9
15V SISSIBOO	69 Sissiboo Falls	5.1%	3.0%	0.8%	-2.5%	-5.7%	322	2.2	166	2.1
16N STEWIAKE	69 Stewiacke	6.5%	5.5%	4.4%	3.3%	2.2%	228	4.0	217	4.2
16V WEYMOUTH	69 Weymouth Mills	6.9%	4.3%	2.7%	-1.3%	-5.6%	265	2.1	144	1.9
16W HEBRON	69 Hebron	-6.1%	-7.4%	-8.6%	-9.9%	-11.4%	352	3.2	223	3.8
17N BROWNELL	69 Brownell Ave., Amherst	5.9%	4.6%	3.4%	2.0%	0.7%	281	6.3	275	6.5
17V ST CROIX	69 St. Croix	-0.7%	-0.8%	-1.0%	-1.2%	-1.4%	809	11.9	607	13.3
18V BURLINGTON	69 Upper Burlington	3.5%	2.4%	1.2%	0.0%	-1.3%	363	1.6	321	1.9
199H TRAFALGAR	69 Trafalgar	8.0%	6.5%	4.9%	3.2%	1.5%	227	3.6	199	3.5
199W EAST BRIDGEWATER	69 Oakhill (east of Bridgewater)	-0.4%	-1.1%	-1.8%	-2.4%	-3.3%	441	7.9	357	8.8
19C CANSO	69 Canso	28.7%	23.0%	17.7%	12.2%	5.8%	57	2.1	54	2.1
19W ARGYLE	69 Glenwood - Central Argyle, Yar.	N/A	N/A	N/A	-9.9%	-11.6%	329	4.7	192	4.4
1N ONSLOWA	69 Onslow	3.0%	2.9%	2.8%	2.6%	2.5%	626	42.9	548	36.5
1N ONSLOW6B	69 Onslow	2.5%	2.3%	2.2%	2.0%	1.9%	624	43.0	546	36.6
1S SEABOARD	69 Glace Bay	11.1%	10.6%	10.1%	9.6%	9.1%	619	3.8	473	4.6
1V AVON	69 Smith's Corner	3.0%	1.8%	0.7%	-0.5%	-1.7%	319	2.4	281	2.6
20H SPRYFIELD	69 Halifax	-1.6%	-2.1%	-2.6%	-3.1%	-3.7%	239	11.5	212	12.2
20N PARKST	69 Park Street, Amherst	4.8%	3.8%	2.7%	1.7%	0.6%	296	8.0	288	8.3
20V FIVE PT	69 Hantsport	-2.0%	-2.5%	-3.0%	-3.4%	-4.0%	528	4.1	425	4.8
20W PUBNICO	69 Lower East Pubnico	N/A	N/A	N/A	N/A	-13.4%	235	5.1	130	3.7
21W WOODS HBR	69 Lower Woods Harbour	N/A	N/A	N/A	N/A	-14.8%	185	4.4	112	3.6
22V NEW MINAS	69 New Minas	-4.4%	-4.9%	-5.4%	-5.9%	-6.4%	551	4.1	429	4.7
22W BARRINGTON	69 Barrington Passage	N/A	N/A	N/A	N/A	-16.2%	153	3.6	99	3.2
23H ROCKINGHAM	69 Meadowlark Cres., Bridgeview	-0.5%	-0.8%	-1.2%	-1.5%	-1.8%	551	5.8	450	6.6
23W CLYDE RIVER	69 Clyde River	1.4%	-0.5%	-2.6%	-4.7%	-7.1%	158	2.9	138	3.2
24C DICKIE BROOK	69 West Cook's Cove	17.5%	14.2%	11.0%	7.4%	3.6%	88	3.7	81	3.6
25W SHELBURNE	69 Ohio Road at Shelburne	-2.7%	-3.8%	-4.9%	-6.0%	-7.1%	254	4.4	206	4.9
2S V.J.	69 Victoria Junction	11.6%	11.4%	11.3%	11.1%	10.9%	1284	13.9	778	12.8
30N MACCAN	69 Maccan	3.1%	2.5%	1.9%	1.3%	0.7%	365	16.1	354	17.1
30W SOURIQUOIS	69 Shelburne (East of)	-3.2%	-4.0%	-4.9%	-5.9%	-6.8%	280	5.0	222	5.6
34H GEIZERS	69 Highway 102 at Dunbrack St	-0.8%	-1.1%	-1.4%	-1.6%	-1.9%	267	20.3	234	20.8
36V HILLATON	69 Hillaton	-2.5%	-3.5%	-4.6%	-5.7%	-6.9%	359	3.0	303	3.3
36W EAST GREEN HBR	69 Green Harbour - Lydgate	-0.6%	-1.8%	-3.0%	-4.2%	-5.7%	252	3.0	204	3.6
37N PARSBORO	69 Parrsboro	5.5%	4.2%	3.0%	1.7%	0.4%	165	6.9	162	7.0
37W LOCKPORT	69 Lockeport	0.7%	-0.7%	-2.2%	-3.7%	-5.5%	217	2.8	180	3.2
3N OXFORD	69 Oxford Junction	3.1%	2.4%	1.6%	0.9%	0.0%	265	8.7	260	9.0
3S GANNON RD	69 North Sydney	12.6%	12.2%	11.9%	11.4%	11.2%	385	11.4	319	10.8
3V BLACK RIVER	69 White Rock	-3.8%	-4.1%	-4.4%	-4.8%	-5.1%	482	9.7	380	9.6
3W BIG FALL	69 Mersey River	6.2%	5.3%	4.1%	3.1%	2.2%	427	3.9	249	3.8
40H WOODLAWN	69 Mt. Edward Dr. Dartmouth	-0.4%	-0.5%	-0.7%	-0.8%	-1.0%	923	7.9	663	9.0
43V CANAAN RD	69 White Rock	-4.1%	-4.4%	-4.7%	-5.0%	-5.3%	775	7.3	552	7.8
46W BROAD RIVER	69 Broad River	1.4%	0.5%	-0.4%	-1.4%	-2.4%	348	2.9	254	3.8
48H PENHORN	69 Portland St., Dartmouth	-0.5%	-0.6%	-0.7%	-0.8%	-1.0%	1167	8.1	779	9.5

Note: This table does not imply that the indicated size of generator can be interconnected at the bus listed.
All interconnections are subject to System Impact Studies.

2014 Transmission Bus
Loss Factor and Short Circuit Level Data

Station ID	NAME	kV	LOCATION	Incremental Locational Loss Factors											Short Circuit Level			
				110 MW	100 MW	90 MW	80 MW	70 MW	60 MW	50 MW	40 MW	30 MW	20 MW	10 MW	Maximum (MVA)	X/R Ratio	Minimum (MVA)	X/R Ratio
48W LIVERPOOL	69 Liverpool	1.5%	0.8%	0.2%	-0.5%	-1.2%	396	5.1	272	6.2
4C LOCHABER	69 Antigonish	7.6%	7.2%	6.9%	6.4%	6.2%	152	44.1	142	46.1
4N TATAMAGOUCHE	69 Tatamagouche	9.4%	7.9%	6.4%	4.8%	3.3%	171	3.7	165	3.8
4S TOWNSEND	69 Townsend Street, Sydney	11.4%	11.1%	10.8%	10.5%	10.2%	893	4.6	616	5.7
4W LOWER GR.BK	69 Mersey River	3.2%	2.5%	1.9%	1.2%	0.6%	502	5.1	299	5.5
50N TRENTON	69 Trenton	-0.8%	-2.5%	-5.3%	-10.8%	-26.9%	1121	46.2	849	44.7
50V KLONDIKE	69 Kentville	-3.5%	-4.7%	-6.0%	-7.3%	-8.8%	330	2.6	283	2.9
50W MILTON	69 Milton	0.6%	0.2%	-0.2%	-0.6%	-0.9%	600	9.6	353	10.4
51V TREMONT	69 Tremont - East Tremont	-4.2%	-4.7%	-5.1%	-5.5%	-6.0%	615	6.2	440	6.3
52V BERWICK	69 Berwick	-4.0%	-4.8%	-5.7%	-6.7%	-7.6%	390	3.3	319	3.7
53N NORTHERN PULP	69 Abercrombie	5.7%	5.3%	4.8%	4.3%	3.9%	652	6.0	513	5.9
54H MAPLE ST	69 Maple Street, Dartmouth	-0.3%	-0.4%	-0.5%	-0.6%	-0.7%	1457	10.5	899	11.8
54N ABERCROMIE	69 Abercrombie	5.4%	5.0%	4.7%	4.3%	4.0%	723	7.4	567	7.5
55N PICTOU	69 Pictou	6.1%	5.4%	4.8%	4.0%	3.4%	445	3.4	381	3.7
55V WATERVILLE	69 Waterville	-4.9%	-5.6%	-6.4%	-7.2%	-8.1%	412	3.7	336	4.1
56N HALIBURTON	69 Haliburton	5.6%	5.0%	4.5%	3.9%	3.4%	531	4.1	443	4.4
57C SALMON R	69 Salmon River Lake	12.6%	10.3%	8.2%	5.9%	3.5%	99	4.8	92	4.7
57S ALBERT B	69 Hwy. 22 at Horn's Road	15.0%	13.4%	11.7%	9.9%	8.0%	241	1.7	217	2.0
57W CALEDONIA	69 Caledonia	7.4%	5.3%	3.2%	0.9%	-1.5%	234	1.7	165	2.1
58C SW MARGAREE	69 Southwest Margaree	15.0%	13.3%	11.6%	9.8%	8.1%	122	4.3	115	4.4
58H IMPERIAL	69 Imperoyal, Dartmouth	-0.6%	-0.7%	-0.9%	-1.0%	-1.2%	983	7.3	693	8.6
5V LUMSDEN	69 Newtonville (SSE White Rock)	-3.2%	-3.6%	-4.0%	-4.3%	-4.8%	632	5.0	469	5.5
62H ALBRO	69 Albro Lake Road, Dartmouth	0.1%	0.0%	-0.1%	-0.1%	-0.2%	1541	10.7	930	12.0
62N BRIDGE AV	69 Bridge Ave., Stellarton	4.5%	3.9%	3.4%	2.7%	2.2%	468	5.2	413	5.8
62N STELLARTON	69 Bridge Ave., Stellarton	6.2%	5.7%	5.1%	4.5%	4.0%	606	4.0	512	4.5
63V KINGSTON	69 Kingston	-4.0%	-4.7%	-5.3%	-5.9%	-6.7%	468	4.2	359	4.5
64V GREENWOOD	69 Greenwood Village	-4.2%	-4.7%	-5.3%	-5.9%	-6.5%	531	4.6	395	4.9
65V MIDDLETON	69 Middleton (1 km SE)	-3.2%	-3.9%	-4.7%	-5.6%	-6.5%	398	4.7	289	4.6
67C WHYCOGO	69 Whycocomagh	12.3%	11.8%	11.3%	10.8%	10.3%	232	8.2	207	8.2
6N BLACK RIVER	69 Springhill	3.3%	2.6%	1.8%	1.1%	0.3%	324	6.6	316	6.9
6S TERRACE ST	69 Terrace Street, Sydney	11.3%	11.0%	10.6%	10.3%	10.0%	713	7.0	524	7.8
6S TERR. EXT	69 Terrace Street, Sydney	11.2%	10.9%	10.6%	10.3%	10.0%	776	7.4	557	8.3
6V HOLLOW B	69 Newtonville (SSE White Rock)	-1.8%	-2.5%	-3.0%	-3.6%	-4.3%	502	3.6	389	3.9
70V BRIDGETOWN	69 Bridgetown	-1.3%	-2.5%	-3.8%	-5.0%	-6.3%	332	4.6	214	3.9
70W HIGH STREET	69 High Street, Bridgewater	-2.1%	-2.8%	-3.5%	-4.3%	-5.1%	453	8.4	365	9.2
73W AUBURNDALE	69 Auburndale	-1.5%	-1.8%	-2.0%	-2.1%	-2.5%	548	15.7	424	15.8
74N SPRINGHILL	69 East of Springhill Town	2.3%	1.9%	1.4%	0.9%	0.4%	404	15.9	391	16.9
74V CORNWALLIS	69 Cornwallis	2.9%	1.0%	-1.1%	-3.2%	-5.4%	367	2.8	183	2.6
75N DOMTAR	69 Nappan	5.1%	4.1%	3.1%	2.1%	1.1%	275	5.1	269	5.3
75W WESTHAVER	69 Blockhouse - Maitland	-1.0%	-1.3%	-1.5%	-1.8%	-2.2%	355	23.6	298	22.0
76V MAITLAND	69 Maitland Bridge	7.1%	4.9%	2.6%	0.3%	-2.2%	229	1.7	158	2.1
76W MAHONE T	69 Fauxbourg (Mahone Bay)	-0.8%	-1.5%	-2.2%	-2.9%	-3.8%	299	6.1	258	6.6
76W MAHONE BAR	69 Mahone Bay	-0.4%	-1.2%	-1.9%	-2.8%	-3.7%	287	5.2	249	5.7

Note: This table does not imply that the indicated size of generator can be interconnected at the bus listed.
All interconnections are subject to System Impact Studies.

2014 Transmission Bus
Loss Factor and Short Circuit Level Data

Station ID	NAME	KV	LOCATION	Incremental Locational Loss Factors											Short Circuit Level			
				110 MW	100 MW	90 MW	80 MW	70 MW	60 MW	50 MW	40 MW	30 MW	20 MW	10 MW	Maximum (MVA)	X/R Ratio	Minimum (MVA)	X/R Ratio
77V CONWAY	69 Digby	4.9%	2.3%	-0.2%	-3.0%	-5.5%	383	3.2	146	2.1	
78W MARTINS	69 Martins Brook (North West)	-0.4%	-1.6%	-2.7%	-4.0%	-5.4%	252	3.7	223	4.0	
79V 3 MILE PLAIN	69 Plains	-0.9%	-1.3%	-1.8%	-2.3%	-2.8%	650	5.9	511	6.9	
79W LUN SWST	69 Green St. Lunenburg	-0.1%	-1.4%	-2.8%	-4.2%	-5.9%	237	3.3	211	3.6	
7N PUGWASH	69 Pugwash	5.1%	3.9%	2.6%	1.4%	0.0%	154	6.4	152	6.5	
7W HARMONY	69 Harmony Mills	7.3%	5.2%	3.0%	0.7%	-1.8%	230	1.7	162	2.1	
80W INDIAN PATH	69 Indian path	1.6%	-0.1%	-2.0%	-4.0%	-6.3%	185	2.8	169	3.0	
81S RESERVE	69 Reserve Street, Glace Bay	10.8%	10.4%	9.9%	9.5%	9.0%	636	4.3	482	5.1	
81V ANNAPOLIS	69 Annapolis River Causeway	0.1%	-1.4%	-2.8%	-4.4%	-5.9%	396	4.9	203	3.4	
81W LUNENBUR	69 Lunenburg	0.3%	-1.2%	-2.7%	-4.2%	-6.0%	229	3.1	205	3.4	
82S WHITNEY PIER	69 Lingan Road, Sydney	12.2%	11.9%	11.5%	11.1%	10.8%	705	5.0	520	5.8	
82W NATIONAL SEA	69 Blue Rocks	1.5%	-0.2%	-1.9%	-3.7%	-5.8%	208	2.7	188	3.0	
83V WOLFVILLE	69 Wolfville	-3.1%	-3.6%	-4.1%	-4.6%	-5.2%	515	4.1	412	4.8	
84S VJ DISTRIBUTION	69 Victoria Junction	11.6%	11.4%	11.2%	11.0%	10.8%	1214	10.1	751	10.6	
84W ROBINSONS	69 Robinson Corner	2.3%	0.9%	-0.5%	-1.9%	-3.5%	164	4.8	153	5.1	
85W EAST RIVER	69 East River	-0.1%	-0.7%	-1.4%	-2.0%	-2.7%	218	10.3	199	10.6	
85W CANEXEL	69 East River	0.5%	-0.3%	-1.0%	-1.8%	-2.7%	202	8.5	186	8.8	
86W MIDRIVSW	69 3.7 km North of East River	1.0%	0.0%	-1.0%	-2.0%	-3.1%	180	6.9	167	7.2	
87W HUBBARDS	69 Hubbards, Mill Lake Road	-0.6%	-1.1%	-1.5%	-1.9%	-2.4%	251	18.1	226	17.7	
88H UPPER. MUSQ	69 Upper Musquodoboit	13.8%	10.7%	7.3%	3.6%	-0.7%	119	2.0	111	2.1	
88W PLEASANT ST	69 Pleasant St., Yarmouth	-4.8%	-6.5%	-8.3%	-10.2%	-12.4%	288	2.2	196	2.8	
88W PEASANT_B5	69 Pleasant St., Yarmouth	-5.4%	-6.9%	-8.5%	-10.2%	-12.2%	288	2.2	196	2.8	
89N NUTTBY	69 Co.	7.7%	6.8%	6.0%	5.0%	4.2%	268	4.5	253	4.7	
90H SACKVILLE	69 Bedford, Lower Sackville	-0.6%	-0.7%	-0.8%	-0.9%	-1.0%	1192	12.3	800	13.3	
91H TUFTCOVE	69 Tufts Cove, Dartmouth	0.0%	0.0%	0.0%	-0.1%	-0.1%	2181	38.9	1130	21.5	
91W MIDDLEFIELD	69 Middlefield	7.0%	5.4%	3.9%	2.3%	0.6%	296	2.1	199	2.5	
92V MICH WAT	69 Waterville - Cambridge	-4.7%	-5.4%	-6.1%	-6.8%	-7.5%	446	4.1	359	4.6	
92W CARLETON	69 Carleton, Yarmouth	-2.4%	-3.9%	-5.4%	-7.0%	-8.7%	343	2.2	219	2.9	
93V SAULNIER	69 Saulnierville	8.1%	4.9%	1.6%	-1.5%	-6.5%	169	2.7	110	2.2	
95H MALAY FALLS	69 Malay Falls	12.7%	9.8%	7.1%	4.3%	1.2%	143	4.0	119	3.6	
96H RUTH FALLS	69 East River, Sheet Harbour	14.6%	11.4%	8.2%	4.8%	1.0%	133	3.7	110	3.2	
96S DONKIN RD	69 Donkin or Schooner Pond	11.4%	10.8%	10.2%	9.6%	9.1%	567	3.3	442	4.0	
98V GULLIVERS	69 Digby Neck	8.6%	5.6%	2.6%	-0.5%	-3.7%	392	5.7	118	2.1	
99H FARRELL	69 Farrell St., Dartmouth	0.0%	0.0%	-0.1%	-0.1%	-0.2%	2109	30.7	1111	20.2	
99W BRIDGEWATER	69 Bridgewater	-1.4%	-1.5%	-1.7%	-1.8%	-2.1%	587	24.6	447	22.0	
9C ABERDEEN	69 Aberdeen	14.7%	13.7%	12.7%	11.7%	10.7%	179	4.7	164	4.9	
9W TUSKET B51	69 Tusket Falls	-6.3%	-7.1%	-7.8%	-8.6%	-9.6%	543	6.3	286	6.1	
9W Tusket B53	69 Tusket Falls	-6.3%	-7.1%	-7.8%	-8.6%	-9.6%	543	6.3	286	6.1	

Note: This table does not imply that the indicated size of generator can be interconnected at the bus listed.
All interconnections are subject to System Impact Studies.

NON-CONFIDENTIAL

1 **Request IR-2:**

2

3 **Please provide any estimates available to NS Power of the “system dispatch, load following**
4 **and operating reserve effects” of renewable by energy source (Appendix 16 at 30):**

5

6 (a) **Wind**

7 (b) **Solar**

8 (c) **Biomass**

9 (d) **Tidal**

10 (e) **Small hydro**

11

12 **Response IR-2:**

13

14 The effects of all system resources, including wind, solar, biomass, tidal and small hydro, on all
15 system operating parameters, including system dispatch, load following and operating reserve,
16 are considered in the system dispatch optimization simulation simultaneously. The analysis of
17 the effects of individual resources on specific system operating parameters is not available.

18

19 For more information, refer to the 2013 GE Energy Consulting report, *Nova Scotia Renewable*
20 *Energy Integration Study*, which was provided by NS Power in the 2014 Annual Capital
21 Expenditure Plan proceeding. It can be found on the NSUARB website under Matter Number
22 M05998, Exhibit N-3, as NSUARB IR-19 Attachment 1.

NON-CONFIDENTIAL

1 **Request IR-3:**

2

3 **Please explain whether NS Power believes that all types of renewables used in RtR**
4 **transaction should pay for the same level of system dispatch, load following and operating**
5 **reserve, and if so, why.**

6

7 Response IR-3:

8

9 These services are all Ancillary Services provided under the OATT and are required in order to
10 ensure reliable service to customers. As a result, in accordance with the FERC 888 pro-forma
11 tariff and subsequent practice, these costs have been allocated and charged according to customer
12 load. This is unchanged from the requirements under the OATT.

13

14 NS Power has seen no cause for any revision of this industry accepted practice for the purpose of
15 the RtR market.

NON-CONFIDENTIAL

1 **Request IR-4:**

2

3 **Reference: Distribution Losses**

4

5 **Please reconcile the 7.7% distribution losses in Appendix 13 (e.g., page 136) and Appendix**
6 **14, pp. 4–6, with the much lower average distribution losses reported in the EBS tab of the**
7 **Appendix 24 spreadsheet.**

8

9 Response IR-4:

10

11 The distribution losses of 7.7% were used by NS Power in the illustrative bill calculations in
12 response to Scotian WindFields Inc. DR-1 (**Appendix 14**) and is consistent with that applied in
13 **Appendix 24**. The bill calculations in Appendix 14 are for the month of February and use
14 distribution losses of 7.7% from that month. The same distribution line losses are used in bill
15 calculations for the month of February in the EBS tab of Appendix 24. The average line losses
16 of 6.2% from the EBS tab represent an annual average.

NON-CONFIDENTIAL

1 **Request IR-5:**

2

3 **Reference: Spill and Top-Up Rates**

4

5 **Please provide all workpapers (including the input and output from the Plexos runs)**
6 **supporting the following values in Appendix 19A:**

7

8 **(a) \$13,052,400 for “Avoided Costs of departing customer Load before taking energy**
9 **balancing service from NS Power.”**

10

11 **(b) \$11,541,300 for “Avoided Costs of departing customer Load after taking energy**
12 **balancing service from NS Power.”**

13

14 **Response IR-5:**

15

16 (a-b) The calculation of the avoided costs above is provided in the response to Multeese DR-
17 25, included in Appendix 13B. It is predicated on the Plexos run results included in
18 Attachment 1 to **SBA IR-8 part (a)**.

NON-CONFIDENTIAL

1 **Request IR-6:**

2

3 **Reference: Spill and Top-Up Rates**

4

5 **Please provide a breakdown of the avoided costs by month and by time of day, if available.**

6

7 Response IR-6:

8

9 The avoided costs were calculated on an annual basis from the model results. Time of day
10 avoided costs are not available from the simulation output.

NON-CONFIDENTIAL

1 **Request IR-7:**

2

3 **Reference: Spill and Top-Up Rates**

4

5 **Please identify the period for which Appendix 19A estimates the costs of the EBS.**

6

7 Response IR-7:

8

9 Please refer to **SBA IR-8 part (b)**.

NON-CONFIDENTIAL

1 **Request IR-8:**

2
3 **Reference: Spill and Top-Up Rates**

4
5 **Please explain why NS Power chose to present only annual energy charges for customers**
6 **who will have interval meters and can be charged by month and time of day.**

7
8 Response IR-8:

9
10 Please refer to **Section 5.5.2** of the Cary Report (**Appendix 16**). In brief, the Company notes as
11 follows:

- 12
- 13 • The avoided cost at any time is highly dependent on other variable generation
14 production, with which the RtR generation production may be correlated.
15
 - 16 • The pattern of such RtR generation is not pre-determinable and as a result, cannot
17 be used as a basis for determining hourly rate differentials.
18
 - 19 • NS Power cannot therefore use pre-determined time of day or seasonal rates to
20 recover all the losses that would otherwise arise from differences in marginal cost
21 at time of spill and marginal cost at time of top-up.
22
 - 23 • Given a need for a spread between top-up and spill rates, there is no benefit of the
24 additional complexity that would arise from superimposing such spread on rates
25 that vary on an hourly or seasonal basis.
26

27 The use of *ex-post* calculated hourly incremental costs would add significant further uncertainty,
28 administration and cost to the settlement process and was rejected for those reasons.
29

NON-CONFIDENTIAL

1 The selected approach is consistent with the annual basis for the Bundled Service rates against
2 which RtR service competes, and avoids the need for further complexity to address variable top-
3 up rates in the determination of the Renewable to Retail Market Transition Tariff energy charges.

NON-CONFIDENTIAL

1 **Request IR-9:**

2
3 **Reference: Spill and Top-Up Rates**

4
5 **Please enumerate the categories of costs that are assumed to be avoidable in the Plexos**
6 **runs. In particular, do the Plexos runs reflect:**

- 7
- 8 (a) **Variable non-fuel O&M, including the effect of energy load on maintenance**
9 **intervals.**
 - 10
 - 11 (b) **The effect of energy loads and renewable capacity on NS Power's ability to**
12 **mothball units during the summer.**
 - 13
 - 14 (c) **The effect of energy loads and renewable capacity on NS Power's ability to**
15 **retire coal plants earlier than currently planned.**
 - 16
 - 17 (d) **The effect of energy loads and renewable capacity on the need for new**
18 **generation.**
 - 19
 - 20 (e) **Variable interim capital additions, including environmental retrofits.**
- 21

22 **Response IR-9:**

23
24 The categories of costs assumed to be avoided in the Plexos runs are: fuel costs, unit start costs,
25 variable operating and maintenance charges based on the generation by each unit, abatement
26 costs, and market purchases.

27
28 The avoided costs runs did not reflect the other effects described in parts (a–e).

NON-CONFIDENTIAL

1 **Request IR-10:**

2

3 **Does NS Power believe that the avoided costs for the RtR should incorporate savings that**
4 **depend on renewable energy contributions for several years, or on multiple renewable**
5 **projects? If not, please explain why.**

6

7 Response IR-10:

8

9 In the context of the Energy Balancing Service (EBS) Tariff, the avoided costs are those related
10 to energy production. These avoided costs are mostly fuel-related and will vary from year to
11 year. The EBS Tariff elements related to avoided cost will therefore be subject to annual
12 adjustment.

13

14 In the context of the Renewable to Retail Market Transition Tariff, some cost mitigation may be
15 annual in nature, but any ability to avoid or defer investment would be considered in the context
16 of longer time horizons which may explicitly consider cumulative effects of multiple RtR
17 projects.

NON-CONFIDENTIAL

1 **Request IR-11:**

2

3 **Does NS Power agree that, once the transmission ties to New Brunswick are reinforced, the**
4 **benefits of spill and the cost of top-up will include changes in sales over those lines to New**
5 **Brunswick and New England? If not, please explain why.**

6

7 Response IR-11:

8

9 Energy flows on the tie are currently limited in part by system constraints in NB Power's service
10 territory. In the hypothetical scenario referenced, and to the extent these system constraints
11 could be alleviated, an increase in exports from and imports to Nova Scotia may be possible.
12 The proposed annually adjusted approach to determination of the top-up and spill rates enables
13 timely alignment of Energy Balancing Service Tariff rates with changing market conditions.

NON-CONFIDENTIAL

1 **Request IR-12:**

2

3 **Do the proposed EBS rates reflect the relative contribution of various types of renewable**
4 **generation to ramping costs and operating reserves?**

5

6 **(a) If not, would such consideration be appropriate in setting the EBS rates?**

7

8 Response IR-12:

9

10 No. The contribution of various types of renewable generation to ramping costs is not
11 considered in the system dispatch optimization model. The effect of incremental renewable
12 energy additions on steam unit ramping costs is negligible compared to the cost of fuel. Further,
13 while operating reserve provision is a part of the Plexos system dispatch optimization,
14 intermittent variable renewable resources are not contributors to the operating reserve provision
15 in the dispatch optimization.

NON-CONFIDENTIAL

1 **Request IR-13:**

2

3 **For Appendix 19A, please provide the number of GWh of the following transactions**
4 **assumed for the RtR Plexos runs:**

5

6 (a) **spill GWh**

7 (b) **top-off GWh**

8

9 Response IR-13:

10

11 Plexos system dispatch optimization simulations optimize system dispatch by taking into account
12 all system resources and demand. Top-up and spill amounts are not a direct result of the Plexos
13 simulation. Plexos reflects conservation of energy between supply and demand, therefore top-up
14 and spill amounts are matched in the annual outcome. Please refer also to **CA IR-17**.

NON-CONFIDENTIAL

1 **Request IR-14:**

2

3 **Please provide the characteristics assumed for the “effect of 3rd party renewable**
4 **generation under no curtailment assumption” in Appendix 19A, including at least the**
5 **following:**

6

7 (a) **The type of renewable generation (e.g., small hydro, wind, solar, tidal).**

8

9 (b) **The monthly, daily and hourly generation pattern assumed, and the basis for those**
10 **assumptions.**

11

12 (c) **Forecasting accuracy for commitment planning, for the renewable generator and**
13 **other resources.**

14

15 **Response IR-14:**

16

17 (a) The renewable generation was modeled with the characteristics of wind generation.

18

19 (b) The generation pattern of the third party renewable generation was an hourly shape with a
20 profile based on NS Power historical hourly wind generation, fitted using the energy of
21 an equivalent 50 MW wind farm.

22

23 (c) Plexos simulation unit commitment optimization is based on a matched wind and load
24 hourly shape data set with no forecasting error.

NON-CONFIDENTIAL

1 **Request IR-15:**

2
3 **Please restate the credits against the total energy-related costs in cell G29 of Appendix 19A**
4 **in ¢/kWh.**

5
6 **(a) Please confirm that these credits total less than the estimated value of avoided costs**
7 **with or without EBS (cells F6 and F8).**

8
9 **(b) Please confirm that the sum of the avoided-cost rate and the fixed-cost rate would**
10 **exceed the energy charge for full-service customers.**

11
12 **(c) Please explain why NS Power should charge more for energy provided to RtR**
13 **customer than to full-service customers.**

14
15 **Response IR-15:**

16
17 **The restated credits, based on the 2014 Cost of Service Study, are as follows:**

18

	Costs in thousands of \$'s	Unit Costs in cents per kWh
All energy-related generation costs	\$753,049	7.920
Less		
Plant Fuel Cost	\$367,943	3.870
Purchased Power regular	\$507	0.005
Purchased Power biomass	\$11,595	0.122
Purchased Wind Power	\$59,982	0.631
Imports	\$217	0.002
Export Revenues	-\$1,826	(0.019)
Subtotal Fuel-related	\$438,418	4.611
Energy-related fixed costs	\$314,631	3.309

19
20

NON-CONFIDENTIAL

1 (a) Confirmed. However, NS Power notes, as provided in the response to **SBA IR-8**, the
2 avoided cost calculations were derived using multiple runs over a ten year period from
3 2018 to 2027 based on the 2014 IRP preferred resource plan. Going forward, for the
4 purpose of the Annually Adjusted Rate setting process, the Company intends to use
5 calculations based on a single test year. The table below illustrates that individual test
6 year results can vary.

7

Source	Avoided Cost of 25 MW decrement (c/kWh)	Average fuel-related cost embedded in base cost rates (c/kWh)	% Variance from average fuel cost	Outcome
2014 LF Rate	4.55	4.611	-1%	Lower
2015 LF Rate	5.08	4.611	10%	Higher
2016 LF Rate (Preliminary Estimate from 2016 BCF)	4.53	4.915	-8%	Lower

8
9 (b) Energy charges for full service customers billed under most rate classes are greater than
10 the sum of the avoided fuel and fixed unit costs of 7.92 cents per kWh. For example, the
11 current energy charge for the Domestic class is 14.251 cents per kWh and for the Large
12 General class it is 8.029 cents per kWh. The Company notes, however, that energy
13 charges in rate classes that do not include demand charges are designed to recover both
14 the energy and demand related costs.

15
16 (c) The proposed approach to determination of the fixed cost component of the EBS charge
17 is based on fully allocated costs as is the case under the full service rates. However, the
18 fuel cost component is based on incremental fuel costs as opposed to average fuel costs
19 applicable under the bundled service rates. As can be seen from parts (a) and (b) NS
20 Power would not always charge more for energy provided to the RtR customers than to
21 full service customers.

NON-CONFIDENTIAL

1 The top-up and spill energies are typified by uncertainty in terms of their annual levels
2 and hourly patterns. They are far less predictable than loads served under the bundled
3 service rate classes. Due to variability in the spill and top-up energies, the Company
4 must often ramp up and down its dispatchable generation forcing it to operate under
5 suboptimal heat curve conditions. This results in higher unit fuel costs which are
6 attributable to the characteristics of the RtR market. NS Power energy provided under
7 the top-up service and displaced under the spill from the LRS's generators comes solely
8 from dispatchable fossil fuel-fired or hydro generators. The more expensive must-run
9 renewable purchases from IPPs and COMFIT are not affected by this balancing service.

NON-CONFIDENTIAL

1 **Request IR-16:**

2

3 **Reference Appendix 15 at 11:**

4

5 **This Annual Energy Cost Adjustment is deducted from the base energy rate**
6 **to get the net energy charge under the tariff. If the average fuel cost were to**
7 **exceed the avoided cost, this Energy Charge Adjustment would become an**
8 **addition to the net energy charge under the tariff.**

9

10 **Since NS Power's estimate of the avoided costs is higher than the average fuel cost, why**
11 **doesn't NS Power subtract that difference from the fixed cost energy rate?**

12

13 Response IR-16:

14

15 To provide an indication of a longer-term pricing level under the top-up and spill rates, the
16 Company estimated annual avoided costs based on multiple Plexos runs over a ten year period
17 from 2018 to 2027 taking advantage of the 2014 IRP cost information on the regulatory record.
18 Going forward, however, commencing with the 2017 EBS Tariff rate submission, the Company
19 proposes to estimate avoided costs for a single test year analysis, consistent with the treatment of
20 fuel costs of other Annually Adjusted Rates. As indicated in the response to **CA IR-15**, under
21 the single test year approach the annual marginal costs are expected to fluctuate closely around
22 the average system fuel cost. The adjustment is expected to be minor and close to zero on the
23 average in the foreseeable future. In view of this, no estimate of this adjustment was included in
24 the RTT in the Application.

NON-CONFIDENTIAL

1 **Request IR-17:**

2
3 **Please provide the basis for assuming that “top-up energy accounts for 50% of the total**
4 **energy consumed in the RtR market” (Appendix 19A).**

5
6 Response IR-17:

7
8 Absent forecast information on types and numbers of future RtR customers as well as types of
9 future renewable generation that would make it possible for the Company to develop hourly load
10 and generation profiles, the Company assumed hourly fluctuations in top-up and spill energy to
11 be random with zero percent correlation and the same factors for load and capacity, which yields
12 the 50 percent overlap factor in top-up deliveries and customer load.¹ From a statistical outcome
13 perspective this represents the safest approach to minimize swings in over- or under-recovery of
14 energy balancing costs. Going forward, as the Company accumulates historic data on hourly
15 energy balancing services and gathers information on future service potential, the Company will
16 provide a forecast of this factor. Please refer to the following Data Requests for more details:

- 17
18 • Multeese DR-25, **Appendix 13B**
19 • Multeese DR-30, **Appendix 13**, pages 113-115
20 • Multeese DR-35, **Appendix 13**, pages 124-128

¹ The Company realizes that in actuality the RtR customer load factors will likely be higher than capacity factors of wind generation, having the reducing effect on the overlap factor, and that there may be some measure of a positive correlation in fluctuations of load and generation, having an offsetting increasing effect on the overlap factor.

NON-CONFIDENTIAL

1 **Request IR-18:**

2

3 **Please provide the ratio of top-up energy to total consumption for a typical residential RtR**
4 **customer served by:**

5

6 **(a) A typical NS Power wind resource.**

7

8 **(b) A biomass resource that operates with the same hourly pattern as:**

9

10 **(i) Port Hawkesbury Biomass**

11 **(ii) Brooklyn Power**

12

13 **(c) A small hydro resource that operates with the same hourly pattern as:**

14

15 **(i) Black River Hydro**

16 **(ii) The Lequille Hydro system**

17

18 **(d) A tidal project that operates with the same hourly pattern as Annapolis Tidal**
19 **Power.**

20

21 **Response IR-18:**

22

23 **(a) The ratio of top-up energy to total consumption for a residential RtR customer served by**
24 **wind in the Plexos modeling was approximately thirty percent.**

25

26 **(b–d) The requested analysis was not completed as part of this Application.**

NON-CONFIDENTIAL

1 **Request IR-19:**

2

3 **Please provide the derivation of the excess spill discount.**

4

5 **(a) If the spill rate is properly set, at the value to the system of backing down NS Power**
6 **generation, why would any discount be appropriate for additional energy provided**
7 **in excess of RtR customer requirements?**

8

9 Response IR-19:

10

11 The Company did not undertake a cost study in support of the proposed excess spill discount
12 rates. The rates were set in a manner that directionally aligns with the anticipated decline in fuel
13 cost savings with increases in excess spill and also provides an incentive to the LRS to match, to
14 the maximum extent possible, generation with RtR load. Please refer to **ECI IR-7** for more
15 details.

16

17 (a) Given the declining scale of the excess spill discounts, a generic flat spill rate, applicable
18 on a monthly and year-end basis, would be lower than the one currently proposed for the
19 monthly compensation along with separate excess spill discount rates. The lower flat
20 spill rate would disadvantage those LRSs that come close to matching their generation to
21 their load.

NON-CONFIDENTIAL

1 **Request IR-20:**

2

3 **Please provide the hourly generation for each renewable resource of the NS Power system**
4 **with hourly metering (including purchases and NS Power hydro, wind and biomass**
5 **resources), for each hour since January 2010.**

6

7 Response IR-20:

8

9 The data requested was not used in the preparation of this Application. The tariffs were prepared
10 using average monthly system dispatch optimization data outputs.

11

12 Historical hourly generation was not used by the Plexos model to complete the analysis. Hydro
13 generation is modeled in Plexos as monthly available energy with dispatch optimized within
14 individual hydro system dispatch constraints. Wind generation is based on a 2014 hourly wind
15 generation profile from which Plexos develops a fitted hourly wind generation shape based on
16 forecasted monthly energy and maximum capacity of each wind resource. The Port Hawkesbury
17 Biomass generation is modeled as must-run using constraints to enforce the legislated amount of
18 energy produced. Energy purchases are not input directly into the model, but selected by a
19 dispatch optimization algorithm economically, given the system conditions.

NON-CONFIDENTIAL

1 **Request IR-21:**

2

3 **Please provide any data available to NS Power on its hourly marginal energy costs, for any**
4 **available periods since January 2010.**

5

6 Response IR-21:

7

8 The requested analysis was not completed as part of this Application. Please refer to **CA IR-20**.

NON-CONFIDENTIAL

1 **Request IR-22:**

2

3 **Please explain why Appendix 19A uses a transmission loss factor, rather than losses to the**
4 **customer meter.**

5

6 Response IR-22:

7

8 Appendix 19A is concerned with a determination of a generic energy-related energy charge
9 applicable to LRS load estimated at a transmission service level. The charge is not specific to
10 any bundled service rate class. The fixed cost portion of the rate is determined by dividing the
11 total system energy-related fixed generation costs of \$314,631,000 by the system energy
12 requirement of 9,507,746 GWh at a transmission service level. The energy requirement was
13 determined by applying an average system transmission loss factor of 3.2%, as used in the 2013
14 General Rate Application and Cost of Service Study proceedings, to the total energy
15 requirement. Given that NS Power's Cost of Service model provides for a uniform transmission
16 loss factor for all distribution served customers, the proposed approach is the most effective way
17 to estimate energy requirements at transmission level of these customers.

NON-CONFIDENTIAL

1 **Request IR-23:**

2
3 **Please explain the difference between the 3.2% transmission loss factor used in Appendix**
4 **19A and the 2.28% transmission loss factor in Appendix 14A, note 2.**

5
6 **(a) Please provide the derivation of the 3.2% transmission loss factor used in Appendix**
7 **19A.**

8
9 **(b) Please provide the derivation of the 2.28% transmission loss factor used in**
10 **Appendix 14A.**

11
12 **Response IR-23:**

13
14 The 3.2% transmission loss factor identified in **Appendix 19A** is employed in the 2014 Cost of
15 Service study. The 2.28% loss factor of **Appendix 14A** is the System Average Transmission
16 Loss Factor applied to Network Integration Transmission System Load in accordance with
17 Section 28.5 and Schedule 9 (paragraph 2) of the NSPI Open Access Transmission Tariff.

18
19 (a) The Cost of Service Transmission Loss Factor includes generator transformer losses and
20 assumes delivery at distribution voltage levels, thereby including the losses of NSPI
21 distribution substation transformers.

22
23 (b) The System Average Transmission Loss Factor is computed annually based on the hourly
24 calculated transmission system losses from the previous calendar year. Actual system
25 operational conditions for each hour of each month are imported into a model of the NS
26 Power system (in the transmission system analysis program). The model calculates the
27 transmission system losses for each hour. Network Integration Transmission Service
28 requires that the transmission customer replace losses associated with transmission
29 service, which does not include generator transformer losses or distribution substation

NSPI Renewable to Retail (NSUARB P-896/M06214)
NSPI Responses to Consumer Advocate Information Requests

NON-CONFIDENTIAL

1 transformer losses. As a result, the System Average Transmission Loss Factor is lower
2 than the Cost of Service Transmission Loss Factor.

NON-CONFIDENTIAL

1 **Request IR-24:**

2
3 **Reference: Forecasting Charges**

4
5 **Please provide the derivation of the charges for the “aggregate hourly scheduled or**
6 **forecast quantity” (Appendix 12, p. 16), including:**

7
8 **(a) The rationale for a 10% threshold, rather than a higher or lower percentage.**

9
10 **(b) The rationale for charging 10% of marginal cost, rather than a higher or lower**
11 **percentage.**

12
13 **(c) The rationale for using the average period system marginal cost for the billing**
14 **month for computing the 10%, rather than the cost in the hours with the forecasting**
15 **error.**

16
17 **Response IR-24:**

18
19 The Company did not conduct a cost analysis in support of this proposal. Rather, the proposed
20 approach builds on the pricing construct already approved for use under Schedule 4 of the
21 OATT. This approach is consistent with the Company’s objective to leverage, to the extent
22 practical, the existing rate design structures to keep the proposed rate changes simple.

23
24 **(a) The 10 percent threshold is currently approved for use for non-dispatchable generation**
25 **energy imbalance services under Schedule 4.**

26
27 **(b) The 10 percent threshold for adjustment to hourly marginal costs, applicable to all**
28 **deviations from schedule outside of the +/- 10 percent deviation band, is currently**
29 **approved for use for non-dispatchable generation energy imbalance services under**
30 **Schedule 4.**

NON-CONFIDENTIAL

1
2 (c) In design of this component, the Company borrowed from a simplified treatment of
3 hourly deviations within the deviation band as used for the pricing purposes of Load
4 Energy Imbalance. Given the small scale renewable generation anticipated under the
5 market and the fact that the purpose behind this schedule is to provide only an incentive
6 for accurate forecasting and not to recover costs of balancing services, as these are
7 accounted for under the Energy Balancing Service Tariff, this simplification is considered
8 appropriate.¹

¹ Assuming a purely random occurrence of negative and positive deviations outside the 10% band such that positive and negative imbalances net out to zero at the end of the billing period, a non-dispatchable generator should see very similar billing results under the hourly approach of schedule 4 and time of day period approach of schedule 4A.

NON-CONFIDENTIAL

1 **Request IR-25:**

2

3 **Reference: Forecasting Charges**

4

5 **Considering NS Power's experience with forecasting wind output, and the greater base**
6 **over which it conducts such forecast, why does NS Power propose to require the LRS to**
7 **perform its own duplicative forecasting for wind generation, rather than NS Power**
8 **assuming the responsibility for forecasting wind-plant output, other than equipment**
9 **outages?**

10

11 Response IR-25:

12

13 This provision is consistent with the requirements of the current Market Rules. Section 4.0 to 4.5
14 (**Appendix 25**, pages 88-99) covers scheduling. The proposed amendment to the Market Rules
15 for Submission of Energy Schedules for the Renewable to Retail Market is in **Appendix 25**
16 Section 3.6, on pages 93-94.

17

18 Each generator technology and location will have unique characteristics that will affect the
19 generation forecast. The generator owner will be in the best position to provide the generator
20 day-ahead forecast.

NON-CONFIDENTIAL

1 **Request IR-26:**

2

3 **Reference: Transition Charges**

4

5 **Please provide the derivation of the RTT charges.**

6

7 Response IR-26:

8

9 For derivation of the Renewable to Retail Market Transition Tariff charges please refer to:

10

- 11 • The Company's response to Multeese DR-29, included in Application **Appendix**
- 12 **13C**, which provides the derivation of the Standby Service Tariff charges, and
- 13
- 14 • Application **Appendix 19A**, which provides the derivation of the Energy
- 15 Balancing Service Tariff charges.
- 16

17 For the explanation of why the same charges are used in the RTT tariff as in the EBS and SS

18 tariffs please refer to **NSUARB IR-2**.

NON-CONFIDENTIAL

1 **Request IR-27:**

2

3 **Reference: Transition Charges**

4

5 **Please explain the logic for charging a demand charge of \$5.37/kW-month for an LRS**
6 **serving customers in rate classes that do not have demand charges.**

7

8 Response IR-27:

9

10 The charge determinant for the demand charge element of the Renewable to Retail Market
11 Transition Tariff depends on the quantity and characteristics of the LRS's generation, and only in
12 exceptional circumstances on the customer load. The generation is independent of the customer
13 class(es) being served. There would be no reason to differentiate the charge basis according to
14 customer class.

15

16 It should be noted in support that the energy charges to Bundled Service residential customers do
17 include in effect the conversion of that \$5.37/kW-month demand charge into an energy charge
18 based on the relevant class load profile.

NON-CONFIDENTIAL

1 **Request IR-28:**

2

3 **Reference: Transition Charges**

4

5 **Please explain why NS Power is proposing to charge the RTT demand charge on the**
6 **“LRS’s firm demand at the time of system coincident firm load peak in each month,”**
7 **rather than just the three winter months, or some other weighting of months.**

8

9 Response IR-28:

10

11 The demand charge in the Renewable to Retail Market Transition Tariff is a reflection of the
12 demand charge in the Standby Service Tariff.

13

14 Under a steady-state RtR market without migration of customers to and from RtR supply and
15 among LRSs, it would be possible to utilise the three winter months as a basis for charges under
16 both tariffs. The need to achieve fair cost recovery under circumstances where we can expect
17 migration of customers, particularly during market growth, drives the use of equivalent annual
18 peak demand derived from monthly coincident peaks.

NON-CONFIDENTIAL

1 **Request IR-29:**

2
3 **Reference: Transition Charges**

4
5 **The derivation of the RTT demand charge appears to divide total demand-allocated**
6 **generation costs by the sum of coincident loads in just three months (Appendix 13, at 112),**
7 **but NS Power is proposing to apply this charge in all twelve months. If this does not result**
8 **in a mismatch in costs and revenues and significant over-collection of costs, please explain**
9 **why.**

10
11 Response IR-29:

12
13 **Appendix 13** at page 112 shows a three month average coincident peak of 1,811,990 kW.

14
15 The annual demand related fixed generation cost is \$121,275,450.

16
17 The annual cost per kW of winter peak (measured as the average of the three winter month
18 peaks) is \$64.440/kW-year.

19
20 The monthly cost per kW of equivalent winter peak is $\$64.440/\text{kW-year} \div 12 = \$5.370/\text{kW-}$
21 month .

22
23 Consider an example of an LRS with a customer portfolio with a three month average winter
24 peak = 20 MW. The monthly peak in a summer month may be, say, 15 MW, which is factored
25 up to 20 MW equivalent winter peak (using customer class factors as set out in the Standby
26 Service Tariff, using for this example an assumed average factor of 1.333).

27
28 The NS Power annual demand related fixed generation cost requiring to be recovered is
29 $20,000 \text{ kW} \times \$64,440/\text{kW-year} = \$1,288,800$.

NSPI Renewable to Retail (NSUARB P-896/M06214)
NSPI Responses to Consumer Advocate Information Requests

NON-CONFIDENTIAL

- 1 If the LRS self-supplies firm dependable capacity capable of supporting 8 MW of peak demand,
2 then NS Power provides 12 MW of Standby Service x 12 months x \$5.37/kW-month x 1,000 =
3 \$773,280.
4
- 5 The RTT demand charge, before mitigation, is 8 MW x 12 months x \$5.37/kW-month x 1,000 =
6 \$515,520.
7
- 8 The total NS Power recovery before mitigation is $\$773,280 + \$515,520 = \$1,288,800$.
9
- 10 This matches the cost to be recovered (before mitigation).

NON-CONFIDENTIAL

1 **Request IR-30:**

2

3 **Reference Appendix 16 at 26:**

4

5 **Given that RtR customers are to be served with the same reliability as**
6 **equivalent Bundled Service customers, the system adequacy requirement is**
7 **mandatory in respect of those customer.**

8

9 **Please explain how the RTT rate design reflects the contribution to system reliability of the**
10 **renewable generator.**

11

12 Response IR-30:

13

14 The services provided under the Energy Balancing Service Tariff, the Standby Service Tariff, the
15 OATT and the Distribution Tariff are designed so that in combination they provide the same
16 reliability as to equivalent Bundled Service customers.

17

18 The RTT does not contribute directly to system reliability, as its purpose is the recovery of
19 embedded costs otherwise transferred to bundled service customers by LRS supply under the
20 RtR market. The rate design does, however, result in charges that reflect the contribution to
21 system reliability of the renewable generator.

22

23 For example, if an LRS serves customers whose equivalent winter peak demand is 20 MW, and
24 its generation has a firm dependable capacity capable of supporting 8 MW, then NS Power
25 would provide 12 MW of Standby Service. The RtR supply displaces 8 MW of NS Power
26 service capability and the associated revenue. Unless and until NS Power can reduce its costs
27 (e.g. by avoided or deferred investment) corresponding to that 8 MW, those costs are recovered
28 from the LRS through the RTT. The RTT charges are thus reflective of the extent to which the
29 LRS's self-supply of capacity to support system reliability has displaced utilisation and cost
30 recovery on equivalent NS Power resources.

31

NON-CONFIDENTIAL

- 1 The energy charge under the RTT is similarly affected by the extent to which the LRS's supply
- 2 of energy, excluding top-up, has displaced NS Power supply, and in particular the fixed costs
- 3 recovered through that supply.

NON-CONFIDENTIAL

1 **Request IR-31:**

2

3 **Reference: FAM Rates**

4

5 **If the FAM balance is positive, implying that fuel costs were higher than reflected in base**
6 **rates, would it be appropriate to increase both the top-up and spill rates, since additional**
7 **energy supplied by NS Power and additional energy supplied by the LRS would be more**
8 **valuable than assumed in the original rate computation? If not, please explain why.**

9

10 Response IR-31:

11

12 The Company has proposed that the treatment of fuel costs under the top-up and spill rates be
13 consistent with that currently applicable to other Annually Adjusted Rates which are not subject
14 to the FAM. Load billed under the AAR rates accounts for a small percentage of the total system
15 load¹ and therefore has a limited effect on fuel costs of the FAM classes. Please refer to **SWEB**
16 **IR-4** and **NSUARB IR-1** for further discussion of this subject matter.

¹ The forecast for 2016 kWh sales to AAR rate classes in the 2016 Base Cost of Fuel proceeding amounts to 25 GWh representing about 0.2% of the total system load.

NON-CONFIDENTIAL

1 **Request IR-32:**

2

3 **Reference: Metering**

4

5 **Please describe the cost and capabilities of the interval meters that NS Power expects to**
6 **install for RtR customers, disaggregated by class, voltage, or other capability as**
7 **appropriate.**

8

9 Response IR-32:

10

11 The meters will be capable of recording hourly demand and usage data and periodically
12 uploading data to a central system using a data connection.

13

14 For an example of how present metering costs vary across customer classes, please refer to
15 Application **Appendix 11A**, Cost of Service Model, Tab Exh 6.1, lines 1-34.

16

17 Specific meters suitable for residential, commercial, and industrial RtR installations have not yet
18 been selected. In preparation for the implementation of the market opening, NS Power will
19 conduct a procurement exercise to source the meters from competitive suppliers. At this point
20 NS Power estimates that the installed cost for a new residential meter would be under \$500.
21 Some customers may already have the appropriate meters and will not need new meters.