

Interconnection Feasibility Study Report GIP-IR640-FEAS-R0

**Generator Interconnection Request 640
100 MW Wind Generation Facility
Uniacke, NS**

2022-03-16

Control Centre Operations
Nova Scotia Power Inc.

Executive Summary

This Feasibility Study report (FEAS) presents the results of a Feasibility Study Agreement for the connection of a 100 MW Wind Turbine Generation (WTG) facility interconnected to the NSPI system as Network Resource Interconnection Service (NRIS), with Energy Resource Interconnection Service (ERIS) as an option.

This project is listed as Interconnection Request #640 in the NSPI Interconnection Request Queue and will be referred to as IR640 throughout this report. The proposed Commercial Operation Date is 2025/12/31.

The Interconnection Customer (IC) identified a 138 kV bus at the 120H-Brushy Hill substation as the primary Point of Interconnection (POI). This WTG facility will be interconnected to the POI via a 5 km long 138 kV transmission line from the Point of Change of Ownership (PCO).

There is one relevant long-term firm Transmission Service Request (TSR) that has established Queue position and is at the System Impact Study (SIS) stage, with a requested in-service date of 2025/01/01. This request, TSR411, is expected to alter the configuration of the Transmission System in Nova Scotia. As a result, the following notice has been posted to the OASIS site¹:

Effective January 19th, 2021, please be advised that the completion of advanced-stage Interconnection Studies under the Standard Generator Interconnection Procedures (GIP) may be delayed pending the outcome of the Transmission Service Request (TSR) 411 System Impact Study, which is expected to identify significant changes to the NSPI transmission system. The revised expected completion date for the study is February 28, 2022. Feasibility Studies initiated prior to the completion of the TSR System Impact Study will be performed based on the current system configuration.

The system upgrades resulting from this TSR study are not expected to greatly influence the results of IR640, as it is connected in the Halifax Area and is electrically close to the load centre with minimal transmission system impact.

Based on the information provided by the IC, this feasibility assessment presents the following findings:

- There are no concerns regarding increased short circuit levels. The increase in short circuit level is still within the capability of associated breakers. The minimum three

¹ OASIS Generation Interconnection Procedures; <https://www.nspower.ca/oasis/generation-interconnection-procedures>

- phase short circuit level at the Interconnection Facility's (IF) low side bus is 564 MVA with all lines in service.
- Voltage flicker will be examined when data is made available for the SIS.
 - The project design must meet the NSPI Transmission System Interconnection Requirements (TSIR)².
 - Since IR640 meets the NERC definition of Bulk Electric System (BES), the high side interconnection with the 138 kV bus would also be considered BES. There is the potential for an exclusion from BES to be granted for the high side (138kV) bus based on further analysis per the NS BES Exception Procedure. This analysis will be initiated as part of the System Impact Study (SIS) and exclusion from BES will only be granted upon subsequent approval by the Nova Scotia Utility and Review Board (UARB).
 - IR640 proposes connecting to the 138 kV bus at 120H-Brushy Hill substation which is designated NPCC Bulk Power System (BPS). As such, all protection systems associated with the new 138kV breaker supplying the line to IR640 must comply with NPCC Directory 4 *System Protection Criteria*.
 - The preliminary loss factor is calculated as 0.5% while generating at the 120H-Brushy Hill 138 kV bus POI.
 - The power flow analysis identified no contingencies inside Nova Scotia that violate thermal loading criteria or voltage criteria while generating at full output.

The present preliminary non-binding cost estimate for interconnecting IR640 to the 120H-Brushy Hill 138 kV bus as Network Resource is \$5,181,000 (\$1,900,000 for Network Upgrades, \$2,810,000 for TPIF, 10% contingency adder). This does not include any To Be Determined costs associated with the SIS. This estimate will be further refined in the SIS and Facilities (FAC) studies.

Note that the proposed transmission path at 120H-Brushy Hill from the POI to PCO requires more detailed engineering to provide a more accurate cost estimate. It is the customers responsibility to provide a suitable right of way for the transmission line. The right of way shall be registered in NSPI's name.

The estimated time to construct the Network Upgrades and TPIF for NRIS operation is 18-24 months after the receipt of funds.

² NS Power Transmission System Interconnection Requirements; <https://www.nspower.ca/oasis/standards-codes>

Table of Contents

Executive Summary	ii
List of Tables & Figures	iv
1.0 Introduction.....	1
2.0 Scope.....	2
3.0 Assumptions.....	2
4.0 Project Queue Position.....	5
5.0 Short Circuit.....	7
6.0 Voltage Flicker & Harmonics	8
7.0 Load Flow Analysis	8
8.0 Voltage Control.....	11
9.0 System Security	13
10.0 Expected Facilities Required for Interconnection.....	14
11.0 NSPI Interconnection Facilities and Network Upgrades Cost Estimate.....	15
12.0 Loss Factor.....	16
13.0 Preliminary Scope of Subsequent SIS	16

List of Tables & Figures

Table 1: Transmission line ratings.....	5
Table 2: Maximum Short circuit levels in MVA	7
Table 3: Minimum Short circuit levels in MVA.....	7
Table 4: Flicker requirements	8
Table 5: Base Case Dispatch.....	10
Table 6: Power factor analysis results (@ 1.0 VPU)	12
Table 7: BPS & BES classification of neighbouring elements.....	13
Table 8: Cost estimate.....	15
Table 9: Loss factor	16
Figure 1: IR640 approximate geographic location	1
Figure 2: IR640 Point of Interconnection	2
Figure 3: GIP Queue	6
Figure 4: TSR Queue	6
Figure 5: NSPI Major Interfaces.....	9
Figure 6: Vestas V162 6.2 MW reactive power capability.....	11
Figure 7: NERC PRC-024-2 Attachment 2	12

1.0 Introduction

This Feasibility Study report (FEAS) presents the results of a Feasibility Study Agreement for the connection of a 100 MW Wind Turbine Generation (WTG) facility interconnected to the NSPI system as Network Resource Interconnection Service (NRIS), with Energy Resource Interconnection Service (ERIS) as an option.

This project is listed as Interconnection Request (IR) #640 in the NSPI Interconnection Request Queue and will be referred to as IR640 throughout this report. The proposed Commercial Operation Date is 2025/12/31.

The Interconnection Customer (IC) identified the 138 kV bus at 120H-Brushy Hill as the Point of Interconnection (POI). This WTG facility will be interconnected to the POI via a 5 km long 138 kV transmission line from the Point of Change of Ownership (PCO). Figure 1 shows the approximate location of the proposed IR640 site.




Figure 1: IR640 approximate geographic location




Figure 2: IR640 Point of Interconnection

2.0 Scope

This Interconnection Feasibility Study's (FEAS) objective is to provide a preliminary evaluation of system impact and a high-level non-binding cost estimate of interconnecting the new WTG facility to the NSPI Transmission System at the designated location based on single contingency criteria. This assessment will identify potential impacts on transmission element loading, which must remain within their thermal limits. Any potential voltage criteria violations will be identified and addressed. Circuit breakers must be upgraded if the proposed facility increases the short-circuit duty of any circuit breakers beyond their rated capacity.

The scope of the FEAS includes modelling the power system in normal state, with all transmission elements in service, under anticipated load and generation dispatch. A power flow and short circuit analysis will be performed to provide the following preliminary information:

- Identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection and any Network Upgrades necessary to address the short circuit issues associated with the IR.
- Identification of any thermal overload or voltage limit violations resulting from the interconnection and identify the necessary Network Upgrades to allow full output of the proposed facility.
- Description and high-level non-binding estimated cost of and time to construct the facilities required to interconnect the generating facility to the transmission system.

This FEAS does not include a complete determination of facility changes/additions required to increase the system transfer capabilities that may be required to the transmission system to meet the design and operating criteria established by NSPI, the Northeast Power Coordinating Council (NPCC), and the North American Electric Reliability Corporation (NERC). These requirements will be determined by a more detailed analysis in the subsequent interconnection System Impact Study (SIS). An Interconnection Facilities Study (FAC) follows the SIS in order to ascertain the final cost estimate to the interconnect the generating facility.

3.0 Assumptions

This FEAS is based on technical information provided by the IC. The POI and configuration are studied as follows:

1. NRIS and ERIS will be studied per the IR640 Feasibility Study agreement and section 3.2 of the Generation Interconnection Procedures (GIP).
2. Commercial Operation date: 2025/12/31.
3. The Interconnection Facility consists of 18 x 6.2 MW Vestas V162 wind turbine generator units (type 4 inverter-based), capped at 100 MW. Each WTG is connected via one of five 34.5 kV collector circuits to the 82.2/110/137 MVA substation step-up transformer.
4. The IC identified the 138 kV bus at the 120H-Brushy Hill substation as the POI. To facilitate this, a new 138 kV node can be created by installing one new breaker to split one of the existing 138 kV buses (see Figure 2 in Section 1).
5. This study uses 795 ACSR Drake rated at 100°C for the 5 km transmission line between 120H and the IC substation to match NSPI standard construction. This differs from the 1272 kmil Bittern ACSR conductor specified in the IC supplied single line diagram.
6. Preliminary data provided by the IC for the substation step-up transformer and padmount transformers:
 - 6.1. The substation step-up transformer was modelled as a 138 kV–34.5 kV (with 13.8 kV tertiary) transformer rated at 82.2/110/137 MVA, with a positive sequence impedance of 9% and zero sequence impedance of 7.65% at 82.2 MVA. It has a winding configuration of Grounded Wye (HV) – Delta (TV) – Grounded Wye (LV). An X/R ratio of 39.53 was specified for this unit.

- 6.2. The generator step-up transformers were modelled as an equivalent transformer based on 18 (eighteen) 34.5 kV - 0.72 kV 7.5 MVA transformers, with a 10.6% positive sequence impedance and 10.3% zero sequence impedance and a specified X/R ratio of 11.77. The winding configuration is given as Delta (HV) – Grounded Wye (LV).
7. Equivalent 34.5 kV collector circuit impedance (positive and zero sequence) was modelled based on information provided by the IC.
8. The FEAS analysis is based on the assumption that IRs higher in the Generation Interconnection Queue and OATT Transmission Service Queue that have a completed System Impact Study or that have a System Impact Study in progress will proceed, as listed in Section 4.0: Project Queue Position.
9. It is the IC’s responsibility that the new facility will meet all requirements of NSPI’s GIP and NSPI’s Transmission System Interconnection Requirements.
10. Ratings of transmission lines into the 120H-Brushy Hill substation are:

NSPI Transmission Line Ratings														Last Updated: 2021-08-27	
LINE	STATION	CONDUCTOR	Type	Maximum Operating Temp. (Celsius)	SUMMER RATING 25 DEG (MVA)	WINTER RATING 5 DEG (MVA)	BREAKER 100% Name-plate	SWITCH 100% Name-plate	CURRENT TRANSFORMER			FULL SCALE METERING			TRIP MVA
									Ratio	R.F.	MVA	Ratio	R.F.	MVA	
L-6005	120H Brushy Hill	ACSR 795 Drake	100	268	304	478	478	800	2	382	1200	1	346	1762	
	90H Sackville														287
L-6010	120H Brushy Hill	ACSR 795 Drake	100	268	304	478	478	800	2	382	1200	1	346	1708	
	90H Sackville														287
L-6011	120H Brushy Hill	ACSR 556.5 Dove	100	215	242	478	478	800	2	382	800	1	231	670	
	17V St. Croix														287
L-6016	120H Brushy Hill	ACSR 1113 Beaumont	70	242	301	478	478	800	2	382	1200	1	346	1323	
	103H Lakeside														287
L-6051	120H Brushy Hill	ACSR 795 Drake	100	268	304	478	478	800	2	382	800	1	231	865	
	17V St. Croix														287

L-7001	67N Onslow EHV	ACSR 795 Drake	60	298	383	797	797	500	2	398	1000	1	462	533
	120H Brushy Hill					797	797	800	2	637	1200	1	554	1065
L-7002	67N Onslow EHV	ACSR 795 Drake	100	447	506	797	797	800	2	637	1000	1	462	1065
	120H Brushy Hill					797	797	800	2	637	1200	1	577	1065
L-7008	120H Brushy Hill	ACSR 1113 Beaumont	70	404	502	797	797	800	2	478	1200	1	554	1235
	99W Bridgewater EHV					797	797	500	2	398	1000	1	462	1235
L-7009	120H Brushy Hill	ACSR 795 Drake	50	223	340	797	797	800	2	637	1200	1	577	901
	99W Bridgewater EHV					996	797	500	2	398	1200	1	577	751
L-7018	67N Onslow EHV	ACSR 2x795 Drake /AACSR 2156	60	506	675	797	797	800	2	637	800	1.25	462	1441
	120H Brushy Hill					797	797	800	2	637	1000	1	462	1441

Table 1: Transmission line ratings

4.0 Project Queue Position

All in-service generation is included in this FEAS. As of October 15, 2021, the following projects are higher queued in the Advanced Stage Interconnection Request Queue and are included in this study's base cases. Figure 3 shows the GIP queue which applies to all Rate Base RFP (Request For Proposal) feasibility studies currently underway.

Combined T/D Advanced Stage Interconnection Request Queue													
Publish Date: Friday, October 15, 2021													
Queue Order*	IR #	Request Date DD-MMM-YY	County	MW Summer	MW Winter	Interconnection Point Requested	Type	Inservice date DD-MMM-YY	Revised Inservice date	Status	Service Type	IC Identity	
1	-T	426	27-Jul-12	Richmond	45	45	47C	Biomass	01-Jan-17	01/09/2018	GIA Executed	NRIS	N/A
2	-T	516	05-Dec-14	Cumberland	5	5	37N	Tidal	01-Jul-16	31/05/2020	GIA Executed	NRIS	N/A
3	-T	540	28-Jul-16	Hants	14.1	14.1	17V	Wind	01-Jan-18	31/10/2023	GIA Executed	NRIS	N/A
4	-T	542	26-Sep-16	Cumberland	3.78	3.78	37N	Tidal	01-Jan-19	01/11/2021	GIA Executed	NRIS	N/A
5	-D	557	19-Apr-17	Halifax	5.6	5.6	24H	CHP	01-Sep-18		SIS Complete	N/A	N/A
6	-D	569	26-Jul-19	Digby	0.6	0.6	509V-302	Tidal	01-Mar-21	30/07/2021	GIA Executed	N/A	N/A
7	-D	568	21-May-19	Cumberland	2	2	22N-404	Solar	01-Sep-20	01/09/2021	GIA Executed	N/A	N/A
8	-D	566	16-Jan-19	Digby	0.7	0.7	509V-301	Tidal	31-Jul-19	29/01/2021	GIA Executed	N/A	N/A
9	-T	574	27-Aug-20	Hants	58.8	58.8	L-6051	Wind	30-Jun-23		FAC Complete	NRIS	N/A
10	-D	595	11-Mar-21	Halifax	0.1	0.1	1H-454	Battery	11-Jan-21		SIS Complete	N/A	N/A
11	-T	598	13-May-21	Cumberland	2.52	2.52	37N	Tidal	01-Dec-22		SIS in Progress	NRIS	N/A
12	-D	604	07-Jun-21	Cape Breton	0.45	0.45	11S-303	Solar	15-Jan-22		SIS in Progress	N/A	N/A
13	-D	603	31-May-21	Cumberland	0.4	0.4	22N-404	Solar/Battery	16-Feb-22		SIS in Progress	N/A	N/A
14	-D	600	27-May-21	Halifax	0.6	0.6	99H-312	Solar/Battery	02-Mar-22		SIS in Progress	N/A	N/A
Totals:				139.65	139.65								

Figure 3: GIP Queue

The following projects in Figure 4 below are included in the Transmission Service Request (TSR) Queue as of January 22, 2022:

OATT Transmission Service Queued System Impact Studies Active January 22, 2022							
Item	Project	Date & Time of Service Request	Project Type	Project Location	Requested In-Service Date	Project Size (MW)	Status
1	TSR 400	July 22, 2011	Point-to-point	NS-NB*	May 2019	330	System Upgrades in Progress
2	TSR 411	January 19, 2021	Point-to-point	NS-NB*	January 1, 2025	550	SIS in Progress
3	TSR 412	January 19, 2021	Point-to-point	Woodbine - NS	January 1, 2025	500	Withdrawn

*Indicates project as being located near provincial border.

Figure 4: TSR Queue

Regarding TSR 411, it is expected to be in service in 2025 and system studies are currently underway to determine the required upgrades to the Nova Scotia transmission system. As a result, the following notice has been posted to the OASIS site³:

³ OASIS Generation Interconnection Procedures; <https://www.nspower.ca/oasis/generation-interconnection-procedures>

Effective January 19th, 2021, please be advised that the completion of advanced-stage Interconnection Studies under the Standard Generator Interconnection Procedures (GIP) may be delayed pending the outcome of the Transmission Service Request (TSR) 411 System Impact Study, which is expected to identify significant changes to the NSPI transmission system. The revised expected completion date for the study is February 28, 2022. Feasibility Studies initiated prior to the completion of the TSR System Impact Study will be performed based on the current system configuration.

5.0 Short Circuit

IR640 will not impact 120H-Brushy Hill and neighbouring breaker's interrupting capability based on this study's short circuit analysis. Analysis was performed using PSS/e 34.8, classical fault study, flat voltage profile at 1.0 PU voltage, LG, and 3LG faults.

The interrupting capability of the neighbouring 138 kV circuit breakers is at least 5000 MVA. Short circuit levels with and without IR640 are provided in Tables 2 and 3.

Table 2: Maximum Short circuit levels in MVA

Maximum Generation: All Generation On, All Transmission Lines In Service					
IR 640	Measured Bus	Three Phase MVA	X/R	Single Phase MVA	X/R
On	120H-Brushy Hill 138kV Bus 199201	3625	13.5	4214	11.8
	IR 640 34.5kV Bus 199747	771	9.0	711	9.0
Off	120H-Brushy Hill 138kV Bus 199201	3527	13.3	4126	11.8
	IR 640 34.5kV Bus 199747	661	7.8	645	9.0

Table 3: Minimum Short circuit levels in MVA

Minimum Generation: PA, ML, LG1, TR6 On, All Transmission Lines In Service					
IR 640	Measured Bus	Three Phase MVA	X/R	Single Phase MVA	X/R
On	120H-Brushy Hill 138kV Bus 199201	1934	17.4	2475	11.8
	IR 640 34.5kV Bus 199747	674	10.2	652	9.0
Off	120H-Brushy Hill 138kV Bus 199201	1837	16.9	2364	11.8
	IR 640 34.5kV Bus 199747	564	8.7	578	9.0
Minimum Generation: PA, ML, LG1, TR6 On, L6005 Out Of Service					
On	120H-Brushy Hill 138kV Bus 199201	1895	17.3	2423	12.8
	IR 640 34.5kV Bus 199747	670	10.2	649	9.0
Off	120H-Brushy Hill 138kV Bus 199201	1798	16.8	2313	12.8
	IR 640 34.5kV Bus 199747	560	8.7	575	9.0

Further short circuit analysis will be performed in the SIS and will also examine Short Circuit Ratio (SCR) under minimum short circuit level conditions.

6.0 Voltage Flicker & Harmonics

Voltage flicker will be examined when data is made available for the SIS, as the information was not provided at the time of this study. A summary of NS Power's voltage flicker requirements is listed in Table 4: Flicker requirements.

Table 4: Flicker requirements

	P_{st}	P_{lt}
NS Power's requirements	≤ 0.25	≤ 0.35

The WTG facility must meet IEEE Standard 519-2014 limiting voltage Total Harmonic Distortion (*all frequencies*) to no higher than 1.5% with no individual harmonic exceeding 1.5% on 138 kV.

7.0 Load Flow Analysis

Power flow analysis was performed for generation dispatches under system light load, summer peak load, and winter peak load conditions. Dispatch was selected to represent import and export scenarios with New Brunswick for various flows associated with the existing Maritime Link transmission service reservation. These include exports to NB of up to 330 MW between March 1st and November 30th, and exports of 150MW to NB for the period from December 1st to February 28th. These represent flows under normal system conditions. In the event of a contingency in New Brunswick, NSPI must provide an additional 168 MW of supply. As well, in the event of a contingency in Nova Scotia, New Brunswick is obligated to provide up to 142.5 MW of generation to NS.

IR640 is located to the north of Halifax, connected via 138 kV bus at 120H-Brushy Hill substation. IR640 is most notably impacted by the Onslow South (ONS) corridor which defines the interface flows into the load centre in Halifax via Truro. The ONS corridor includes line L8002, L7001, L7002, L7018, and L6001.




Figure 5: NSPI Major Interfaces

7.1 Base Cases:

The base cases used in this study are shown in Table 5: Base Case Dispatch. For these cases:

- Transmission connected wind generation facilities were dispatched between 22% and 100% of their rated capability.
- All interface limits were respected for base case scenarios.

Two scenarios were examined for each of the Spring Light Load (SLL), Summer Peak (SUM), and Winter Peak (WIN) cases:

- IR640 off (i.e., SUM_00).
- IR640 generating at full output with NRIS designation (i.e., SUM_00-N).

Table 5: Base Case Dispatch

Case name	NS load	Wind	NS/NB	NS/NL	Cape Breton Export	Onslow Import	Onslow South	Mainland at Hastings	Hastings from
SLL_00-N	854	467	331	-330	137	241	-87	30	163
SLL_00	870	367	331	-330	245	347	19	82	222
SLL_01-N	854	345	0	-165	-45	30	7	-45	95
SLL_01	854	245	0	-165	7	104	86	-9	83
SUM_00-N	1443	590	332	-475	612	670	299	293	330
SUM_00	1443	490	332	-475	708	762	392	346	384
SUM_01-N	1443	430	-98	-330	401	429	465	200	240
SUM_01	1443	330	-99	-330	457	484	521	230	272
SUM_02-N	1452	430	332	-475	792	891	495	413	376
SUM_02	1452	330	332	-475	929	1020	624	488	453
WIN_00-N	2211	590	147	-320	652	807	552	372	260
WIN_00	2211	490	154	-320	651	886	624	375	263
WIN_01-N	2211	210	0	-320	876	931	763	500	408
WIN_01	2211	110	0	-320	875	1010	842	503	411
WIN_02-N	2206	590	331	-320	909	1092	651	506	399
WIN_02	2206	490	332	-320	986	1164	724	549	443

Note 1: All values are in MW.

Note 2: CBX (Cape Breton Export) and ONI (Onslow Import) are IROL (Interconnection Reliability Operating Limit) defined interfaces.

Note 3: Wind refers to transmission connected wind only.

7.2 Load Flow Contingencies:

All load flow contingencies must meet the following post contingency requirements:

- All system elements must be within 110% of their thermally limited ratings (assuming system operator action can resolve the overload in < 10 minutes)
- Steady state bus voltage must remain within 90% - 110% of nominal voltage following correction by automatic tap changers.
- Any Pre/Post contingency voltage change at buses must be < 10% prior to tap changer action

The studied contingencies must include breaker failure, which can impact multiple system elements.

7.3 Load Flow Results:

The results for the load flow analysis were acceptable with no criteria violations in any of the dispatch cases considered.

In summary, the steady state contingencies evaluated in this study demonstrate that IR640 does not require Network Upgrades beyond the POI to operate at its full source capacity of 100 MW under NRIS.

8.0 Voltage Control

IR640 will meet NS Power's ± 0.95 net power factor requirement at the HV terminals of the ICIF substation.

Using the Vestas reactive power capability, shown in Figure 6: *Vestas V162 6.2 MW reactive power capability*, various levels were calculated and are displayed in Table 6: *Power factor analysis results*.




Figure 6: Vestas V162 6.2 MW reactive power capability⁴

The Vestas technical bulletin's reactive power capability, shown above in Figure 6, shows that the reactive power capability is slightly reduced as real power output reaches its max (regions A-B, and C-D).

⁴ Vestas Performance Specification EnVentus V162-6.2 MW, Document no: 0107-3707 V00, 2021/06/30

Breakpoints B and C are applicable only when the site is producing/ absorbing maximum VARs while operating at its max real power output. Because the IR640 site will be restricted to 100 MW output (from a capacity of 111.6 MW), breakpoints A and D are the only relevant operating points. As seen in Table 6 below, IR640 meets NS Power's ±0.95 net power factor requirement at breakpoints A and D on the Vestas reactive capability curve.

Table 6: Power factor analysis results (@ 1.0 VPU)

Breakpoints on Vestas reactive capability curve	IR640 rated output (18 x 6.2MW WTG units)				Measurements at the HV terminals of the ICIF substation				Meets net 0.95 pf requirement?
	MW	MVAR	MVA	pf	MW	MVAR	MVA	pf	
A	100.80	63.23	118.99	0.847	98.51	42.44	107.26	0.918	Yes
D	100.80	-54.56	114.62	0.879	98.36	-80.87	127.34	0.772	Yes

The net power factor will be re-evaluated when final information on the transformers and collector circuit is provided in the SIS stage.

A centralized controller will be required, which continuously adjusts the individual generator reactive power output within the plant capability limits and regulates the voltage at the low voltage terminal of the ICIF transformer. The voltage controls must be responsive to voltage deviations, be equipped with a voltage setpoint control, and have facilities that will slowly adjust the setpoint over several (5-10) minutes to maintain reactive power within the individual generators' capabilities. Details of the specific control features, control strategy, and settings will be reviewed and addressed in the SIS.

The NSPI System Operator must have manual and remote control of the voltage setpoint and the reactive setpoint of this facility to coordinate reactive power dispatch requirements.




Figure 7: NERC PRC-024-2 Attachment 2

This facility must have voltage ride-through capability as detailed in Figure 7 above and in the NS Power Transmission System Interconnection Requirements (TSIR)⁵. The SIS will examine the plant capabilities and controls in detail to specify options, controls, and additional facilities that are required to achieve low voltage ride-through.

9.0 System Security

Transmission System Elements will be required to meet NPCC⁶ Bulk Power System (BPS) and NERC⁷ Bulk Electric System (BES) requirements.

Table 7 summarizes the BPS/BES status of neighbouring system elements:

Table 7: BPS & BES classification of neighbouring elements

Neighbouring element classification	NPCC BPS	NERC BES
120H 138 kV Bus	Yes	Yes
L6005	Yes	Yes
L6010	Yes	Yes
L6011	Yes	Yes
L6016	Yes	Yes
L6051	Yes	Yes

NPCC BPS criteria is performance based, and currently the 138 kV bus at 120H-Brushy Hill is designated NPCC BPS. As such, all protection systems associated with the new 138kV breaker supplying the radial line to IR640 must comply with NPCC Directory 4 *System Protection Criteria*.

NERC BES criteria uses a bright line approach for expected facilities required for interconnection. As IR640 has dispersed generation totalling more than 75 MVA, Inclusion I4 of the NERC BES Definition would apply, and each generator would be classified as a BES element. As well, the IR640 138 kV bus and 34.5 kV bus, 138–34.5 kV interconnection transformer, and 138 kV tap line would be classified as BES elements.

There is the potential for an exclusion from BES to be granted for the high side (138kV) bus based on further analysis per the NS BES Exception Procedure. This analysis will be initiated as part of the System Impact Study (SIS) and exclusion from BES will only be granted upon subsequent approval by the NS Utility and Review Board (UARB).

⁵ NS Power Transmission System Interconnection Requirements; <https://www.nspower.ca/oasis/standards-codes>

⁶ Northeastern Power Coordination Council.

⁷ North American Electric Reliability Corporation.

10.0 Expected Facilities Required for Interconnection

The following facilities are required to interconnect IR640 to the NSPI system via the 138 kV bus at 120H-Brushy Hill as NRIS. Note that the requirements for ERIS are identical for this IR.

1) Network Upgrades:

- a) P&C modifications at 120H-Brushy Hill substation.
- b) A 138 kV breaker, associated switches, and substation modifications at 120H-Brushy Hill.

2) Transmission Provider's Interconnection Facilities (TPIF):

- a) A 138 kV transmission line (~5 km) built to NSPI standards from 120H-Brushy Hill 138 kV bus to the IR640 substation.
- b) Control and communications between the ICIF and the NSPI SCADA and protection system.

2) Interconnection Customer's Interconnection Facilities (ICIF):

- a) Centralized controls for voltage setpoint control for the low side of the ICIF transformer. Fast acting control is required and will include a curtailment scheme, which will limit/reduce total output from the facility, upon receipt of a telemetered signal from NSPI's SCADA system.
- b) NSPI to have supervisory and control of this facility, via the centralized controller. This will permit the NSPI System Operator to raise/lower the voltage setpoint, change the status of reactive power controls, change the real/reactive power remotely. NSPI will also have remote manual control of the curtailment scheme.
- c) When not at full output, the facility shall offer over-frequency and under-frequency control with a deadband of ± 0.2 Hz and a droop characteristic of 4%. The active power controls shall also have the capability to react to continuous control signals from the NSPI SCADA system's Automatic Generation Control (AGC) system to control tie-line fluctuations as required.
- d) Real-time telemetry will include MW, MVAR, bus voltages, curtailment state, wind speed, and wind direction.
- e) Nominal voltage and frequency operation as specified in the NS Power Transmission System Interconnection Requirements (*TSIR*) Section 7.2.
- f) Voltage and frequency ride-through capability as detailed in NS Power Transmission System Interconnection Requirements (*TSIR*) Sections 7.4.1 and 7.4.2.
- g) Facilities for NSPI to execute high speed rejection of generation (transfer trip), if determined in the SIS. The plant may be incorporated in SPS runback schemes.

- h) The facility must use equipment capable of closing a circuit breaker with minimal transient impact on system voltage and frequency (*matching voltage within ± 0.05 PU and a phase angle within $\pm 15^\circ$*).
- i) Operation at ambient temperatures as low as -30°C .

11.0 NSPI Interconnection Facilities and Network Upgrades Cost Estimate

The present high level, non-binding, cost estimate, excluding HST, for IR640's Network Resource Interconnection Service is shown in the following table. Note that the requirements for Energy Resource Interconnection Service are identical for this IR. This estimate assumes there is adequate space for new equipment and modifications. This does not include any costs yet to be determined by the SIS.

Table 8: Cost estimate

Determined Cost Items		Estimate
NSPI Interconnection Facilities		
i.	Transmission line from 120H to IR640 substation (~5 km)	\$ 2,500,000
ii.	Protection & control relaying equipment + NSPI RTU	\$ 160,000
iii.	Teleprotection & SCADA communications	\$ 150,000
	Subtotal:	\$ 2,810,000
Network Upgrades		
iv.	138kV breaker, switches, terminal at 120H-Brushy Hill	\$ 1,700,000
v.	Protection modifications	\$ 200,000
	Subtotal:	\$ 1,900,000
Totals		
vi.	Subtotal:	\$ 4,710,000
vii.	Contingency (10%)	\$ 471,000
viii.	Total of Determined Cost Items	\$ 5,181,000
To Be Determined Cost Items		
ix.	System additions to address potential stability limits	TBD (SIS)

The estimated time to construct the Network Upgrades and Transmission Provider's Interconnection Facilities is 18-24 months after receipt of funds.

Note that the proposed transmission corridor requires more detailed design work that is not in scope for this FEAS. Below are a few highlighted issues that could significantly impact the estimate for this project:

- The requirement for easements and structure relocations for the new transmission line to the ICIF.
- Issues with implementation may be discovered at the 120H-Brushy Hill substation. No major issues were found in this preliminary review, however, detailed design could potentially find issues resulting in increased scope.

12.0 Loss Factor

Loss factor is calculated by running the winter peak load flow case with and without the new facility in service, while keeping 91H-Tufts Cove as the NS Area Interchange bus. This methodology reflects the load centre in and around 91H-Tufts Cove. A negative loss factor reflects a reduction in system losses.

With IR640 in service at full output, the loss factor is calculated as 0.5%.

Table 9: Loss factor

Parameter	Generation (MW)
IR640	100.0
TC3 w/ IR640	68.7
TC3 w/o IR640	168.2
Delta	0.5
2025 loss factor	0.5%

13.0 Preliminary Scope of Subsequent SIS

The SIS will be conducted in accordance with the GIP with the assumption that all appropriate higher-queued projects will proceed, and the facilities associated with those projects are installed. It will provide a more comprehensive assessment, based on NSPI, NPCC, and NERC criteria, of the technical issues and requirements to interconnect the proposed facility as requested.

The assessment will consider, but not be limited to, the following:

- Contingency analysis for both steady state and system stability.
- Ride-through and operation following a contingency (n-1 operation).
- The minimum transmission and substation additions/upgrades that are necessary to permit operation of this generating facility, under all dispatch conditions, catering to, at a minimum, the first contingencies listed below.
- Options and ancillary equipment that the customer must install to control flicker, voltage and ensure that the required ride-through capability.
- Identify guidelines and restrictions applicable following a first contingency (curtailments, etc.).
- Loss Factor.
- Determination of BPS designation.
- Changes to SPS schemes required for operation of this generating facility
- Under-frequency load shedding.
- Facilities that the customer must install to meet the requirements of the GIP.

Parameters for a generic model must be supplied for transient analysis in PSS/e.

The SIS will determine the facilities required to operate this facility at full capacity, withstand the contingencies as defined by NPCC/NERC and identify any restrictions that must be placed on the system following a first contingency loss. The SIS will be conducted

with the assumption that all projects higher queued will proceed and the facilities associated with those projects are installed.

Any changes to SPS schemes required for operation of this generating facility, in addition to existing generation and facilities that can proceed before this project, will be determined by the SIS as well as any required additional transmission facilities. The determination will be based on NERC⁸ and NPCC⁹ criteria as well as NSPI guidelines and good utility practice. The SIS will also determine the contingencies for which this facility must be curtailed.

A thorough assessment will be provided to ensure that the facilities will meet applicable NSPI, NPCC and NERC transmission design criteria.

Additionally, electromagnetic transient (EMT) study may be required to account for IR640 control system to coordinate with other facilities in the transmission system and to ensure fault ride through.

Nova Scotia Power
Transmission System Operations
2022-03-16

⁸ NPCC Directory #1: *Design and Operation of the Bulk Power System*

⁹ NERC Reliability Standard TPL-001-4: *Transmission Operations*