



Interconnection Feasibility Study Report
GIP-IR601-FEAS-REV0

Generator Interconnection Request IR601
60 MW Wind Generating Facility
Location Westchester Station, Cumberland County, NS

2021-08-31

Control Centre Operations
Nova Scotia Power Inc.

Executive Summary

The Interconnection Customer (IC) submitted an Interconnection Request (IR601) for Network Resource Interconnection Service (NRIS) for a proposed 60 MW wind generation facility interconnected to NSPI transmission system, with a Commercial Operation Date of December 31, 2023. The Point of Interconnection (POI) requested by the customer is line L-6613 section between 81N-Debert and 74N-Springhill. The generation will consist of ten 6.0 MW, Vestas V162 generators.

This feasibility assessment is conducted with IR601 generation to be used in NS and not for exporting outside NS. The assessment is completed based on NSPI's Generator Interconnection Procedure.

Based on the information provided by the IC, this feasibility assessment provides the following findings:

- In general, IR601 rated output does not violate thermal or voltage criteria. However, when it displaces Halifax generation in winter peak, the Metro Dynamic Reactive Reserves can be marginally exceeded and 120H-T71 or 120H-T72 transformer at Brushy Hill substation can marginally exceed their nominal ratings under certain N-1 contingencies. At this time, this assessment considers them marginal and no associated system upgrades are identified.
- IR601 voltage flicker and harmonic levels will be studied in SIS as the information is not provided.
- IR601 will require power factor correction or mitigation measure to meet NSPI's power factor requirement when it delivers reactive power to the power system.
- The minimum Short Circuit Ratio (SCR) at 34.5 kV bus is 3.2, less than 5, hence it needs to be discussed with Vestas to properly design the wind turbines.
- The estimated loss factor for IR601 is 8% at rated output.
- The high level cost estimate, in 2021 Canadian dollars, for IR601 connection is \$7,881,500 which includes 10% contingency and excludes HST.

IR601 will require to meet NSPI's Generator Interconnection Procedure (GIP) and Transmission System Interconnection Requirements (TSIR).

This assessment is a feasibility study and is further subjected to the subsequent SIS and Facility Study which will determine any further system requirements and upgrades for IR601.

Table of Contents

| | |
|---|-----|
| Executive Summary | ii |
| Table of Contents | iii |
| 1.0 Introduction..... | 1 |
| 2.0 Scope | 3 |
| 3.0 Assumptions | 4 |
| 3.1 System Assumptions | 4 |
| 3.2 Project Assumptions | 4 |
| 4.0 Projects with Higher Queue Positions | 5 |
| 5.0 Short-Circuit Duty / Short Circuit Ratio | 7 |
| 6.0 Voltage Flicker and Harmonics | 9 |
| 7.0 Thermal Limits | 9 |
| 7.1 NS Load Forecast | 9 |
| 7.2 IR601 Model..... | 9 |
| 7.3 IR601 Steady State Analysis Result | 10 |
| 8.0 Voltage Limits | 14 |
| 9.0 System Security / Bulk Power Analysis..... | 16 |
| 10.0 Loss Factor..... | 16 |
| 11.0 Expected Facilities Required for Interconnection | 16 |
| 12.0 Facilities and Network Upgrades Cost Estimate | 18 |
| 13.0 Preliminary Scope of the SIS | 18 |

List of Tables

| | |
|--|----|
| Table 1: Maximum generation short circuit level system normal | 8 |
| Table 2: Minimum generation short circuit level system normal | 8 |
| Table 3: Minimum generation short circuit level with L-6613 out..... | 8 |
| Table 4: Power system cases..... | 12 |
| Table 5: Contingencies in NS and NB studied | 14 |
| Table 6: Power factor with Qmax..... | 15 |
| Table 7: Power factor with Qmin..... | 15 |
| Table 10: Loss factor..... | 16 |
| Table 9: Cost estimates..... | 18 |

List of Figures

| | |
|--|----|
| Figure 1: Westchester Mountain..... | 2 |
| Figure 2 Point of Interconnection (not to scale) | 3 |
| Figure 3: GIP Queue | 6 |
| Figure 4: TSR Queue | 7 |
| Figure 5 Power Factor with Qmax | 15 |
| Figure 6 Power Factor with Qmin | 15 |

The POI on L-6613 is about 34.6 km from 1N-Onslow substation.

The Point of Change of ownership (POC) will be at the 138 kV side of the IC's 138 kV to 34.5 kV substation which is at POI on L-6613.




Figure 1: Westchester Mountain




Figure 2 Point of Interconnection (not to scale)

2.0 Scope

The objective of this Interconnection Feasibility Study (FEAS) is to provide a preliminary evaluation of system impacts from interconnecting the proposed generation facility to the NSPI transmission system at the requested location. The assessment will identify potential impacts on transmission element loading, which must remain within their thermal limits. Any potential violations of voltage criteria will be identified and addressed. If the proposed generation increases the short-circuit duty of any circuit breakers beyond their rated capacity, the circuit breakers must be upgraded.

The scope of the FEAS includes the modelling of the power system in normal state (with all transmission elements in service) under anticipated load and generation dispatch conditions. A power flow and short circuit analysis will be performed to provide the following information:

- Preliminary identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection, and any network upgrades necessary to address the short circuit issues associated with the IR.
- Preliminary identification of any thermal overload or voltage limit violations resulting from the interconnection and identification of the necessary network upgrades to allow full output of the proposed facility.
- Preliminary description and high-level non-binding estimated cost to construct the facilities required to interconnect the generating facility to the transmission system.

This FEAS is based on a power flow and short circuit analysis and does not include a complete determination of facility changes/additions required to increase the system transfer capabilities that may be required to meet the design and operating criteria established by NSPI, the Northeast Power Coordinating Council (NPCC), and the North American Electric Reliability Corporation (NERC). These requirements will be determined by a more detailed analysis in the subsequent interconnection System Impact Study (SIS). An Interconnection Facilities Study (FAC) follows the SIS to ascertain the final cost estimate to interconnect the generating facility.

Applicable planning criteria as approved for use in Nova Scotia by the Utility and Review Board, are used in evaluation of the impact of any facility on the Bulk Electric System.

3.0 Assumptions

3.1 System Assumptions

As mentioned in section 4.0 Projects with Higher Queue Positions, TSR411 and TSR412 are not included in this feasibility assessment of IR601.

The power flow cases used for this feasibility assessment contain only transmission connected generating facilities.

The feasibility assessment of IR601 in this report is based on IR601 output being used as network resource in Nova Scotia and not for exporting outside Nova Scotia.

3.2 Project Assumptions


This FEAS is based on the technical information provided by the Interconnection Customer. The Point of Interconnection (POI) and configuration studied are as follows:

1. Network Resource Interconnection Service (NRIS) type per the Generator Interconnection procedures (GIP). The IR601 generation is for used in NS and not for export outside NS.
2. Commercial Operation Date of December 31, 2023
3. The Interconnection Facility is modelled based on the information provided by the IC as per section 1.0 Introduction.
4. The POI on L-6613 will be modelled at 34.6 km from 1N-Onslow substation. The IC has indicated on their system one-line diagram that the Interconnection Facility will be connected to L-6613 at the POI, hence there is no 138 kV spur line between the POI and the IC substation.
5. The generation technology used must meet NSPI requirements for reactive power capability of at least 0.95 capacitive to 0.95 inductive at the HV terminals of the IC Substation Step Up transformer. It is also required to have high-speed Automatic Voltage Regulation to maintain constant voltage at the designated voltage control point during and following system disturbances as determined in the subsequent System Impact Study. The designated voltage control point will either be the low voltage terminals of the wind farm transformer, or if the high voltage terminals are used, equipped with droop compensation controls. It is assumed that the generating units are not de-rated in their MW capability when delivering the required reactive power to the system.
6. The IC's provided one-line, 3-150-01-001-Layout1.pdf, is used to estimate the equivalent impedances for the collector circuits. Some portions of the circuits reference #755 kcmil ACSR conductors but the IC has confirmed that they are #795 kcmil ACSR, Drake, conductors.
7. The FEAS analysis is based on the assumption that IR's higher in the Generation Interconnection Queue and OATT Transmission Service Queue that have completed a System Impact Study, or that have a System Impact Study in progress will proceed, as listed in Section 4 below, with the exception of TSR411 and TSR412 as discussed earlier in the report.
8. It is required that the wind turbines are equipped with a "cold weather option" suitable for delivering full power under expected Nova Scotia winter environmental conditions.
9. It is the IC's responsibility that the new facility will meet all requirements of NSPI's GIP and NSPI's Transmission System Interconnection Requirements.

4.0 Projects with Higher Queue Positions

All in-service generation is included in the FEAS.

Figure 3 shows the GIP queue, link https://www.nspower.ca/docs/default-source/pdf-to-upload/nspi-combined-interconnection-request-queue.pdf?sfvrsn=d112e57b_9, at the time of this assessment.

| Combined T/D Advanced Stage Interconnection Request Queue | | | | | | | | | | | |  Nova Scotia POWER An Emera Company | |
|---|--------|------------------------|------------|-----------|-----------|---------------------------------|---------|--------------------------|------------------------|-----------------|--------------|--|--|
| Publish Date: Friday, June 18, 2021 | | | | | | | | | | | | | |
| Queue Order* | IR # | Request Date DD-MMM-YY | County | MW Summer | MW Winter | Interconnection Point Requested | Type | Inservice date DD-MMM-YY | Revised Inservice date | Status | Service Type | IC Identity | |
| 1 | -T 426 | 27-Jul-12 | Richmond | 45 | 45 | 47C | Biomass | 01-Jan-17 | 01/09/2018 | GIA Executed | NRIS | N/A | |
| 2 | -T 516 | 05-Dec-14 | Cumberland | 5 | 5 | 37N | Tidal | 01-Jul-16 | 31/05/2020 | GIA Executed | NRIS | N/A | |
| 3 | -T 540 | 28-Jul-16 | Hants | 14.1 | 14.1 | 17V | Wind | 01-Jan-18 | 31/10/2023 | GIA Executed | NRIS | N/A | |
| 4 | -T 542 | 26-Sep-16 | Cumberland | 3.78 | 3.78 | 37N | Tidal | 01-Jan-19 | 01/11/2021 | GIA Executed | NRIS | N/A | |
| 5 | -D 557 | 19-Apr-17 | Halifax | 5.6 | 5.6 | 24H | CHP | 01-Sep-18 | | SIS Complete | N/A | N/A | |
| 6 | -D 569 | 26-Jul-19 | Digby | 0.6 | 0.6 | 509V-302 | Tidal | 01-Mar-21 | 30/07/2021 | GIA Executed | N/A | N/A | |
| 7 | -D 568 | 21-May-19 | Cumberland | 2 | 2 | 22N-404 | Solar | 01-Sep-20 | 01/09/2021 | GIA Executed | N/A | N/A | |
| 8 | -D 566 | 16-Jan-19 | Digby | 0.7 | 0.7 | 509V-301 | Tidal | 31-Jul-19 | 29/01/2021 | GIA Executed | N/A | N/A | |
| 9 | -T 574 | 27-Aug-20 | Hants | 58.8 | 58.8 | L-6051 | Wind | 30-Jun-23 | | FAC in Progress | NRIS | N/A | |

Nova Scotia Power - Interconnection Request Queue: Page 1 of 2

ERIS - Energy Resource Interconnection Service
 NRIS - Network Resource Interconnection Service
 N/A - Not Applicable

T - Transmission Interconnection Request
 D - Distribution Interconnection Request

* Note: Queue reflects current list of IR's which have established an advanced queue position per GIP/DGIP Section 4.1

Figure 3: GIP Queue

The following projects are higher queued in the Advanced Stage Interconnection Request Queue and are committed to the study base cases:

- IR426: GIA executed
- IR516: GIA executed
- IR540: GIA executed
- IR542: GIA executed
- IR557: SIS complete
- IR569: GIA executed
- IR568: GIA executed
- IR566: GIA executed
- IR574: FAC in Progress

Figure 4 shows the Transmission Service Request (TSR) queue, link https://www.nspower.ca/docs/default-source/test/transmission-service-studies-feb-18-2020.pdf?sfvrsn=5a5228ea_2, at the time of this assessment.

| OATT Transmission Service Queued System Impact Studies Active June 15, 2021 | | | | | | |
|---|--------------------------------|----------------|------------------|---------------------------|-------------------|-----------------------------|
| Project | Date & Time of Service Request | Project Type | Project Location | Requested In-Service Date | Project size (MW) | Status |
| TSR 400 | July 22, 2011 | Point to Point | NS-NB | May 2019 | 330 | System Upgrades in Progress |
| TSR 411 | January 19, 2021 | Point to Point | NB-NS | Jan 1, 2025 | 800 | SIS In Progress |
| TSR 412 | January 19, 2021 | Point to Point | Woodbine-NS | Jan 1, 2025 | 500 | SIS In Progress |
| TSR 413 | April 14, 2021 | Network | Antigonish NS | Jan 1, 2022 | 8.792 | Accepted Application |

Figure 4: TSR Queue

TSR400 has a firm export from NS to NB of 150 MW in winter and 330 MW in summer. This is a “through NS” export from NL via the Maritime Link (ML) HVDC to the NS and NB border, and NS does not carry the operating reserve for it. The sink entity will be responsible for that reserve. Loss of ML HVDC under this condition, NS will cut the 150 MW or 330 MW “through NS” export.

Regarding TSR411 and TSR412, they are expected to be in service in 2025 and system studies are currently underway to determine the required upgrades to the Nova Scotia transmission system. As a result, the following notice has been posted to the OASIS site at <https://www.nspower.ca/oasis/generation-interconnection-procedures>:

Effective January 19th, 2021, please be advised that the completion of advanced-stage Interconnection Studies under the Standard Generator Interconnection Procedures (GIP) may be delayed pending the outcome of the Transmission Service Request (TSR) 411 and 412 System Impact Studies, which are expected to identify significant changes to the NSPI transmission system. The expected completion date for these studies is December 31, 2021. Feasibility Studies initiated prior to the completion of these TSR System Impact Studies will be performed based on the current system configuration.

5.0 Short-Circuit Duty / Short Circuit Ratio

The maximum (design) expected short-circuit level is 5,000 MVA on 138 kV systems.

Short circuit analysis is based on ASPEN One-Liner v14.4 short circuit case that is maintained and updated by NSPI system protection department for short circuit calculations. The case is imported into PSSE version 33.12.1 and the short circuit analysis is performed in PSSE with higher queued projects and IR601 added to the PSSE models.

The bulletin, General Description EnVentus.pdf, provided by IC, on the short circuit capability is used for this assessment.

The short circuit calculations are based on three-phase-fault and flat voltage profile at one per unit voltage.

Minimum generation has only the Maritime Link, Point Aconi, Lingan 1, and Trenton 6 in NS in service under the present system operating requirements. In NB, only the nuclear plant Point Lepreau and the large coal plant Belledune in service.

Table 1 shows maximum and minimum short circuit levels at 1N-Onslow, 74N-Springhill, 81N-Debert, IR601 POI and at 34.5 kV terminal.

| Maximum generation system normal | 1N Onslow | 74N Springhill | 81N Debert | IR601 POI | IR601 34.5 kV MV | Unit |
|---|------------------|-----------------------|-------------------|------------------|-------------------------|-------------|
| IR601 Off | 2,325 | 1,288 | 1,633 | 1,252 | 234 | MVA |
| IR601 On | 2,353 | 1,311 | 1,666 | 1,304 | 298 | MVA |

Table 1: Maximum generation short circuit level system normal

The interrupting capability of the 138 kV circuit breakers at 1N-Onslow and 74N-Springhill is at least 3,500 MVA, much higher than the maximum short circuit levels at these locations with IR601 being on-line, hence IR601 will not incur any breaker upgrades at these substations.

As for the minimum short circuit level, a variety of N-1 system conditions were simulated for fault conditions under system minimum generation, and it is found that the lowest short circuit level at IR601 is when L-6613 is out of service between IR601 and 81N-Debert.

Table 2 shows minimum short circuit levels at IR601 POI, 34.5 kV bus and 720 V equivalent generator terminal bus.

| Minimum generation system normal | IR601 POI | IR601 34.5 kV MV | IR601 Terminal | Unit |
|---|------------------|-------------------------|-----------------------|-------------|
| IR601 Off | 949 | 233 | 180 | MVA |
| IR601 On | 1,001 | 297 | 250 | MVA |

Table 2: Minimum generation short circuit level system normal

Table 3 shows minimum short circuit levels at IR601 POI, 34.5 kV bus and 720 V equivalent generator terminal bus with L-6613 out of service between IR601 POI and Debert.

| Minimum generation with L-6613 Out (section from IR601 to Debert) | IR601 POI | IR601 34.5 kV MV | IR601 Terminal | Unit |
|---|------------------|-------------------------|-----------------------|-------------|
| IR601 Off | 484 | 194 | 156 | MVA |
| IR601 On | 536 | 257 | 227 | MVA |

Table 3: Minimum generation short circuit level with L-6613 out

Table 3 system three phase short circuit (with IR601 off-line) at the POI 138 kV is 484 MVA and short circuit level at 34.5 kV is 194 MVA. Hence, the short circuit ratio (SCR) for IR601 at 34.5 kV level is $194/60 = 3.2$ which is less than the minimum required SCR

of 5 for Vestas V162 wind turbines. Therefore, the IC needs to discuss with Vestas for the design of the wind turbines to operate properly at this SCR. In addition, the subsequent system impact study will verify the final SCR.

6.0 Voltage Flicker and Harmonics

The voltage flicker and harmonics can't be determined due to lack of information at this time. The subsequent SIS can do that at a later date.

7.0 Thermal Limits

7.1 NS Load Forecast

At the time of this assessment for IR601, the latest NSPI corporate load forecast available was in the "2021 Ten Year System Outlook" report issued by NS Power June 30, 2021. The load forecast for the year 2031 has NS system peak forecast of 2,262 MW with a firm peak of 2,057 MW. The total net system load includes system losses but excludes power plant station service loads.

The winter peak load for NS is modeled based on the above load forecast.

7.2 IR601 Model

Based on the information provided by the IC, the following was determined and modelled for IR601:

1. Using NSPI's OneGIS, the POI is determined to be about 34.6 km on L-6513 from 1N-Onslow substation.
2. There is no spur line from the POI on L-6613 to the IC's 138 kV substation as the site plan indicates it being at the POI.
3. The 138 kV to 34.5 kV transformer is modelled based on 9.5% positive impedance on 40 MVA base rating and X/R of 20. The nominal rating is modelled as 67 MVA.
4. The 34.4 kV to 720 V transformer is modelled based on 10.3% positive impedance on 7.3 MVA base rating. Since the IC did not provide the X/R ratio, a value of 10 was assumed. The nominal rating is modelled as 73 MVA.

5. The equivalent generator for the 10 wind turbines is modelled based on the bulletin, General Description EnVentus.pdf, provided by the IC for Vestas V162 wind turbines.
6. The impedances of the collector equivalent circuit are calculated based on the information that the IC provided in the one-line, 3-150-01-001-Layout.pdf, dated April, 2021.

7.3 IR601 Steady State Analysis Result

The load flow analysis was completed for generation dispatches under system light load, summer peak load, and winter peak load conditions. Generation dispatch was also chosen to represent import and export scenarios that take into account expected flows from the existing transmission service reservation associated with the Maritime Link (ML).

At the present, the firm export from Woodbine 345 kV bus in NS to the NS-NB border by the Maritime Link is 150 MW in winter when ML receives 320 MW from Newfoundland (NL) and 330 MW in non-winter when ML receives 475 MW from NL. Under these conditions, NSPI does not carry additional operating reserve for the through export from Woodbine to the NS-NB border. Any customer who buys this flow-through power will carry the additional reserve.

Also, at the present, firm import from NB to NS is zero in winter and in non-winter.

For each system dispatch chosen, a steady state analysis is performed and checked for the system performance with IR601 off-line and with IR601 on-line at full output in order to determine any thermal overload or voltage violation directly caused by IR601.

The initial attempt to dispatch pre-IR601 winter peak case with NB sending 300 MW to PEI in winter peak encountered some local thermal and voltage issues that are unrelated to IR601, hence the final cases were dispatched with NB sending 250 MW to PEI (measured at Memramcook) in winter peak prior to turning on IR601 at full output.

A variety of system dispatch cases were created with the above considerations and were tested in steady state using PSSE software version 33.12.1. The power flows of various interfaces inside and outside NS are displayed in Table 4.

| Power System Cases | | | | | | | | | | | | |
|--------------------|-------|--------|-------|-------|-------|------|------|------|------------|-----------|-----------|------------------|
| Case | NB-NS | NB-PEI | NB-NE | NL-NS | NB-HQ | CBX | ONI | ONS | IR601 Wind | Amh. Wind | Nutt Wind | Total Trans Wind |
| WP_C24b_R1 | -150 | 250 | 0 | 475 | -928 | 924 | 1000 | 792 | 60 | 31 | 50 | 549 |
| WP_C24a_R1 | -150 | 250 | 0 | 475 | -928 | 986 | 1058 | 792 | 0 | 31 | 50 | 489 |
| WP_C22b_R1 | 0 | 250 | 0 | 475 | -928 | 774 | 859 | 801 | 60 | 31 | 50 | 549 |
| WP_C22a_R1 | 0 | 250 | 0 | 475 | -928 | 835 | 916 | 801 | 0 | 31 | 50 | 489 |
| WP_C19b_R1 | 150 | 150 | 0 | 475 | -928 | 1039 | 1008 | 1034 | 60 | 4 | 7 | 128 |

Interconnection Feasibility Study Report

| Power System Cases | | | | | | | | | | | | |
|--------------------|-------|--------|-------|-------|-------|------|------|------|------------|-----------|-----------|------------------|
| Case | NB-NS | NB-PEI | NB-NE | NL-NS | NB-HQ | CBX | ONI | ONS | IR601 Wind | Amh. Wind | Nutt Wind | Total Trans Wind |
| WP_C19a_R1 | 150 | 150 | 0 | 475 | -928 | 1039 | 1008 | 975 | 0 | 4 | 7 | 68 |
| WP_C16b_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1086 | 1029 | 60 | 31 | 50 | 198 |
| WP_C16a_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 971 | 0 | 31 | 50 | 138 |
| WP_C13b_R1 | -320 | 250 | 0 | 475 | -928 | 1124 | 1159 | 778 | 60 | 31 | 50 | 198 |
| WP_C13a_R1 | -320 | 250 | 0 | 475 | -928 | 1124 | 1159 | 720 | 0 | 31 | 50 | 138 |
| WP_C10b_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 951 | 60 | 0 | 0 | 117 |
| WP_C10a_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 892 | 0 | 0 | 0 | 57 |
| WP_C07b_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 998 | 60 | 0 | 50 | 167 |
| WP_C07a_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 940 | 0 | 0 | 50 | 107 |
| WP_C04b_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 981 | 60 | 31 | 0 | 148 |
| WP_C04a_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 923 | 0 | 31 | 0 | 88 |
| WP_C01b_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 961 | 60 | 4 | 7 | 128 |
| WP_C01a_R1 | 0 | 250 | 0 | 475 | -928 | 1123 | 1087 | 904 | 0 | 4 | 7 | 68 |
| SP_C25b_R1 | -330 | 236 | -800 | 475 | -785 | 740 | 844 | 533 | 60 | 31 | 50 | 549 |
| SP_C25a_R1 | -330 | 236 | -800 | 475 | -785 | 801 | 902 | 533 | 0 | 31 | 50 | 489 |
| SP_C23b_R1 | 0 | 235 | -800 | 475 | -785 | 393 | 510 | 532 | 60 | 31 | 50 | 549 |
| SP_C23a_R1 | 0 | 235 | -800 | 475 | -785 | 452 | 568 | 532 | 0 | 31 | 50 | 489 |
| SP_C20b_R1 | 150 | 150 | -800 | 475 | -785 | 565 | 577 | 749 | 60 | 31 | 50 | 198 |
| SP_C20a_R1 | 150 | 150 | -800 | 475 | -785 | 625 | 635 | 749 | 0 | 31 | 50 | 138 |
| SP_C17b_R1 | 0 | 236 | -800 | 475 | -785 | 720 | 727 | 749 | 60 | 31 | 50 | 198 |
| SP_C17a_R1 | 0 | 236 | -800 | 475 | -785 | 781 | 785 | 749 | 0 | 31 | 50 | 138 |
| SP_C14b_R1 | -500 | 235 | -800 | 475 | -785 | 954 | 988 | 503 | 60 | 31 | 50 | 198 |
| SP_C14a_R1 | -500 | 236 | -800 | 475 | -785 | 953 | 988 | 445 | 0 | 31 | 50 | 138 |
| SP_C11b_R1 | 0 | 236 | -800 | 475 | -785 | 804 | 806 | 749 | 60 | 0 | 0 | 117 |
| SP_C11a_R1 | 0 | 236 | -800 | 475 | -785 | 864 | 863 | 749 | 0 | 0 | 0 | 57 |
| SP_C08b_R1 | 0 | 236 | -800 | 475 | -785 | 753 | 758 | 749 | 60 | 0 | 50 | 167 |
| SP_C08a_R1 | 0 | 236 | -800 | 475 | -785 | 813 | 816 | 749 | 0 | 0 | 50 | 107 |
| SP_C05b_R1 | 0 | 236 | -800 | 475 | -785 | 771 | 775 | 749 | 60 | 31 | 0 | 148 |
| SP_C05a_R1 | 0 | 236 | -800 | 475 | -785 | 831 | 832 | 749 | 0 | 31 | 0 | 88 |
| SP_C02b_R1 | 0 | 236 | -800 | 475 | -785 | 792 | 795 | 749 | 60 | 4 | 7 | 128 |
| SP_C02a_R1 | 0 | 236 | -800 | 475 | -785 | 852 | 852 | 749 | 0 | 4 | 7 | 68 |
| LL_C21b_R1 | 200 | 100 | -1000 | -90 | -727 | 53 | 0 | 272 | 60 | 31 | 50 | 198 |
| LL_C21a_R1 | 200 | 100 | -1000 | -40 | -727 | 111 | 56 | 272 | 0 | 31 | 50 | 138 |
| LL_C18b_R1 | 0 | 63 | -1000 | -40 | -727 | 254 | 198 | 272 | 60 | 31 | 50 | 198 |
| LL_C18a_R1 | 0 | 63 | -1000 | -40 | -727 | 312 | 255 | 272 | 0 | 31 | 50 | 138 |
| LL_C15b_R1 | -500 | 63 | -1000 | 475 | -727 | 777 | 705 | 273 | 60 | 31 | 50 | 198 |
| LL_C15a_R1 | -500 | 63 | -1000 | 475 | -727 | 838 | 762 | 273 | 0 | 31 | 50 | 138 |

| Power System Cases | | | | | | | | | | | | |
|--------------------|-------|--------|-------|-------|-------|-----|-----|-----|------------|-----------|-----------|------------------|
| Case | NB-NS | NB-PEI | NB-NE | NL-NS | NB-HQ | CBX | ONI | ONS | IR601 Wind | Amh. Wind | Nutt Wind | Total Trans Wind |
| LL_C12b_R1 | 0 | 63 | -1000 | -40 | -727 | 333 | 276 | 272 | 60 | 0 | 0 | 117 |
| LL_C12a_R1 | 0 | 63 | -1000 | -40 | -727 | 392 | 333 | 272 | 0 | 0 | 0 | 57 |
| LL_C09b_R1 | 0 | 63 | -1000 | -40 | -727 | 285 | 229 | 272 | 60 | 0 | 50 | 167 |
| LL_C09a_R1 | 0 | 63 | -1000 | -40 | -727 | 343 | 286 | 272 | 0 | 0 | 50 | 107 |
| LL_C06b_R1 | 0 | 63 | -1000 | -40 | -727 | 302 | 245 | 272 | 60 | 31 | 0 | 148 |
| LL_C06a_R1 | 0 | 63 | -1000 | -40 | -727 | 360 | 303 | 272 | 0 | 31 | 0 | 88 |
| LL_C03b_R1 | 0 | 63 | -1000 | -40 | -727 | 322 | 265 | 272 | 60 | 4 | 7 | 128 |
| LL_C03a_R1 | 0 | 63 | -1000 | -40 | -727 | 380 | 322 | 272 | 0 | 4 | 7 | 68 |

Table 4: Power system cases

Applicable contingencies in NS and some contingencies in NB around Memramcook substation were simulated in steady state for the above cases. These contingencies are shown in Table 5. Please note that 67N-815 contingency is the same as 67N-814 contingency due to the empty node adjacent to 67N-815 breaker. In NS, system normal uses Rate A and N-1 contingencies use Rate B, whereas in NB, system normal uses Rate A and N-1 contingencies use Rate C. Contingencies marked with * denotes applicable in service SPS may be armed.

| Contingencies in NS and NB | | | | |
|----------------------------|----------|---------|-------------|---------|
| 101S_701 | 120H_710 | 30N_B61 | 67N_706 | 90H_608 |
| 101S_702 | 120H_711 | 30N_T61 | 67N_710 | 90H_609 |
| 101S_703 | 120H_712 | 3C_711 | 67N_713 | 90H_611 |
| 101S_704 | 120H_713 | 3C_712 | 67N_811* | 90H_612 |
| 101S_705 | 120H_714 | 3C_713 | 67N_812 | 90H_T1 |
| 101S_706 | 120H_715 | 3C_714 | 67N_813 | 91H_511 |
| 101S_711 | 120H_716 | 3C_715 | 67N_814 | 91H_513 |
| 101S_712 | 120H_720 | 3C_716 | 67N_T71 | 91H_516 |
| 101S_713 | 120H_SVC | 3C_T71 | 67N_T81 | 91H_521 |
| 101S_811 | 120H_T71 | 3C_T72 | 67N_T82 | 91H_523 |
| 101S_812* | 120H_T72 | 3C710* | 67N711* | 91H_603 |
| 101S_813* | 132H_602 | 3C720* | 67N712* | 91H_604 |
| 101S_814* | 132H_603 | 3S_T1 | 70037004* | 91H_605 |
| 101S_816 | 132H_605 | 47C_602 | 70087009Sep | 91H_606 |
| 101S_T81 | 132H_606 | 47C_603 | 74N_B61 | 91H_607 |
| 101S_T82 | 1C_689 | 47C_674 | 74N_T61 | 91H_608 |
| 103H_600 | 1C_B61 | 47C_T63 | 79N-T81* | 91H_609 |
| 103H_608 | 1C_B62 | 47C_T64 | 85S_B61 | 91H_611 |
| 103H_681 | 1C_G2 | 47C_T65 | 85S_G1 | 91H_613 |
| 103H_881 | 1N_600 | 47C_T67 | 88S_710 | 91H_621 |

| Contingencies in NS and NB | | | | |
|----------------------------|-------------|-----------|-----------|--------------|
| 103H_B61 | 1N_601 | 49N_600 | 88S_711 | 91H_T11 |
| 103H_B62 | 1N_613 | 4C_T2 | 88S_712 | 91H_T62 |
| 103H_T81 | 1N_B51 | 4C_T63 | 88S_713 | 91H_TC3 |
| 104H600 | 1N_B52 | 50N_500 | 88S_714 | 91N_701 |
| 108H_600 | 1N_B61 | 50N_604 | 88S_715 | IR601_POI |
| 108H_B1 | 1N_B62 | 50N_B55 | 88S_720 | L-5003 |
| 108H_B3 | 1N_C61 | 50N_B57 | 88S_721 | L-5011 |
| 113H_600 | 1N_T1 | 50N_G6 | 88S_722 | L5012 |
| 120H_621 | 1N_T4 | 50N_T12 | 88S_723* | L-5014 |
| 120H_622 | 2CB61WC1 | 50N_T8 | 88S_G4 | L-5015 |
| 120H_623 | 2CB62WC1 | 50NB61G6 | 88S_T71 | L-5016 |
| 120H_624 | 2S_513 | 50NB62G5 | 88S_T72 | L-5017 |
| 120H_625 | 2S_600 | 67N_701 | 89S_G1 | L-5019 |
| 120H_626 | 2S_B64 | 67N_702 | 90H_602 | L-5020 |
| 120H_627 | 2S_B65 | 67N_703 | 90H_603 | L1108 |
| 120H_628 | 2S_T1 | 67N_704 | 90H_604 | L1142 |
| 120H_629 | L-5534 | L6012 | L6523 | L1108 |
| L-5021 | L-5535 | L6013 | L6531 | L1142 |
| L-5022 | L-5536 | L6014 | L6535 | L1143 |
| L-5023L5053 | L-5537 | L6015 | L6536 | L1148-L1151* |
| L-5024 | L-5538 | L6016 | L6537* | L1157 |
| L-5025 | L-5539 | L6020 | L6538 | L1190 |
| L-5026 | L-5541 | L6021 | L6539 | L1190-L1215 |
| L-5027 | L-5546 | L6024 | L6551 | L1244 |
| L-5028 | L-5547L5551 | L6025 | L6552 | L3004 |
| L-5029L5030 | L-5548 | L6033 | L6613_1N | L3006 |
| L-5032L5004 | L-5549 | L60335039 | L6613_74N | L3013 |
| L-5033 | L-5550L5582 | L60336035 | L7001 | L3017_3019 |
| L-5035 | L-5559L5579 | L6035 | L7002 | Lepreau |
| L-5036 | L-5560 | L6038 | L7003 | ME1-10 |
| L-5037L3031 | L-5561L5565 | L6040 | L7004 | ME1-11 |
| L-5039 | L-5563 | L60406042 | L7005* | ME1-12 |
| L-5040 | L-5564L5576 | L6042 | L7008 | ME1-13 |
| L5041 | L-5571 | L6043 | L7009 | ME1-14 |
| L-5042 | L-5573L5575 | L6044 | L7011 | ME1-15 |
| L5049 | L-5580 | L6047 | L7012 | ME1-16 |
| L-5054 | L6001 | L6048 | L7014 | ME1-6 |
| L-5058 | L6002_90H | L6051 | L7015 | ME1-7 |
| L-5500 | L6002_99W | L6052 | L7019 | ME1-8 |

| Contingencies in NS and NB | | | | |
|----------------------------|-----------|-----------|-----------|--------|
| L-5501 | L6003 | L6053 | L7021 | ME1-9 |
| L-5502 | L60036007 | L6054 | L70216534 | ME3-1* |
| L-5505 | L60036009 | L6055 | L7022 | ME3-2* |
| L-5506 | L6004 | L6503 | L8001* | ME3-3* |
| L-5507L5508 | L6005 | L6507 | L8002 | Mem_T3 |
| L-5511 | L60056010 | L65076508 | L80027009 | |
| L-5512 | L60056016 | L6508 | L8003* | |
| L-5521 | L6006 | L6510 | L8004* | |
| L-5524 | L6007 | L6511 | ML_2Poles | |
| L-5527A | L6008 | L6514 | ML_Pole1 | |
| L-5527B | L6009 | L6515 | ML_Pole2 | |
| L-5530 | L6010 | L6516 | PHP | |
| L-5531 | L60106011 | L6517 | 90H_605 | |
| L-5532 | L6011 | L6518 | 90H_606 | |
| L-5533L5581 | 2S_T2 | 67N_705 | 90H_607 | |

Table 5: Contingencies in NS and NB studied

In general, IR601 rated output does not violate thermal or voltage criteria. However, when it displaces Halifax generation in winter peak, the Metro Dynamic Reactive Reserves can be marginally exceeded and 120H-T71 or 120H-T72 transformer at Brushy Hill substation can marginally exceed their nominal ratings under certain N-1 contingencies. At this time, this assessment considers them marginal and no associated system upgrades are identified. The subsequent System Impact Study will make the final determination.

8.0 Voltage Limits

The steady state assessment of the power flow cases used in this assessment shows no voltage violations that are directly caused by IR601.

Regarding power factor, NSPI requires IR601 to meet +/-0.95 on the high voltage side of the IC substation transformer.

Figure 5 shows power factor on the high voltage side of the IC substation transformer when IR601 generates maximum reactive power output. Table 6 shows that IR601 does not meet NSPI's required power factor of +0.95 or less, hence IR601 will require power factor correction. This will be further examined in the SIS.




Figure 5 Power Factor with Qmax

| IR601 Max MW | IR601 Max MVAR | Tx HV MW | Tx HV MVAR | Tx HV Power Factor |
|--------------|----------------|----------|------------|--------------------|
| 60.0 | 26.6 | 57.3 | 6.5 | 0.994 |

Table 6: Power factor with Qmax

Figure 6 shows power factor on the high voltage side of the IC substation transformer when IR601 absorbs maximum reactive power output. Table 7 shows that IR601 meets NSPI's required power factor of -0.95 when it absorbs reactive power from the system.




Figure 6 Power Factor with Qmin

| IR601 Max MW | IR601 Max MVAR | Tx HV MW | Tx HV MVAR | Tx HV Power Factor |
|--------------|----------------|----------|------------|--------------------|
| 60.0 | -19.9 | 57.3 | -39.6 | 0.823 |

Table 7: Power factor with Qmin

A centralized controller will be required which continuously adjusts individual generator reactive power output within the plant capability limits and regulates the voltage at the 34.5 kV bus voltage. The voltage controls must be responsive to voltage deviations at the terminals of the Interconnection Facility substation; be equipped with a voltage set-point control; and also have the ability to slowly adjust the set-point over several (5-10) minutes to maintain reactive power within the individual generators capabilities (Please refer to NSPI's TSIR). The details of the specific control features, control strategy and settings will be reviewed and addressed in the SIS, as will the dynamic performance of the generator

and its excitation. Line drop compensation, voltage droop, control of separate switched capacitor banks must be provided.

The NSPI System Operator must have manual and remote control of the voltage set-point and the reactive set-point of this facility to coordinate reactive power dispatch requirements.

This facility must also have low voltage ride-through capability as per NSPI’s TSIR. The SIS will state specific options, controls and additional facilities that are required to achieve this.

9.0 System Security / Bulk Power Analysis

L-6613 is classified as BPS (Bulk Power System) as defined by NPCC and BES (Bulk Electricity System) as defined by NERC. L-6613 is currently on NSPI’s 2021 BPS list and BES list, hence IR601 interconnection to L-6613 will be required to meet NPCC and NERC requirements. The SIS will determine the BPS and BES status of IR601.

10.0 Loss Factor

The Loss Factor calculation is based on the peak load case and is used only for comparison purposes. The winter peak load flow case is run with and without the new facility in service, while keeping 91H-Tufts Cove Generator TC3 as the NS Area Interchange bus. This methodology reflects the load centre in and around 91H-Tufts Cove. A negative loss factor reflects a reduction in system losses.

The loss factor for IR601 is shown in Table 10:

| Loss Factor | |
|--------------------------------|-------|
| Description | MW |
| IR601 at POI on L-6613 | 60 |
| TC3 with IR601 at rated output | 74.8 |
| TC3 with IR601 Off | 130 |
| IR601 Loss Factor | +8.0% |

Table 8: Loss factor

11.0 Expected Facilities Required for Interconnection

The following facility changes will be required to connect IR601 to L-6613.

a. Required Network Upgrades

- Modification of NSPI protection systems at 1N-Onslow and 74N-Springhill on line L-6613 as IR601 will be connected to this line.
- Install a new 138kV substation complete with 3 breaker ring bus at the POI to L-6613 and control and protection as acceptable to NSPI. A Remote Terminal Unit (RTU) to interface with NSPI's SCADA, with telemetry and controls as required by NSPI.

b. Required Transmission Provider's Interconnection Facilities (TPIF):

- Install jumpers from NSPI Interconnection Facility substation to the IC substation.
- Add P&C, control and communications between the wind farm and NSPI SCADA system (to be specified).

c. Required Interconnection Customer's Interconnection Facilities (ICIF)

- Facilities to provide 0.95 leading and lagging power factor when delivering rated output at the HV terminals of the IC Substation Step Up Transformer when the voltage at that point is operating between 95 and 105 % of nominal.
- Centralized controls. These will provide centralized voltage set-point controls and are known as Farm Control Units (FCU). The FCU will control the 34.5 kV bus voltage and the reactive output of the machines. Responsive (fast-acting) controls are required. The controls will also include a curtailment scheme which will limit or reduce total output from the facility, upon receipt of a telemetered signal from NSPI's SCADA system. Please refer to NSPI's TSIR for additional requirements such as primary frequency responses (curtailed and un-curtailed), full reactive power capability over active power range and voltage/frequency ride through.
- NSPI will have control and monitoring of reactive output of this facility, via the centralized controller. This will permit the NSPI Operator to raise or lower the voltage set-point remotely.
- Low voltage ride-through capability per Nova Scotia Power Transmission System Interconnection Requirements (TSIR) document.
- Real-time monitoring (including an RTU) of the interconnection facilities. Local wind speed and direction, MW and MVAR, as well as bus voltages are required.
- Facilities for NSPI to execute high speed rejection of generation (transfer trip) if determined in SIS. The plant may be incorporated into SPS run-back schemes.
- Automatic Generation Control to assist with tie-line regulation.
- The facility must meet NSPI's TSIR as published on the NSPI OASIS site at <https://www.nspower.ca/oasis/standards-codes>.

12.0 Facilities and Network Upgrades Cost Estimate

The cost estimates for NSPI Interconnection Facilities (IF) and Network Upgrades for interconnecting IR601 to L-6613 are shown in Table 9.

Please note that this cost estimate is high level, non-binding in 2021 Canadian dollars. This does not include additional costs to be identified by the subsequent SIS and Facility Study.

L-6613 is classified as BPS (Bulk Power System) and BES (Bulk Electricity System) in NSPI’s 2021 BPS list and BES list, hence the requirement for a three breaker ring bus substation as per NSPI’s “Transmission System Interconnection Requirements”, dated February 25, 2021, Version 1.1.

| Item | Network Upgrades | Estimate |
|------|---|-------------|
| I | P&C modifications at 1N-Onslow and 74N-Springhill for L-6613 | \$400,000 |
| II | The breaker ring bus 138 kV substation complete with P&C at NSPI IF substation and connection to L-6613 | \$6,250,000 |
| | Sub-total for Network Upgrades | \$6,650,000 |
| Item | TPIF Upgrades | Estimate |
| I | Install jumpers from NSPI IF substation to IC substation | \$200,000 |
| II | P&C relaying equipment | \$100,000 |
| III | NSPI supplied RTU | \$65,000 |
| IV | Tele-protection and SCADA communications | \$150,000 |
| | Sub-total for TPIF Upgrades | \$515,000 |
| Item | Total Upgrades | Estimate |
| | Network Upgrades + TPIF Upgrades | \$7,165,000 |
| | Contingency (10%) | \$716,500 |
| | Total (Incl. 10% contingency and Excl. HST) | \$7,881,500 |

Table 9: Cost estimates

13.0 Preliminary Scope of the SIS

The following provides a preliminary scope of work for the subsequent SIS for IR601. The SIS will include a more comprehensive assessment of the technical issues and requirements to interconnect generation as requested. It will include contingency analysis, system stability, ride through, and operation following a contingency (N-1 operation). The SIS must determine the facilities required to operate this facility at full capacity, withstand any contingencies (as defined by the criteria appropriate to the location) and identify any restrictions that must be placed on the system following a first contingency loss. The SIS will confirm the options and ancillary equipment that the customer must install to control

flicker, voltage, frequency response, active power, low voltage ride-through, frequency ride-through, and power factor to meet NSPI TSIR requirements. The SIS will be conducted in accordance with the GIP with the assumption that all appropriate higher-queued projects will proceed and the facilities associated with those projects are installed.

The following outline provides the minimum scope that must be complete in order to assess the impacts. It is recognized the actual scope may deviate, to achieve the primary objectives. The SIS will consider but not be limited to the following:

- 1) Correct models of the entire facility from the POI to the IC substation and IR601 facility including the collector circuits.
- 2) Facilities that the customer must install to meet the requirements of the GIP and NSPI's latest version of "Transmission System Interconnection Requirements", informally referred to as NSPI's Grid Code.
- 3) The minimum transmission additions/upgrades that are necessary to permit operation of this Generating Facility, under all dispatch conditions, meeting NPCC and NERC criteria.
- 4) Guidelines and restrictions applicable to first contingency operation (curtailments etc.).
- 5) Under-frequency load shedding impacts.
- 6) Metro Dynamic Reactive Reserves requirement and short time ratings of 120H-T71 and 120H-T72.

The SIS will assess system contingencies such that the system performance will meet the following criteria:

- Table 1 "Planning Design Criteria" of NPCC Directory 1 latest revision as approved by NS-UARB.
- Table 1 "Steady State & Stability Performance Planning Events" of NERC TPL-001-x latest revision as approved by NS-UARB.
- NSPI System Design Criteria, report number NSPI-TPR-003-4 latest revision as approved by NSPI and submitted to NS-UARB.

Additionally, electromagnetic transient study may be required to account for IR601 control system to coordinate with other facilities in the transmission system and to ensure fault ride through.

Any changes to SPS schemes required for operation of this generating facility, in addition to existing generation and facilities that can proceed before this project, will be determined by the SIS as well as any required additional transmission facilities. The determination will be based on all NERC and NPCC criteria approved by the UARB as well as NSPI

guidelines and good utility practice. The SIS will also determine the contingencies for which this facility must be curtailed.

Nova Scotia Power Inc.
Transmission System Operations
2021-08-31